

## **TABLES**

**TABLE 1**  
**MONITORING WELL SUMMARY**  
Defense Fuel Support Point, Norwalk  
Norwalk, California

Well	Installation Date	Installed By	Total Depth (ft bgs) <sup>1</sup>	Casing Diameter (inches)	Screen Interval (ft bgs)	Slot Size (inches)	Casing Elevation (ft msl) <sup>2</sup>
BW-1	05/16/96	GMX <sup>3</sup>	55	5	31.9 - 51.4	0.01	73.17
BW-2	05/20/96	GMX	53.5	5	27 - 46.5	0.01	73.57
BW-3	05/17/96	GMX	55.5	5	30.6 - 50	0.01	74.16
BW-4	05/20/96	GMX	53.1	5	28.2 - 47	0.01	74.61
BW-5	05/23/96	GMX	52.5	5	27 - 45.5	0.01	73.59
BW-6	05/22/96	GMX	52.4	5	27.6 - 46.9	0.01	73.48
BW-7	05/22/96	GMX	52	5	27.1 - 46.3	0.01	74.65
BW-8	05/21/96	GMX	51.5	5	27 - 46.4	0.01	75.08
BW-9	05/21/96	GMX	52.5	5	26.9 - 46.4	0.01	76.19
EXP-1	03/06/92	WC <sup>4</sup>	128.5	4	82 - 122	0.01	78.44
EXP-2	10/15/92	WC	149	4	90 - 120	0.02	79.43
EXP-3	10/20/92	WC	150	4	85 - 115	0.01	77.58
EXP-4	07/07/98	GMX	118	4	96.1 - 115.2	0.02	79.81
EXP-5	07/08/98	GMX	120	4	94.4 - 113.4	0.02	72.41
GMW-1	05/16/91	GTI <sup>5</sup>	50	4	20 - 50	0.01	74.77
GMW-2	05/16/91	GTI	50	4	20 - 50	0.01	73.57
GMW-3	05/17/91	GTI	50	4	20 - 50	0.01	75.10
GMW-4	05/21/91	GTI	50	4	20 - 50	0.01	75.45
GMW-5	05/21/91	GTI	50	4	20 - 50	0.01	77.61
GMW-6	07/09/91	GTI	50	4	25 - 50	0.01	77.31
GMW-7	07/09/91	GTI	50	4	25 - 50	0.01	75.84
GMW-8	07/10/91	GTI	50	4	25 - 50	0.01	73.20
GMW-9	07/08/91	GTI	50	4	20 - 50	0.01	74.44
GMW-10	07/08/91	GTI	50	4	25 - 50	0.01	74.67
GMW-11	07/09/91	GTI	50	4	20 - 50	0.01	72.90
GMW-12	07/09/91	GTI	50	4	25 - 50	0.01	75.21
GMW-13	07/08/91	GTI	50	4	25 - 50	0.01	74.17
GMW-14	07/10/91	GTI	50	4	25 - 50	0.01	74.72
GMW-15	07/30/91	GTI	50	4	25 - 50	0.01	76.21
GMW-16	08/01/91	GTI	50	4	25 - 50	0.01	77.00
GMW-17	08/01/91	GTI	50	4	25 - 50	0.01	74.66
GMW-18	07/31/91	GTI	50	4	25 - 50	0.01	75.36
GMW-19	07/31/91	GTI	50	4	25 - 50	0.01	76.83
GMW-20	08/01/91	GTI	50	4	25 - 50	0.01	75.10
GMW-21 <sup>6</sup>	08/02/91	GTI	50	4	25 - 50	0.01	76.23
GMW-22	08/02/91	GTI	61	4	25 - 60	0.01	74.17
GMW-23	08/02/91	GTI	60	4	25 - 60	0.01	74.85
GMW-24	08/05/91	GTI	60	4	25 - 60	0.01	74.04
GMW-25	01/10/92	GTI	50	6	20 - 50	0.01	74.29
GMW-26	01/07/92	GTI	51.5	4	20 - 50	0.01	74.52
GMW-27	01/10/92	GTI	50	4	20 - 50	0.01	74.41

**TABLE 1**  
**MONITORING WELL SUMMARY**  
Defense Fuel Support Point, Norwalk  
Norwalk, California

Well	Installation Date	Installed By	Total Depth (ft bgs) <sup>1</sup>	Casing Diameter (inches)	Screen Interval (ft bgs)	Slot Size (inches)	Casing Elevation (ft msl) <sup>2</sup>
GMW-28	01/07/92	GTI	50	4	20 - 50	0.01	74.68
GMW-29	01/09/92	GTI	50	4	20 - 50	0.01	77.57
GMW-30	01/09/92	GTI	51.5	6	20 - 50	0.01	74.91
GMW-31	06/02/93	GTI	65	4	25 - 65	0.01	76.50
GMW-32	06/01/93	GTI	50	4	20 - 50	0.02	74.62
GMW-33	06/01/93	GTI	50	4	20 - 50	0.02	74.88
GMW-34	06/03/93	GTI	50	4	20 - 50	0.02	75.25
GMW-35	06/04/93	GTI	50	4	20 - 50	0.02	76.12
GMW-36	04/11/94	GTI	50	4	20 - 50	0.01	74.53
GMW-37	04/11/94	GTI	50	4	20 - 50	0.01	77.32
GMW-38	04/12/94	GTI	50	4	20 - 50	0.01	75.47
GMW-39	04/12/94	GTI	50	4	20 - 50	0.01	75.05
GMW-40	06/29/94	GTI	50.5	4	20 - 50	0.01	73.13
GMW-41	06/30/94	GTI	50.5	4	20 - 50	0.01	74.46
GMW-42	06/30/94	GTI	50.5	4	20 - 50	0.01	75.50
GMW-43	07/01/94	GTI	50.5	4	20 - 50	0.01	74.44
GMW-44	07/01/94	GTI	50.5	4	20 - 50	0.01	74.45
GMW-45	07/01/94	GTI	50.5	4	20 - 50	0.01	75.67
GMW-46	07/05/94	GTI	50.5	4	20 - 50	0.01	76.10
GMW-47	07/05/94	GTI	50.5	4	20 - 50	0.01	75.98
GMW-48	07/05/94	GTI	50.5	4	20 - 50	0.01	75.03
GMW-49	07/06/94	GTI	50.5	4	20 - 50	0.01	74.75
GMW-50	12/19/94	GTI	46.5	4	15 - 45	0.01	75.51
GMW-51	12/19/94	GTI	41.5	4	15 - 40	0.01	75.93
GMW-52	12/19/94	GTI	41.5	4	15 - 40	0.01	75.03
GMW-53	12/19/94	GTI	46.5	4	15 - 45	0.01	74.90
GMW-54	12/20/94	GTI	46.5	4	15 - 45	0.01	75.16
GMW-55	12/20/94	GTI	41.5	4	15 - 40	0.01	74.60
GMW-56	08/12/98	FDGTI <sup>7</sup>	55	2	20 - 55	0.02	76.50
GMW-56	08/12/98	FDGTI	55	4	20 - 55	0.02	76.52
GMW-57	08/13/98	FDGTI	55	2	19 - 54	0.02	76.66
GMW-57	08/13/98	FDGTI	55	4	19 - 54	0.02	76.66
GMW-58	08/14/98	FDGTI	55	2	20 - 55	0.02	75.46
GMW-58	08/14/98	FDGTI	55	4	20 - 55	0.02	75.48
GMW-59	08/14/98	FDGTI	55	2	20 - 55	0.02	75.28
GMW-59	08/14/98	FDGTI	55	4	20 - 55	0.02	75.28
GMW-60	04/14/04	Parsons	50	4	25 - 40	0.01	76.24
GMW-61	04/14/04	Parsons	50	4	30 - 40	0.01	75.60
GMW-62	07/02/07	Parsons	40.5	4	20 - 40	0.01	76.34
GMW-63	09/29/08	Parsons	41	4	20 - 40	0.02	77.32
GMW-64	09/29/08	Parsons	41	4	19.5 - 39.5	0.02	75.84

**TABLE 1**  
**MONITORING WELL SUMMARY**  
Defense Fuel Support Point, Norwalk  
Norwalk, California

Well	Installation Date	Installed By	Total Depth (ft bgs) <sup>1</sup>	Casing Diameter (inches)	Screen Interval (ft bgs)	Slot Size (inches)	Casing Elevation (ft msl) <sup>2</sup>
GMW-65	07/06/09	Parsons	41.5	4	21 - 41	0.02	76.78
GMW-66	09/08/09	Parsons	40.5	4	20 - 40	0.02	77.00
GMW-O-1	03/04/92	GTI	51.5	4	19 - 49.5	0.01	71.45
GMW-O-2	03/02/92	GTI	51.5	4	20 - 50	0.01	72.54
GMW-O-3	03/02/92	GTI	51.5	4	20 - 50	0.01	72.19
GMW-O-4	03/03/92	GTI	51.5	4	20 - 50	0.01	71.95
GMW-O-4 (MID)	03/03/92	GTI	66.5	4	54.5 - 64.5	0.01	72.24
GMW-O-5	03/04/92	GTI	51.5	4	20 - 50	0.01	72.36
GMW-O-6	05/18/92	GTI	51.5	4	20 - 50	0.01	71.41
GMW-O-7	05/19/92	GTI	51.5	4	20 - 50	0.01	70.98
GMW-O-8	05/18/92	GTI	51	4	19.5 - 49.5	0.01	70.91
GMW-O-9	07/29/92	GTI	51.5	4	20 - 50	0.01	73.50
GMW-O-10	07/29/92	GTI	51.5	4	20 - 50	0.01	73.98
GMW-O-11	05/20/92	GTI	51.5	4	20 - 50	0.01	74.17
GMW-O-12	05/21/92	GTI	51.5	4	20 - 50	0.01	73.49
GMW-O-14	05/20/92	GTI	51.5	4	20 - 50	0.01	74.08
GMW-O-15	04/19/94	GTI	50	4	20 - 50	0.02	74.23
GMW-O-16	04/19/94	GTI	50	4	20 - 50	0.02	74.10
GMW-O-17	07/26/94	GMX	41	4	20.4 - 39.5	0.01	73.78
GMW-O-18	07/25/94	GMX	41	4	20.8 - 40.4	0.01	74.36
GMW-O-19	07/29/94	GMX	41.5	4	20.2 - 39.9	0.01	74.46
GMW-O-20	06/15/95	GMX	45.9	4	---8	---	73.34
GMW-O-21	06/19/97	GMX	45.9	4	25.5 - 45.5	0.01	71.43
GMW-O-22	---	GMX	41	4	---	---	74.36
GMW-SF-7	07/27/94	GMX	41	4	20.1 - 39.9	0.01	75.26
GMW-SF-8	07/28/94	GMX	41	4	19.5 - 39.5	0.01	76.75
GMW-SF-9	04/01/03	GMX	47	4	36.6 - 46.2	0.02	73.00
GMW-SF-10	04/02/03	GMX	47	4	36.7 - 46.4	0.02	75.77
GW-1	06/12/95	GTI	63	1	25 - 60	0.02	75.46
GW-1	06/12/95	GTI	63	4	25 - 60	0.02	75.97
GW-2	06/12/95	GTI	63	1	25 - 60	0.02	76.39
GW-2	06/12/95	GTI	63	4	25 - 60	0.02	75.78
GW-3	06/13/95	GTI	63	1	25 - 60	0.02	76.56
GW-3	06/13/95	GTI	63	4	25 - 60	0.02	75.79
GW-4	06/13/95	GTI	63	1	24 - 59	0.02	74.77
GW-4	06/13/95	GTI	63	4	24 - 59	0.02	73.86
GW-5	06/15/95	GTI	63	1	25.5 - 60.5	0.02	77.09
GW-5	06/15/95	GTI	63	4	25.5 - 60.5	0.02	76.99
GW-6	06/15/95	GTI	63	1	25 - 60	0.02	77.41
GW-6	06/15/95	GTI	63	4	25 - 60	0.02	76.38
GW-7	06/16/95	GTI	63	1	25 - 60	0.02	76.76

**TABLE 1**  
**MONITORING WELL SUMMARY**  
Defense Fuel Support Point, Norwalk  
Norwalk, California

Well	Installation Date	Installed By	Total Depth (ft bgs) <sup>1</sup>	Casing Diameter (inches)	Screen Interval (ft bgs)	Slot Size (inches)	Casing Elevation (ft msl) <sup>2</sup>
GW-7	06/16/95	GTI	63	4	25 - 60	0.02	75.02
GW-8	06/14/95	GTI	63	1	24 - 59	0.02	76.88
GW-8	06/14/95	GTI	63	4	24 - 59	0.02	76.15
GW-13	04/26/07	Parsons	65	1	25 - 65	0.02	77.00
GW-13	04/26/07	Parsons	67	6	25 - 65	0.02	76.85
GW-14	04/26/07	Parsons	65	1	25 - 65	0.02	76.55
GW-14	04/26/07	Parsons	67	6	25 - 65	0.02	76.54
GW-15	04/26/07	Parsons	62.5	1	20.5 - 60.5	0.02	75.36
GW-15	04/26/07	Parsons	60.5	6	20.5 - 60.6	0.02	74.94
GW-16p	07/07/09	Parsons	61.3	1	21 - 61	0.02	76.55
GW-16	07/07/09	Parsons	63	6	20.5 - 60.5	0.02	76.33
GWR-1	07/11/91	GTI	50	4	25 - 50	0.01	73.65
GWR-2	07/12/91	GTI	50	4	25 - 50	0.01	73.66
GWR-3	01/10/92	GTI	50	6	20 - 50	0.01	74.93
HL-1	10/14/86	HLA <sup>9</sup>	39	4	18 - 38	0.01	75.83
HL-2	10/13/86	HLA	39	4	16.5 - 36.5	0.01	76.94
HL-3	10/15/86	HLA	44	4	19 - 39	0.01	76.86
HL-4	10/16/86	HLA	39	4	18 - 38.5	0.01	75.75
HL-5	10/16/86	HLA	39.5	4	18.5 - 39	0.01	76.13
MW-6	08/09/90	WC	50	4	18 - 48	0.01	77.20
MW-7	08/27/90	WC	50	4	19 - 48	0.01	78.13
MW-8	08/24/90	WC	51	4	18 - 48	0.01	76.06
MW-9	08/08/90	WC	50	4	18 - 48	0.01	77.11
MW-10	08/24/90	WC	51	4	18 - 48	0.01	79.12
MW-11	08/09/90	WC	50	4	18 - 48	0.01	78.17
MW-12	08/27/90	WC	50	4	18 - 48	0.01	75.76
MW-13	08/23/90	WC	50	4	18 - 48	0.01	78.25
MW-14	08/07/90	WC	50	4	18 - 48	0.01	78.60
MW-15	08/07/90	WC	50	4	18 - 48	0.01	76.99
MW-16	08/08/90	WC	50	4	18 - 48	0.01	76.87
MW-17	08/06/90	WC	50	4	18 - 48	0.01	77.86
MW-18 (MID)	06/10/91	WC	62.2	4	50 - 60	0.01	75.67
MW-19 (MID)	06/11/91	WC	62.2	4	49.5 - 59.5	0.01	78.14
MW-20 (MID)	06/12/91	WC	65.7	4	43 - 53	0.01	77.19
MW-21 (MID)	06/12/91	WC	62.4	4	47 - 57	0.01	77.55
MW-22 (MID)	06/13/91	WC	57.9	4	42 - 52	0.01	79.57
MW-23 (MID)	06/14/91	WC	57.1	4	42 - 52	0.01	79.59
MW-24	06/14/91	WC	47	4	14 - 44	0.01	78.51
MW-25	06/17/91	WC	47.2	4	22.5 - 42.5	0.01	79.15
MW-26	06/17/91	WC	47.3	4	23.5 - 43.5	0.01	77.40
MW-27	06/17/91	WC	52.3	4	18 - 48	0.01	78.46

**TABLE 1**  
**MONITORING WELL SUMMARY**  
Defense Fuel Support Point, Norwalk  
Norwalk, California

Well	Installation Date	Installed By	Total Depth (ft bgs) <sup>1</sup>	Casing Diameter (inches)	Screen Interval (ft bgs)	Slot Size (inches)	Casing Elevation (ft msl) <sup>2</sup>
MW-28	6/19/91	WC	51.5	4	16.5 - 46.5	0.01	78.53
MW-29	06/19/91	WC	52.4	4	17.5 - 47.5	0.01	79.13
MW-O-1	01/22/91	GMX	40	2	25 - 40	0.02	75.48
MW-O-2	01/23/91	GMX	40	2	25 - 40	0.02	71.90
MW-O-3	10/25/91	GMX	41	6	20.5 - 41	0.01	74.53
MW-O-4	10/25/91	GMX	41	4	20.5 - 41	0.01	75.00
MW-SF-1	06/18/90	GMX	40	4	25 - 40	0.02	78.93
MW-SF-2	06/18/90	GMX	40	4	25 - 40	0.02	78.45
MW-SF-3	06/18/90	GMX	40	4	25 - 40	0.02	77.62
MW-SF-4	06/19/90	GMX	40	4	25 - 40	0.02	79.38
MW-SF-5	09/19/90	GMX	40	4	23 - 38	0.02	79.74
MW-SF-6	09/19/90	GMX	40	4	24 - 39	0.02	79.96
MW-SF-9	06/15/95	GMX	40	4	---	---	74.10
MW-SF-10	09/23/03	GMX	30.5	4	10.3 - 29.9	0.02	76.53
MW-SF-11	--	GMX	--	4	--	--	78.56
MW-SF-12	--	GMX	--	4	--	--	78.07
MW-SF-13	--	GMX	--	4	--	--	73.40
MW-SF-14	--	GMX	--	4	--	--	78.16
MW-SF-15	--	GMX	--	4	--	--	78.27
MW-SF-16	--	GMX	--	4	--	--	78.21
PO-7	05/01/89	GW <sup>10</sup>	56	4	29 - 49	0.02	80.26
PW-1	01/06/92	GTI	51.5	4	20 - 50	0.01	75.52
PW-2	01/06/92	GTI	50	4	20 - 50	0.01	74.71
PW-3	01/06/92	GTI	50	4	20 - 50	0.01	73.71
PZ-1	07/12/91	GTI	50	2	25 - 50	0.01	73.74
PZ-2	07/12/91	GTI	50	2	25 - 50	0.01	73.96
PZ-3	06/03/93	GTI	65	2	25 - 65	0.02	76.17
PZ-4	06/02/93	GTI	60	2	25 - 60	0.02	76.13
PZ-5	09/26/00	GMX	40.3	4	20.6 - 39.4	0.01	73.97
PZ-6	09/26/00	GMX	37.5	4	22.8 - 37.8	0.01	73.91
PZ-7A	04/07/03	GMX	32	2	21.5 - 31.2	0.01	73.87
PZ-7B	04/07/03	GMX	47.5	2	42 - 46.7	0.01	73.79
PZ-8A	04/08/03	GMX	31.5	2	21.2 - 31	0.01	75.81
PZ-8B	04/08/03	GMX	47	2	41.4 - 46.2	0.01	75.69
PZ-9A	04/09/03	GMX	32	2	21.6 - 30.9	0.01	76.14
PZ-9B	04/09/03	GMX	47	2	41.5 - 46.2	0.01	76.26
PZ-10	04/10/03	GMX	38.5	2	23.2 - 37.9	0.02	74.34
TF-8	09/22/95	GTI	63	1.5	25 - 60	0.02	75.60
TF-8	09/22/95	GTI	63	4	25 - 60	0.02	74.86
TF-9	09/22/95	GTI	63	1.5	25 - 60	0.02	75.27
TF-9	09/22/95	GTI	63	4	25 - 60	0.02	74.47

**TABLE 1**  
**MONITORING WELL SUMMARY**  
Defense Fuel Support Point, Norwalk  
Norwalk, California

Well	Installation Date	Installed By	Total Depth (ft bgs) <sup>1</sup>	Casing Diameter (inches)	Screen Interval (ft bgs)	Slot Size (inches)	Casing Elevation (ft msl) <sup>2</sup>
TF-10	09/25/95	GTI	63	1.5	25 - 60	0.02	74.19
TF-10	09/25/95	GTI	63	4	25 - 60	0.02	73.61
TF-11	09/25/95	GTI	63	1.5	25 - 60	0.02	74.95
TF-11	09/25/95	GTI	63	4	25 - 60	0.02	74.40
TF-13	09/26/95	GTI	63	1.5	25 - 60	0.02	75.90
TF-13	09/26/95	GTI	63	4	25 - 60	0.02	75.47
TF-14	09/27/95	GTI	63	1.5	25 - 60	0.02	74.78
TF-14	09/27/95	GTI	63	4	25 - 60	0.02	74.35
TF-15	09/28/95	GTI	63	1.5	25 - 60	0.02	75.40
TF-15	09/28/95	GTI	63	4	25 - 60	0.02	74.78
TF-16	09/28/95	GTI	63	1.5	25 - 60	0.02	76.48
TF-16	09/28/95	GTI	63	4	25 - 60	0.02	75.89
TF-17	09/29/95	GTI	63	1.5	25 - 60	0.02	75.26
TF-17	09/29/95	GTI	63	4	25 - 60	0.02	74.88
TF-18	07/06/94	GTI	50.5	4	20 - 50	0.02	73.94
TF-19	10/03/95	GTI	63	1.5	25 - 60	0.02	75.61
TF-19	10/03/95	GTI	63	4	25 - 60	0.02	75.07
TF-20	10/03/95	GTI	63	1.5	25 - 60	0.02	75.59
TF-20	10/03/95	GTI	63	4	25 - 60	0.02	75.08
TF-21	09/29/95	GTI	63	1.5	25 - 60	0.02	75.60
TF-21	09/29/95	GTI	63	4	25 - 60	0.02	74.96
TF-22	10/02/95	GTI	63	1.5	25 - 60	0.02	74.95
TF-22	10/02/95	GTI	63	4	25 - 60	0.02	74.76
TF-23	07/05/94	GTI	50.5	4	20 - 50	0.02	75.31
TF-24 <sup>11</sup>	09/26/95	GTI	63	1.5	25 - 60	0.02	76.35
TF-24 <sup>11</sup>	09/26/95	GTI	63	4	25 - 60	0.02	76.43
TF-25	04/04/01	GTI	47	1.5	41 - 46	0.02	---
TF-25	04/04/01	GTI	47	4	26 - 36	0.02	74.85
TF-26	04/03/01	GTI	47	1.5	41 - 46	0.02	---
TF-26	04/03/01	GTI	47	4	26 - 36	0.02	75.85
WCW-1	02/18/92	WC	52	4	20 - 50	0.01	72.86
WCW-2	02/21/92	WC	52	4	20 - 50	0.01	75.34
WCW-3	02/19/92	WC	56.5	4	19 - 49	0.01	76.16
WCW-4	02/20/92	WC	56.5	4	20 - 50	0.01	78.05
WCW-5	04/30/92	WC	52	4	19 - 49	0.01	73.49
WCW-6	04/20/92	WC	53.5	4	20 - 50	0.01	75.52
WCW-7	04/29/92	WC	53	4	20 - 50	0.01	76.44
WCW-8	04/21/92	WC	53.5	4	20 - 50	0.01	77.34
WCW-9	04/28/92	WC	53.5	4	20 - 50	0.01	77.74
WCW-10	09/11/92	WC	56.5	4	25 - 55	0.01	74.06

**TABLE 1**

**MONITORING WELL SUMMARY**  
Defense Fuel Support Point, Norwalk  
Norwalk, California

Well	Installation Date	Installed By	Total Depth (ft bgs) <sup>1</sup>	Casing Diameter (inches)	Screen Interval (ft bgs)	Slot Size (inches)	Casing Elevation (ft msl) <sup>2</sup>
WCW-11	09/09/92	WC	61.5	4	30 - 60	0.01	75.29
WCW-12	09/08/92	WC	61.5	4	30 - 60	0.01	76.27
WCW-13	09/10/92	WC	61.5	4	30 - 60	0.01	77.70
WCW-14	08/12/98	FDGTI	59	4	24 - 59	0.01	78.81

Notes

1. ft bgs = feet below ground surface.
2. ft msl = feet above mean sea level.
3. GMX = Geomatrix Consultants.
4. WC = Woodward-Clyde.
5. GTI = Groundwater Technology/Groundwater Technology Government Services.
6. GMW-21 is also referred to as TF-24.
7. FDGTI - Fluor Daniel GTI.
8. --- = information not available.
9. HLA = Harding Lawson Associates.
10. GW = Golden West
11. TF-24 is also referred to as "old TF-24" or "former TF-24". See also Note 6.
12. Biosparge and additional soil vapor extraction wells used for remediation purposes only are not listed here.



TABLE 2

**SUMMARY OF GROUNDWATER ELEVATIONS  
JULY 2009 SENTRY EVENT**  
Defense Fuel Support Point, Norwalk  
Norwalk, California

Well	Date	Top of Casing Elevation <sup>1</sup>	Depth to Product (feet) <sup>2</sup>	Depth to Water (feet) <sup>2</sup>	Apparent Product Thickness (feet)	Groundwater Elevation <sup>1</sup>	Gauged by
EXP-1	07/16/09	78.44	---	55.06	---	23.38	Parsons
EXP-1	07/20/09	78.44	---	54.83	---	23.61	Blaine Tech
EXP-2	07/16/09	79.43	---	54.91	---	24.52	Parsons
EXP-2	07/20/09	79.43	---	54.91	---	24.52	Blaine Tech
EXP-3	07/16/09	77.58	---	54.02	---	23.56	Parsons
EXP-3	07/20/09	77.58	---	53.93	---	23.65	Blaine Tech
EXP-4	07/20/09	79.81	---	54.51	---	25.30	Blaine Tech
EXP-5	07/21/09	72.41	---	49.10	---	23.31	Blaine Tech
GMW-5	07/16/09	77.61	---	29.93	---	47.68	Parsons
GMW-6	07/16/09	77.31	---	29.51	---	47.80	Parsons
GMW-7	07/17/09	75.84	---	27.65	---	48.19	Parsons
GMW-15	07/16/09	76.21	---	28.32	---	47.89	Parsons
GMW-16	07/16/09	77.00	---	29.52	---	47.48	Parsons
GMW-17	07/16/09	74.66	---	27.15	---	47.51	Parsons
GMW-18	07/17/09	75.36	---	27.41	---	47.95	Parsons
GMW-19	07/17/09	76.83	---	28.79	---	48.04	Parsons
GMW-21	07/17/09	76.23	---	28.40	---	47.83	Parsons
GMW-32	07/16/09	74.62	---	26.71	---	47.91	Parsons
GMW-33	07/16/09	74.88	---	27.41	---	47.47	Parsons
GMW-35	07/17/09	76.12	---	28.12	---	48.00	Parsons
GMW-36	07/22/09	74.53	---	25.90	---	48.63	Blaine Tech
GMW-38	07/21/09	75.47	---	27.21	---	48.26	Blaine Tech
GMW-39	07/21/09	75.05	---	26.85	---	48.20	Blaine Tech
GMW-45	07/16/09	74.45	---	27.91	---	46.54	Parsons
GMW-47	07/16/09	75.98	---	28.22	---	47.76	Parsons
GMW-50	07/16/09	75.51	---	27.87	---	47.64	Parsons
GMW-51	07/16/09	75.93	---	28.15	---	47.78	Parsons
GMW-52	07/16/09	75.03	---	27.25	---	47.78	Parsons
GMW-53	07/16/09	74.90	---	27.04	---	47.86	Parsons
GMW-56	07/16/09	76.52	---	29.03	---	47.49	Parsons
GMW-57	07/16/09	76.66	---	28.87	---	47.79	Parsons
GMW-58	07/16/09	75.48	---	26.92	---	48.56	Parsons
GMW-59	07/16/09	75.28	---	26.20	---	49.08	Parsons
GMW-60	07/16/09	76.24	---	28.37	---	47.87	Parsons
GMW-61	07/16/09	75.60	---	27.69	---	47.91	Parsons
GMW-62	07/17/09	76.34	---	28.15	---	48.19	Parsons
GMW-63	07/17/09	77.32	---	29.11	---	48.21	Parsons
GMW-64	07/17/09	75.84	---	27.37	---	48.47	Parsons
GMW-65	07/17/09	76.78	---	28.65	---	48.13	Parsons
GMW-O-1	07/20/09	71.45	---	23.15	---	48.30	Blaine Tech
GMW-O-2	07/21/09	72.54	---	24.40	---	48.14	Blaine Tech
GMW-O-3	07/21/09	72.19	---	24.21	---	47.98	Blaine Tech
GMW-O-14	07/22/09	74.08	---	26.31	---	47.77	Blaine Tech
GMW-O-15	07/22/09	74.23	24.94	24.99	0.05	---	Blaine Tech
GW-8	07/16/09	76.15	---	28.48	---	47.67	Parsons
GW-15	07/17/09	75.36	28.51	28.59	0.08	46.84	Parsons
GW-16	07/17/09	76.33	---	28.87	---	47.46	Parsons
MW-10	07/16/09	79.12	---	31.42	---	47.70	Parsons
MW-13	07/16/09	78.25	---	30.51	---	47.74	Parsons
MW-14	07/16/09	78.60	---	31.21	---	47.39	Parsons
MW-16	07/16/09	76.87	---	29.12	---	47.75	Parsons
MW-17	07/16/09	77.86	---	32.25	---	45.61	Parsons
MW-22 MID	07/16/09	79.57	---	33.51	---	46.06	Parsons
MW-23 MID	07/16/09	79.59	---	31.79	---	47.80	Parsons
MW-29	07/16/09	79.13	---	31.15	---	47.98	Parsons

TABLE 2

**SUMMARY OF GROUNDWATER ELEVATIONS  
JULY 2009 SENTRY EVENT  
Defense Fuel Support Point, Norwalk  
Norwalk, California**

Well	Date	Top of Casing Elevation <sup>1</sup>	Depth to Product (feet) <sup>2</sup>	Depth to Water (feet) <sup>2</sup>	Apparent Product Thickness (feet)	Groundwater Elevation <sup>1</sup>	Gauged by
MW-SF-1	07/22/09	78.93	---	30.98	---	47.95	Blaine Tech
MW-SF-4	07/22/09	79.38	31.61	31.65	0.04	---	Blaine Tech
PZ-3	07/16/09	76.17	---	28.97	---	47.20	Parsons
PZ-4	07/16/09	76.13	---	29.05	---	47.08	Parsons
PZ-5	07/22/09	73.97	---	25.20	---	48.77	Blaine Tech
PZ-10	07/21/09	74.34	---	26.60	---	47.74	Blaine Tech
TF-8	07/16/09	75.60	---	28.42	---	47.18	Parsons
TF-9	07/16/09	75.27	---	28.28	---	46.99	Parsons
TF-10	07/16/09	74.19	---	27.02	---	47.17	Parsons
TF-11	07/16/09	74.95	---	27.70	---	47.25	Parsons
TF-13	07/17/09	75.90	---	27.81	---	48.09	Parsons
TF-14	07/17/09	74.78	---	26.91	---	47.87	Parsons
TF-15	07/17/09	75.40	---	26.82	---	48.58	Parsons
TF-16	07/17/09	76.48	---	28.35	---	48.13	Parsons
TF-17	07/17/09	75.26	26.90	27.64	0.74	48.24	Parsons
TF-18	07/16/09	73.94	---	26.42	---	47.52	Parsons
TF-19	07/16/09	75.61	---	27.69	---	47.92	Parsons
TF-20	07/17/09	75.08	---	28.02	---	75.08	Parsons
TF-21	07/17/09	75.60	---	27.31	---	48.29	Parsons
TF-22	07/17/09	74.95	---	27.61	---	47.34	Parsons
TF-23	07/17/09	75.31	---	26.93	---	48.38	Parsons
TF-24	07/16/09	76.43	---	29.11	---	47.32	Parsons
TF-25	07/16/09	74.85	---	28.88	---	45.97	Parsons
TF-26	07/17/09	75.85	---	28.87	---	46.98	Parsons
WCW-3	07/20/09	76.16	---	28.48	---	47.68	Blaine Tech
WCW-7	07/21/09	76.44	---	28.94	---	47.50	Blaine Tech
WCW-13	07/20/09	77.70	---	30.20	---	47.50	Blaine Tech

Notes

1. Feet above mean sea level, based on Los Angeles County Datum, 1980.
2. Below top of casing.
3. --- = product not detected or not applicable.

TABLE 3

**SUMMARY OF GROUNDWATER ELEVATIONS  
OCTOBER 2009 SEMIANNUAL EVENT  
Defense Fuel Support Point, Norwalk  
Norwalk, California**

Well	Date	Top of Casing Elevation <sup>1</sup>	Depth to Product (feet) <sup>2</sup>	Depth to Water (feet) <sup>2</sup>	Apparent Product Thickness (feet)	Groundwater Elevation <sup>1</sup>	Gauged by
EXP-1	10/15/09	78.44	---	55.62	---	22.82	Parsons
EXP-1	10/19/09	78.44	---	55.86	---	22.58	Blaine Tech
EXP-2	10/16/09	79.43	---	55.65	---	23.78	Parsons
EXP-2	10/19/09	79.43	---	55.90	---	23.53	Blaine Tech
EXP-3	10/15/09	77.58	---	54.77	---	22.81	Parsons
EXP-3	10/19/09	77.58	---	55.40	---	22.18	Blaine Tech
EXP-4	10/19/09	79.81	---	55.42	---	24.39	Blaine Tech
EXP-5	10/19/09	72.41	---	50.61	---	21.80	Blaine Tech
GMW-1	10/19/09	74.77	---	27.52	---	47.25	Blaine Tech
GMW-2	10/19/09	73.57	---	26.22	---	47.35	Blaine Tech
GMW-3	10/19/09	75.10	---	27.81	---	47.29	Blaine Tech
GMW-4	10/19/09	75.45	27.81	27.86	0.05	---	Blaine Tech
GMW-5	10/15/09	77.61	---	30.39	---	47.22	Parsons
GMW-6	10/15/09	77.31	---	29.90	---	47.41	Parsons
GMW-7	10/22/09	75.84	28.45	28.47	0.02	47.39	Parsons
GMW-8	10/19/09	73.20	---	25.69	---	47.51	Blaine Tech
GMW-9	10/19/09	74.44	---	---	---	---	Blaine Tech
GMW-10	10/19/09	74.67	---	27.20	---	47.47	Blaine Tech
GMW-11	10/19/09	72.90	---	25.69	---	47.21	Blaine Tech
GMW-11	10/21/09	72.90	---	25.65	---	47.25	Parsons
GMW-12	10/21/09	75.21	---	27.52	---	47.69	Parsons
GMW-13	10/19/09	74.17	---	26.45	---	47.72	Blaine Tech
GMW-14	10/19/09	74.72	---	27.31	---	47.41	Blaine Tech
GMW-15	10/15/09	76.21	---	28.80	---	47.41	Parsons
GMW-16	10/16/09	77.00	---	29.64	---	47.36	Parsons
GMW-17	10/20/09	74.66	---	27.29	---	47.37	Parsons
GMW-18	10/22/09	75.36	---	27.71	---	47.65	Parsons
GMW-19	10/22/09	76.83	---	29.41	---	47.42	Parsons
GMW-20	10/21/09	75.10	---	27.64	---	47.46	Parsons
GMW-21	10/21/09	76.23	---	28.62	---	47.61	Parsons
GMW-22	10/19/09	74.17	---	---	---	---	Blaine Tech
GMW-23	10/19/09	74.85	---	27.51	---	47.34	Blaine Tech
GMW-24	10/19/09	74.04	---	---	---	---	Blaine Tech
GMW-25	10/19/09	74.29	---	30.28	---	44.01	Blaine Tech
GMW-26	10/19/09	74.52	---	26.96	---	47.56	Blaine Tech
GMW-27	10/19/09	74.41	---	27.39	---	47.02	Blaine Tech
GMW-28	10/19/09	74.68	---	27.21	---	47.47	Blaine Tech
GMW-29	10/19/09	77.57	---	29.70	---	47.87	Blaine Tech
GMW-30	10/19/09	74.91	---	27.40	---	47.51	Blaine Tech
GMW-31	10/20/09	76.50	---	29.23	---	47.27	Parsons
GMW-32	10/15/09	74.62	---	26.98	---	47.64	Parsons
GMW-33	10/15/09	74.88	---	27.34	---	47.54	Parsons
GMW-34	10/20/09	75.25	---	27.87	---	47.38	Parsons
GMW-35	10/21/09	76.12	28.69	28.73	0.04	47.42	Parsons
GMW-36	10/19/09	74.53	26.45	26.56	0.11	---	Blaine Tech
GMW-37	10/19/09	77.32	---	29.47	---	47.85	Blaine Tech
GMW-38	10/19/09	75.47	---	27.78	---	47.69	Blaine Tech
GMW-39	10/19/09	75.05	---	27.58	---	47.47	Blaine Tech
GMW-40	10/20/09	73.13	---	25.79	---	47.34	Parsons
GMW-41	10/20/09	74.46	---	27.11	---	47.35	Parsons
GMW-42	10/20/09	75.50	---	28.14	---	47.36	Parsons
GMW-43	10/22/09	74.44	---	27.09	---	47.35	Parsons
GMW-44	10/22/09	74.45	---	27.33	---	47.12	Parsons
GMW-45	10/15/09	75.67	---	28.38	---	47.29	Parsons
GMW-47	10/15/09	75.98	---	28.63	---	47.35	Parsons
GMW-48	10/15/09	75.03	---	26.80	---	48.23	Parsons

TABLE 3

**SUMMARY OF GROUNDWATER ELEVATIONS  
OCTOBER 2009 SEMIANNUAL EVENT  
Defense Fuel Support Point, Norwalk  
Norwalk, California**

Well	Date	Top of Casing Elevation <sup>1</sup>	Depth to Product (feet) <sup>2</sup>	Depth to Water (feet) <sup>2</sup>	Apparent Product Thickness (feet)	Groundwater Elevation <sup>1</sup>	Gauged by
GMW-50	10/15/09	75.51	---	28.10	---	47.41	Parsons
GMW-51	10/15/09	75.93	---	28.47	---	47.46	Parsons
GMW-52	10/15/09	75.03	---	27.28	---	47.75	Parsons
GMW-53	10/15/09	74.90	---	27.18	---	47.72	Parsons
GMW-54	10/20/09	75.16	---	27.67	---	47.49	Parsons
GMW-55	10/20/09	74.60	---	27.13	---	47.47	Parsons
GMW-56	10/15/09	76.52	---	29.14	---	47.38	Parsons
GMW-57	10/15/09	76.66	---	29.29	---	47.37	Parsons
GMW-58	10/15/09	75.48	---	27.35	---	48.13	Parsons
GMW-59	10/15/09	75.28	---	26.63	---	48.65	Parsons
GMW-60	10/15/09	76.24	---	28.86	---	47.38	Parsons
GMW-61	10/15/09	75.60	---	28.15	---	47.45	Parsons
GMW-62	10/15/09	76.34	---	28.78	---	47.56	Parsons
GMW-63	10/15/09	77.32	---	29.52	---	47.80	Parsons
GMW-64	10/15/09	75.84	---	28.01	---	47.83	Parsons
GMW-65	10/15/09	76.78	---	29.18	---	47.60	Parsons
GMW-66	10/15/09	77.00	---	29.53	---	47.47	Parsons
GMW-O-1	10/19/09	71.45	---	23.39	---	48.06	Blaine Tech
GMW-O-2	10/19/09	72.54	---	24.81	---	47.73	Blaine Tech
GMW-O-3	10/19/09	72.19	---	24.49	---	47.70	Blaine Tech
GMW-O-4	10/19/09	71.95	---	24.14	---	47.81	Blaine Tech
GMW-O-4 MID	10/19/09	72.24	---	32.71	---	39.53	Blaine Tech
GMW-O-5	10/19/09	72.36	---	25.21	---	47.15	Blaine Tech
GMW-O-6	10/19/09	71.41	---	22.98	---	48.43	Blaine Tech
GMW-O-7	10/19/09	70.98	---	21.91	---	49.07	Blaine Tech
GMW-O-8	10/19/09	70.91	---	22.41	---	48.50	Blaine Tech
GMW-O-9	10/19/09	73.50	---	25.86	---	47.64	Blaine Tech
GMW-O-10	10/19/09	73.98	---	26.72	---	47.26	Blaine Tech
GMW-O-11	10/19/09	74.17	---	---	---	---	Blaine Tech
GMW-O-11	11/06/09	74.17	26.18	26.33	0.15	---	Blaine Tech
GMW-O-12	10/19/09	73.49	---	25.08	---	48.41	Blaine Tech
GMW-O-14	10/19/09	74.08	---	26.24	---	47.84	Blaine Tech
GMW-O-15	10/19/09	74.23	25.43	25.55	0.12	---	Blaine Tech
GMW-O-16	10/19/09	74.10	---	25.81	---	48.29	Blaine Tech
GMW-O-18	10/19/09	74.36	---	26.31	---	48.05	Blaine Tech
GMW-O-19	10/19/09	74.46	---	26.26	---	48.20	Blaine Tech
GMW-O-20	10/19/09	73.32	---	---	---	---	Blaine Tech
GMW-O-21	10/19/09	71.43	---	---	---	---	Blaine Tech
GMW-O-23	10/19/09	73.63	---	---	---	---	Blaine Tech
GMW-SF-7	10/19/09	75.26	---	27.51	---	47.75	Blaine Tech
GMW-SF-8	10/19/09	76.75	---	29.01	---	47.74	Blaine Tech
GW-1	10/16/09	75.46	---	28.24	---	47.22	Parsons
GW-2	10/16/09	76.39	---	28.95	---	47.44	Parsons
GW-3	10/16/09	76.56	---	29.50	---	47.06	Parsons
GW-4	10/16/09	74.77	---	27.95	---	46.82	Parsons
GW-5	10/16/09	76.99	---	29.69	---	47.30	Parsons
GW-6	10/16/09	76.38	---	29.06	---	47.32	Parsons
GW-7	10/20/09	76.76	---	29.19	---	47.57	Parsons
GW-8	10/16/09	76.88	---	29.66	---	47.22	Parsons
GW-13	10/16/09	77.00	---	29.89	---	47.11	Parsons
GW-14	10/21/09	76.54	---	29.20	---	47.34	Parsons
GW-15	10/15/09	75.36	28.92	29.50	0.58	46.35	Parsons
GW-16 <sup>4</sup>	10/15/09	76.55	---	29.29	---	47.26	Parsons
GWR-1	10/19/09	77.40	---	29.98	---	47.42	Blaine Tech
GWR-3	10/19/09	74.93	---	---	---	---	Blaine Tech

TABLE 3

**SUMMARY OF GROUNDWATER ELEVATIONS  
OCTOBER 2009 SEMIANNUAL EVENT  
Defense Fuel Support Point, Norwalk  
Norwalk, California**

Well	Date	Top of Casing Elevation <sup>1</sup>	Depth to Product (feet) <sup>2</sup>	Depth to Water (feet) <sup>2</sup>	Apparent Product Thickness (feet)	Groundwater Elevation <sup>1</sup>	Gauged by
HL-2	10/19/09	76.94	---	29.03	---	47.91	Blaine Tech
HL-3	10/19/09	76.86	---	29.46	---	47.40	Blaine Tech
MW-6	10/19/09	77.20	---	29.48	---	47.72	Blaine Tech
MW-7	10/19/09	78.13	---	30.70	---	47.43	Blaine Tech
MW-8	10/19/09	76.06	---	28.71	---	47.35	Blaine Tech
MW-9	10/19/09	77.11	29.36	29.4	0.04	47.71	Blaine Tech
MW-10	10/16/09	79.12	---	31.80	---	47.32	Parsons
MW-11	10/20/09	78.17	---	30.81	---	47.36	Parsons
MW-12	10/19/09	75.76	---	28.88	---	46.88	Blaine Tech
MW-12	10/20/09	75.76	---	28.38	---	47.38	Parsons
MW-13	10/15/09	78.25	---	30.91	---	47.34	Parsons
MW-14	10/16/09	78.60	---	31.31	---	47.29	Parsons
MW-15	10/19/09	76.99	29.21	30.37	1.16	46.62	Blaine Tech
MW-16	10/15/09	76.87	---	29.17	---	47.70	Parsons
MW-17	10/15/09	77.86	---	30.40	---	47.46	Parsons
MW-18 MID	10/19/09	75.67	---	32.62	---	43.05	Blaine Tech
MW-19 MID	10/19/09	78.14	---	32.88	---	45.26	Blaine Tech
MW-20 MID	10/19/09	77.19	---	32.11	---	45.08	Blaine Tech
MW-21 MID	10/19/09	77.55	---	30.30	---	47.25	Blaine Tech
MW-22 MID	10/16/09	79.57	---	33.72	---	45.85	Parsons
MW-23 MID	10/16/09	79.59	---	32.22	---	47.37	Parsons
MW-24	10/16/09	78.51	---	31.26	---	47.25	Parsons
MW-25	10/16/09	79.15	---	31.88	---	47.27	Parsons
MW-26	10/16/09	77.40	---	30.03	---	47.37	Parsons
MW-27	10/16/09	78.46	---	30.90	---	47.56	Parsons
MW-28	10/20/09	78.53	---	31.05	---	47.48	Parsons
MW-29	10/15/09	79.13	---	31.50	---	47.63	Parsons
MW-O-1	10/19/09	75.48	---	26.30	---	49.18	Blaine Tech
MW-O-2	10/19/09	71.90	---	---	---	---	Blaine Tech
MW-SF-1	10/19/09	78.93	---	31.11	---	47.82	Blaine Tech
MW-SF-2	10/19/09	78.53	---	---	---	---	Blaine Tech
MW-SF-3	10/19/09	78.12	---	---	---	---	Blaine Tech
MW-SF-4	10/19/09	79.38	31.9	31.93	0.03	---	Blaine Tech
MW-SF-5	10/19/09	79.74	---	---	---	---	Blaine Tech
MW-SF-6	10/19/09	76.80	---	---	---	---	Blaine Tech
MW-SF-9	10/19/09	74.10	---	26.45	---	47.65	Blaine Tech
MW-SF-10	10/19/09	76.53	---	28.61	---	47.92	Blaine Tech
MW-SF-11	10/19/09	78.56	---	---	---	---	Blaine Tech
MW-SF-12	10/19/09	78.07	---	---	---	---	Blaine Tech
MW-SF-13	10/19/09	73.40	---	---	---	---	Blaine Tech
MW-SF-14	10/19/09	78.16	---	---	---	---	Blaine Tech
MW-SF-15	10/19/09	78.27	---	---	---	---	Blaine Tech
MW-SF-16	10/19/09	78.21	---	---	---	---	Blaine Tech
PW-1	10/19/09	75.52	---	27.74	---	47.78	Blaine Tech
PW-2	10/19/09	74.71	---	---	---	---	Blaine Tech
PW-3	10/19/09	73.71	---	26.03	---	47.68	Blaine Tech
PZ-2	10/19/09	73.96	---	---	---	---	Blaine Tech
PZ-3	10/20/09	76.17	---	28.67	---	47.50	Parsons
PZ-4	10/20/09	76.13	---	28.80	---	47.33	Parsons
PZ-5	10/19/09	73.97	---	26.41	---	47.56	Blaine Tech
PZ-10	10/19/09	74.34	---	26.96	---	47.38	Blaine Tech
TF-8	10/20/09	75.60	---	28.51	---	47.09	Parsons
TF-9	10/20/09	75.27	---	27.95	---	47.32	Parsons
TF-10	10/20/09	74.19	---	26.89	---	47.30	Parsons
TF-11	10/20/09	74.95	---	27.53	---	47.42	Parsons
TF-13	10/22/09	75.90	---	28.51	---	47.39	Parsons

TABLE 3

**SUMMARY OF GROUNDWATER ELEVATIONS  
OCTOBER 2009 SEMIANNUAL EVENT  
Defense Fuel Support Point, Norwalk  
Norwalk, California**

Well	Date	Top of Casing Elevation <sup>1</sup>	Depth to Product (feet) <sup>2</sup>	Depth to Water (feet) <sup>2</sup>	Apparent Product Thickness (feet)	Groundwater Elevation <sup>1</sup>	Gauged by
TF-14	10/22/09	74.78	---	27.35	---	47.43	Parsons
TF-15	10/22/09	75.40	---	27.99	---	47.41	Parsons
TF-16	10/22/09	76.48	---	29.11	---	47.37	Parsons
TF-17	10/21/09	74.88	27.1	27.70	0.60	47.68	Parsons
TF-18	10/15/09	73.94	---	26.22	---	47.72	Parsons
TF-19	10/15/09	75.07	---	28.00	---	47.07	Parsons
TF-20	10/21/09	75.08	---	28.30	---	46.78	Parsons
TF-21	10/21/09	75.60	---	27.68	---	47.92	Parsons
TF-22	10/21/09	74.76	---	27.46	---	47.30	Parsons
TF-23	10/21/09	75.31	27.56	27.57	0.01	47.75	Parsons
TF-24	10/16/09	76.35	---	29.32	---	47.03	Parsons
TF-25	10/20/09	74.85	---	28.24	---	46.61	Parsons
TF-26	10/16/09	75.85	---	29.08	---	46.77	Parsons
VE-01	10/15/09	---	---	30.13	---	---	Parsons
VE-02	10/15/09	---	---	29.84	---	---	Parsons
VS-03 (Deep)	10/20/09	---	---	27.55	---	---	Parsons
VS-03 (Shallow)	10/20/09	---	---	27.20	---	---	Parsons
WCW-1	10/22/09	72.86	---	24.87	---	47.99	Parsons
WCW-2	10/22/09	75.34	---	27.59	---	47.75	Parsons
WCW-3	10/22/09	76.16	---	28.70	---	47.46	Parsons
WCW-4	10/22/09	78.05	---	30.66	---	47.39	Parsons
WCW-5	10/22/09	73.49	---	25.45	---	48.04	Parsons
WCW-6	10/22/09	75.52	---	27.84	---	47.68	Parsons
WCW-7	10/19/09	76.44	---	29.29	---	47.15	Parsons
WCW-8	10/19/09	77.34	---	30.10	---	47.24	Parsons
WCW-9	10/22/09	77.74	---	30.44	---	47.30	Parsons
WCW-10	10/22/09	74.06	---	25.41	---	48.65	Parsons
WCW-11	10/22/09	75.29	---	27.14	---	48.15	Parsons
WCW-12	10/22/09	76.27	---	28.52	---	47.75	Parsons
WCW-13	10/22/09	77.70	---	30.23	---	47.47	Parsons
WCW-14	10/22/09	78.81	---	31.27	---	47.54	Parsons

Notes

1. Feet above mean sea level, based on Los Angeles County Datum, 1980.
2. Below top of casing.
3. --- = product not detected or not applicable.
4. GW-16p is the piezometer well.

TABLE 4

**SUMMARY OF GROUNDWATER ANALYTICAL DATA  
THIRD QUARTER 2009 SENTRY EVENT**

Defense Fuel Support Point, Norwalk  
Norwalk, California

Results reported in micrograms per liter (µg/L)

Well	Sample Date	TPHjp <sup>5</sup>	TPHg <sup>2</sup>	TPHfp <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Xylenes <sup>4</sup>	1,2-DCA <sup>5</sup>	MTBE <sup>6</sup>	TBA <sup>7</sup>
EXP-1	07/20/09	--- <sup>8</sup>	< 50	120	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
EXP-2	07/20/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
EXP-3	07/20/09	< 100 <sup>9</sup>	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
EXP-3	07/20/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
EXP-4	07/20/09	---	< 50	120	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
EXP-5	07/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-36	07/22/09	---	24000	15000	3800	5400	720	3380	< 50	28	< 500
GMW-38	07/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.55	27
GMW-39	07/21/09	---	< 100	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	< 0.5	2500
GMW-39 DUP <sup>10</sup>	07/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	4400
GMW-47	07/20/09	1400	200	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	15
GMW-57	07/21/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GMW-58	07/20/09	300	100	---	1.2	< 0.50	< 0.50	< 1	< 0.50	6.4	< 10
GMW-58 DUP	07/20/09	290	---	---	1.2	< 0.50	< 0.50	< 1	< 0.50	6.1	< 10
GMW-59	07/20/09	11000	6700 J <sup>11</sup>	---	520	< 2.5	< 2.5	< 5	< 2.5	3.5	< 50
GMW-59 DUP	07/20/09	9100	---	---	520	< 2.5	< 2.5	< 5	< 2.5	3.4	< 50
GMW-60	07/20/09	1700	3200 J	---	940	< 5.0	11	< 10	< 5.0	< 5.0	< 100
GMW-61	07/20/09	560	760 J	---	350	< 2.5	< 2.5	< 5	< 2.5	< 2.5	< 50
GMW-62	07/21/09	1100	1800	---	1200	< 2.5	67	36	< 2.5	< 2.5	< 50
GMW-63	07/21/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GMW-64	07/21/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GMW-65	07/21/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GMW-O-1	07/20/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-O-2	07/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-O-3	07/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-O-14	07/22/09	---	32000	12000	7800	1900	1500	4100	86	< 25	< 500
GMW-O-14 DUP	07/22/09	---	31000	15000	7800	1900	1400	3900	93	< 25	< 500
GW-16	08/03/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
MW-14	07/20/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	13	1.5	< 10
MW-22 MID	07/20/09	150	---	---	< 0.50	< 0.50	< 0.50	< 1	11	19	34
MW-SF-1	07/22/09	---	12000	34000	6300	110	180	89	< 50	510	540
PZ-5	07/22/09	---	3800	1800	2000	20	98	77	< 5	800	54000
PZ-5 DUP	07/22/09	---	3500	1900	1900	19	92	72	< 5	780	52000
PZ-10	07/21/09	---	< 200	1700	1.4	< 1	< 1	< 2	< 2	9.6	55
WCW-3	07/20/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	1.7	< 0.5	< 10
WCW-7	07/21/09	---	< 50	120	< 0.5	< 0.5	< 0.5	< 1	31	1.9	< 10
WCW-13	07/20/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10

## Notes:

<sup>1</sup>TPHjp5 = total petroleum hydrocarbons quantified using a jet propellant 5 standard.<sup>2</sup>TPHg = total petroleum hydrocarbons quantified using a gasoline standard.<sup>3</sup>TPHfp = total petroleum hydrocarbons quantified using a site fuel product standard.<sup>4</sup>Xylenes = total of m,p-xylene and o-xylene when detected.<sup>5</sup>1,2-DCA = 1,2-dichloroethane.<sup>6</sup>MTBE = methyl tertiary-butyl ether.<sup>7</sup>TBA = tert-butyl alcohol.<sup>8</sup>--- = compound not analyzed.<sup>9</sup><100 = compound not detected at or above the indicated reporting limit.<sup>10</sup>DUP = duplicate.

**TABLE 5**

**SUMMARY OF MISCELLANEOUS COMPOUNDS IN GROUNDWATER  
JULY 2009 SENTRY EVENT**

Defense Fuel Support Point, Norwalk  
Norwalk, California

Results reported in micrograms per liter (µg/L)

Well	Sample Date	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	Bromodichloromethane	Diisopropyl Ether (DIPE)	Isopropylbenzene	Naphthalene	n-Propylbenzene	sec-Butylbenzene
EXP-1	07/20/09	< 1 <sup>1</sup>	< 1	< 1	< 1	< 1	< 10	< 1	< 1
EXP-4	07/20/09	< 1	< 1	<b>1.2</b>	< 1	< 1	< 10	< 1	< 1
GMW-36	07/22/09	<b>450</b>	<b>110</b>	< 50	< 50	< 50	< 200	< 50	< 50
GMW-47	07/20/09	< 1.0	< 1.0	< 1.0	< 2.0	<b>8.2</b>	< 10	< 1.0	<b>1</b>
GMW-58	07/20/09	< 1.0	< 1.0	< 1.0	< 2.0	<b>1.1</b>	< 10	< 1.0	< 1.0
GMW-58 DUP <sup>2</sup>	07/20/09	< 1.0	< 1.0	< 1.0	< 2.0	<b>1.2</b>	< 10	< 1.0	< 1.0
GMW-59	07/20/09	< 5.0	< 5.0	< 5.0	< 10	<b>28</b>	< 50	<b>15</b>	< 5.0
GMW-59 DUP	07/20/09	< 5.0	< 5.0	< 5.0	< 10	<b>27</b>	< 50	<b>15</b>	< 5.0
GMW-60	07/20/09	< 10	< 10	< 10	< 20	<b>68</b>	<b>100</b>	<b>73</b>	< 10
GMW-61	07/20/09	< 5.0	< 5.0	< 5.0	< 10	<b>24</b>	< 50	<b>20</b>	< 5.0
GMW-62	07/21/09	<b>23</b>	< 5.0	< 5.0	< 10	<b>15</b>	< 50	<b>9.6</b>	< 5.0
GMW-O-14	07/22/09	<b>1000</b>	<b>120</b>	< 50	<b>130</b>	< 50	<b>330</b>	<b>80</b>	< 50
GMW-O-14 DUP	07/22/09	<b>990</b>	<b>110</b>	< 50	<b>140</b>	< 50	<b>350</b>	<b>78</b>	< 50
MW-14	07/20/09	< 1.0	< 1.0	< 1.0	<b>2.4</b>	< 1.0	< 10	< 1.0	< 1.0
MW-22 MID	07/20/09	< 1.0	< 1.0	< 1.0	<b>2.9</b>	< 1.0	< 10	< 1.0	< 1.0
MW-SF-1	07/22/09	< 50	< 50	< 50	< 50	< 50	< 200	< 50	< 50
PZ-5	07/22/09	<b>34</b>	<b>6.4</b>	< 5	< 5	< 5	<b>39</b>	<b>6.5</b>	< 5
PZ-5 DUP	07/22/09	<b>32</b>	<b>6.3</b>	< 5	< 5	< 5	<b>38</b>	<b>6.5</b>	< 5
PZ-10	07/21/09	< 2	< 2	< 2	<b>3.1</b>	<b>7.6</b>	< 10	<b>6</b>	< 2
WCW-7	07/21/09	< 1	< 1	< 1	<b>5.6</b>	< 1	< 10	< 1	< 1

Notes:

1. < 1 = compound not detected at or above the indicated reporting limit.
2. DUP = duplicate.



TABLE 6

**SUMMARY OF GROUNDWATER ANALYTICAL DATA  
SECOND SEMI-ANNUAL 2009 EVENT**

Defense Fuel Support Point, Norwalk  
Norwalk, California

Results reported in micrograms per liter (µg/L)

Well	Sample Date	TPH <sub>jp</sub> <sup>5</sup>	TPHg <sup>2</sup>	TPH <sub>fp</sub> <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Xylenes <sup>4</sup>	1,2-DCA <sup>5</sup>	MTBE <sup>6</sup>	TBA <sup>7</sup>
EXP-1	10/19/09	< 100 <sup>8</sup>	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
EXP-1	10/19/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
EXP-2	10/19/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	<b>6.1</b>
EXP-2	10/19/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
EXP-3	10/19/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
EXP-3	10/19/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
EXP-4	10/19/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
EXP-5	10/19/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-1	10/22/09	---	<b>330</b>	<b>1900</b>	<b>1.5</b>	< 1	< 1	< 2	< 2	< 1	< 20
GMW-1 DUP <sup>10</sup>	10/22/09	---	<b>340</b>	<b>2000</b>	<b>2.1</b>	< 1	< 1	< 2	< 2	< 1	< 20
GMW-3	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-6	10/20/09	<b>110 J<sup>11</sup></b>	---	---	<b>1.5</b>	< 0.5	< 0.5	< 1	< 0.5	<b>350</b>	< 10
GMW-8	10/19/09	---	< 50	<b>120</b>	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>1.5</b>	< 10
GMW-12	10/20/09	<b>480 J</b>	< 100	---	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>0.49</b>	< 10
GMW-13	10/19/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-14	10/22/09	---	<b>130</b>	<b>740</b>	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	<b>10</b>
GMW-15	10/20/09	<b>4900 J</b>	---	---	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>3.1</b>	<b>4.5</b>
GMW-16	10/20/09	< 100	---	---	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-17	10/20/09	<b>2400</b>	---	---	<b>0.42 J</b>	< 0.5	< 0.5	< 1	< 0.5	< 0.5	<b>9.5</b>
GMW-17 DUP	10/20/09	<b>2100</b>	---	---	<b>0.46 J</b>	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-18	10/20/09	<b>2700</b>	---	---	<b>15</b>	< 0.5	<b>0.55</b>	<b>5.55</b>	< 0.5	<b>7</b>	<b>13</b>
GMW-19	10/20/09	< 100	---	---	<b>3.8</b>	< 0.5	< 0.5	< 1	< 0.5	<b>1.5</b>	< 10
GMW-27	10/22/09	---	<b>130</b>	<b>140</b>	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>5.7</b>	<b>830</b>
GMW-31	10/20/09	<b>140</b>	---	---	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>0.57</b>	< 10
GMW-32	10/20/09	<b>250 J</b>	---	---	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-37	10/19/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-38	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	<b>29</b>
GMW-39	10/22/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>0.5</b>	<b>2200</b>
GMW-39 DUP	10/22/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	<b>2000</b>
GMW-40	10/21/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	<b>0.4</b>	< 10
GMW-41	10/21/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	<b>0.43</b>	< 10
GMW-43	10/21/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GMW-44	10/21/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GMW-45	10/21/09	<b>1600</b>	---	---	<b>15</b>	< 0.50	<b>2.2</b>	< 1	< 0.50	< 0.50	<b>11</b>
GMW-47	10/19/09	<b>1200</b>	<b>170</b>	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	<b>15</b>
GMW-56	10/21/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	<b>4.2</b>
GMW-57	10/19/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	<b>8.1</b>
GMW-58	10/19/09	<b>2200 J</b>	<b>1000</b>	---	<b>9.5</b>	< 0.50	<b>0.24</b>	< 1	< 0.50	<b>1.5</b>	<b>6</b>
GMW-58 DUP	10/19/09	<b>16000 J</b>	<b>1100</b>	---	<b>11</b>	< 0.50	<b>0.3</b>	< 1	< 0.50	<b>1.5</b>	< 10
GMW-59	10/21/09	<b>3000 J</b>	<b>2600 J</b>	---	<b>1700</b>	< 2.5	<b>1.4</b>	< 5	< 2.5	<b>16</b>	<b>18</b>
GMW-59 DUP	10/21/09	<b>4200 J</b>	<b>3400 J</b>	---	<b>1600</b>	< 2.5	<b>1.3</b>	< 5	< 2.5	<b>16</b>	<b>19</b>
GMW-60	10/19/09	<b>930</b>	<b>2600 J</b>	---	<b>800</b>	< 5.0	<b>8.8</b>	< 10	< 5.0	< 5.0	< 100
GMW-61	10/19/09	<b>410</b>	<b>620 J</b>	---	<b>320</b>	< 2.5	<b>1.2</b>	< 5	< 2.5	< 2.5	< 50
GMW-62	10/21/09	<b>480</b>	<b>2200 J</b>	---	<b>1700</b>	< 2.5	<b>43</b>	<b>12.9</b>	< 2.5	< 2.5	< 50
GMW-63	10/22/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GMW-63 DUP	10/22/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GMW-64	10/21/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GMW-65	10/22/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GMW-66	10/22/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GMW-O-1	10/20/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-O-2	10/20/09	---	< 50	<b>130</b>	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-O-3	10/20/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-O-4	10/20/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10

TABLE 6

SUMMARY OF GROUNDWATER ANALYTICAL DATA  
SECOND SEMIANNUAL 2009 EVENT

Defense Fuel Support Point, Norwalk  
Norwalk, California

Results reported in micrograms per liter (µg/L)

Well	Sample Date	TPH <sub>jp</sub> <sup>5</sup>	TPHg <sup>2</sup>	TPH <sub>fp</sub> <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Xylenes <sup>4</sup>	1,2-DCA <sup>5</sup>	MTBE <sup>6</sup>	TBA <sup>7</sup>
GMW-O-4 MID	10/20/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-O-5	10/20/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-O-8	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-O-9	10/20/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-O-10	10/22/09	---	99	< 100	6.9	< 0.5	< 0.5	< 1	< 0.5	0.77	< 10
GMW-O-14	10/23/09	---	40000	21000	14000	1900	1500	3500	< 200	< 100	< 2000
GMW-O-14 DUP	10/23/09	---	39000	12000	14000	1800	1400	3500	< 200	< 100	< 2000
GMW-O-16	10/21/09	---	< 50	250	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-O-18	10/21/09	---	2400	680	170	440	17	410	< 5	490	480
GMW-O-19	10/20/09	---	< 50	< 200	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-SF-7	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GMW-SF-8	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
GW-3	10/22/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GW-6	10/22/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	1.8	< 10
GW-13	10/23/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	23	9.5	< 10
GW-14	10/22/09	900	110	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
GW-16	10/23/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
HL-2	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
MW-6	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	1.5	1	< 10
MW-7	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	2.8	0.56	< 10
MW-8	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.69	570
MW-8 DUP	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.68	590
MW-11	10/22/09	670	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	3.9	< 10
MW-12	10/21/09	---	< 50	150	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
MW-13	10/22/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
MW-14	10/22/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	16	2.5	< 10
MW-16	10/23/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
MW-17	10/23/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
MW-19 MID	10/21/09	---	< 50	140	< 0.5	< 0.5	< 0.5	< 1	5	0.79	130
MW-20 MID	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	16	18	32
MW-22 MID	10/23/09	130 J	---	---	< 0.50	< 0.50	< 0.50	< 1	13	16	27
MW-22 MID DUP	10/23/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	14	16	28
MW-23 MID	10/23/09	150 J	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
MW-24	10/23/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
MW-25	10/23/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	4.1	0.83	< 10
MW-26	10/23/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	2	< 10
MW-27	10/26/09	< 100	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	0.54	< 10
MW-SF-1	10/23/09	---	21000	12000	11000	110	350	63	< 100	620	< 1000
MW-SF-9	10/22/09	---	2400	5900	1300	< 10	11	< 20	< 20	13	< 200
PW-1	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
PW-1 DUP	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	< 10
PW-3	10/21/09	---	< 50	< 100	< 0.5	< 0.5	< 0.5	< 1	0.86	< 0.5	< 10
PZ-5	10/23/09	---	2900	1300	1100	18	53	69	< 10	500	50000
PZ-5 DUP	10/23/09	---	3000	1300	1100	18	55	74	< 10	530	48000
PZ-10	10/22/09	---	< 200	1200	< 1	< 1	< 1	< 2	< 2	4.4	30
TF-16	10/26/09	960	---	---	7.6	< 0.50	0.34	< 1	< 0.50	3.9	11
TF-21	10/26/09	960	---	---	50	< 0.50	0.46	< 1	< 0.50	0.74	19
WCW-2	10/26/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
WCW-3	10/26/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	4	< 0.50	< 10
WCW-4	10/26/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	0.64	< 10
WCW-5	10/26/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
WCW-6	10/26/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
WCW-7	10/26/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	40	1.8	< 10

**TABLE 6**

**SUMMARY OF GROUNDWATER ANALYTICAL DATA  
SECOND SEMIANNUAL 2009 EVENT**

Defense Fuel Support Point, Norwalk  
Norwalk, California

Results reported in micrograms per liter (µg/L)

Well	Sample Date	TPHjp5 <sup>1</sup>	TPHg <sup>2</sup>	TPHfp <sup>3</sup>	Benzene	Toluene	Ethyl-benzene	Xylenes <sup>4</sup>	1,2-DCA <sup>5</sup>	MTBE <sup>6</sup>	TBA <sup>7</sup>
WCW-8	10/26/09	200	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	1.1	< 10
WCW-12	10/27/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
WCW-13	10/27/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10
WCW-14	10/27/09	< 100	< 100	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50	< 10

Notes:

1. TPHjp5 = total petroleum hydrocarbons quantified using a jet propellant 5 standard.
2. TPHg = total petroleum hydrocarbons quantified using a gasoline standard.
3. TPHfp = total petroleum hydrocarbons quantified using a site fuel product standard.
4. Xylenes = total of m,p-xylene and o-xylene when detected.
5. 1,2-DCA = 1,2-dichloroethane.
6. MTBE = methyl tertiary-butyl ether.
7. TBA = tert-butyl alcohol.
8. <100 = not detected at or above the reporting limit shown.
9. --- = compound not analyzed.
10. J = Estimated value
11. DUP = duplicate.

TABLE 7

SUMMARY OF MISCELLANEOUS COMPOUNDS IN GROUNDWATER  
OCTOBER 2009 SEMIANNUAL EVENT

Defense Fuel Support Point, Norwalk  
Norwalk, California

Results reported in micrograms per liter (µg/L)

Well	Sample Date	1,1-Dichloroethane	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	2-Butanone	Acetone	c-1,2-Dichloroethene	Chloroform	Chloromethane	Diisopropyl Ether (DIPE)	Ethanol	Isopropylbenzene	Naphthalene	n-Butylbenzene	n-Propylbenzene	p-Isopropyltoluene	sec-Butylbenzene	Tert-Amyl-Methyl Ether (TAME)	tert-Butylbenzene	Trichloroethene
GMW-1	10/22/09	< 2 <sup>1</sup>	< 2	< 2	---	< 40	---	< 2	< 8	< 2	---	7.8	< 10	< 2	< 2	---	2.4	< 2	< 2	< 2
GMW-1 DUP <sup>3</sup>	10/22/09	< 2	< 2	< 2	---	< 40	---	< 2	< 8	< 2	---	7.9	< 10	< 2	< 2	---	2.4	< 2	< 2	< 2
GMW-6	10/20/09	1.7	< 1	< 1	< 10	< 50	< 1	< 1	< 5	< 2	< 100	< 1	< 10	< 1	< 1	< 1	< 1	0.51 J1 <sup>4</sup>	< 1	< 1
GMW-8	10/19/09	< 1	< 1	< 1	---	< 10	---	< 1	< 2	< 1	---	< 1	< 10	< 1	< 1	---	< 1	< 1	< 1	< 1
GMW-12	10/20/09	< 1	< 1	< 1	< 10	< 50	< 1	< 1	< 5	< 2	< 100	< 1	< 10	< 1	< 1	< 1	< 1	< 2	< 1	< 1
GMW-14	10/22/09	< 1	< 1	< 1	---	< 10	---	< 1	< 2	< 1	---	< 1	< 10	< 1	< 1	---	1.2	< 1	< 1	< 1
GMW-15	10/20/09	< 1	< 1	< 1	< 10	11 J1	< 1	< 1	< 5	< 2	< 100	< 1	< 10	< 1	< 1	< 1	0.26 J1	< 2	< 1	< 1
GMW-17	10/20/09	< 1	< 1	< 1	10	340	< 1	< 1	< 5	< 2	< 100	1.7	< 10	< 1	< 1	< 1	0.53 J1	< 2	< 1	< 1
GMW-17 DUP	10/20/09	< 1	< 1	< 1	8.2 J1	320	< 1	< 1	< 5	< 2	< 100	1.7	< 10	< 1	< 1	< 1	0.57 J1	< 2	< 1	< 1
GMW-18	10/20/09	< 1	0.77 J1	4.3	< 10	17 J1	< 1	< 1	< 5	< 2	< 100	2.3	< 10	1	< 1	0.41 J1	0.67 J1	< 2	0.54 J1	0.36 J1
GMW-19	10/20/09	< 1	< 1	< 1	< 10	19 J1	< 1	< 1	< 5	< 2	< 100	< 1	< 10	< 1	< 1	< 1	< 1	< 2	< 1	< 1
GMW-27	10/22/09	< 1	< 1	< 1	---	< 10	---	< 1	< 2	17	---	< 1	< 10	< 1	< 1	---	< 1	< 1	< 1	< 1
GMW-31	10/20/09	< 1	< 1	< 1	< 10	< 50	< 1	< 1	< 5	< 2	< 100	< 1	< 10	< 1	< 1	< 1	< 1	< 2	< 1	< 1
GMW-32	10/20/09	< 1	< 1	< 1	< 10	< 50	< 1	< 1	< 5	< 2	< 100	< 1	< 10	< 1	< 1	< 1	< 1	< 2	< 1	< 1
GMW-40	10/21/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	47 J1	< 1.0	< 10	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 1.0	< 1.0
GMW-41	10/21/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	46 J1	< 1.0	< 10	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 1.0	< 1.0
GMW-45	10/21/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	1.3 J1	< 2.0	< 100	84	140	1.6	80	< 1.0	11	< 2.0	1.1	< 1.0
GMW-47	10/19/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	< 100	5.7	< 10	< 1.0	< 1.0	< 1.0	0.69 J1	< 2.0	0.41 J1	< 1.0
GMW-57	10/19/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	43 J1	0.58 J1	< 10	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 1.0	< 1.0
GMW-58	10/19/09	0.81 J1	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	< 100	7.2	26	1.5	4.2	2.2	2.7	< 2.0	0.8 J1	< 1.0
GMW-58 DUP	10/19/09	0.7 J1	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	< 100	7.3	29	1.5	4.5	1.9	2.5	< 2.0	0.84 J1	< 1.0

TABLE 7

SUMMARY OF MISCELLANEOUS COMPOUNDS IN GROUNDWATER  
OCTOBER 2009 SEMIANNUAL EVENT

Defense Fuel Support Point, Norwalk  
Norwalk, California

Results reported in micrograms per liter (µg/L)

Well	Sample Date	1,1-Dichloroethane	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	2-Butanone	Acetone	c-1,2-Dichloroethene	Chloroform	Chloromethane	Diisopropyl Ether (DIPE)	Ethanol	Isopropylbenzene	Naphthalene	n-Butylbenzene	n-Propylbenzene	p-Isopropyltoluene	sec-Butylbenzene	Tert-Amyl-Methyl Ether (TAME)	tert-Butylbenzene	Trichloroethene
GMW-59	10/21/09	< 5.0	< 5.0	< 5.0	< 50	< 250	5.9	< 5.0	< 25	< 10	< 500	24	< 50	1.4 J1	10	< 5.0	3.2 J1	< 10	< 5.0	< 5.0
GMW-59 DUP	10/21/09	< 5.0	< 5.0	< 5.0	< 50	< 250	6.3	< 5.0	< 25	< 10	< 500	25	< 50	1.4 J1	11	< 5.0	3.6 J1	< 10	< 5.0	< 5.0
GMW-60	10/19/09	< 10	< 10	< 10	< 100	< 500	< 10	< 10	< 50	< 20	< 1000	52	85 J1	< 10	55	< 10	5.6 J1	< 20	< 10	< 10
GMW-61	10/19/09	< 5.0	< 5.0	< 5.0	< 50	< 250	< 5.0	< 5.0	< 25	< 10	< 500	26	< 50	< 5.0	20	< 5.0	2.9 J1	< 10	< 5.0	< 5.0
GMW-62	10/21/09	< 5.0	15	< 5.0	< 50	< 250	< 5.0	< 5.0	< 25	< 10	< 500	23	< 50	< 5.0	7.9	1.8 J1	2.7 J1	< 10	< 5.0	< 5.0
GMW-63	10/22/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	71 J1	< 1.0	< 10	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 1.0	< 1.0
GMW-O-2	10/20/09	< 1	< 1	< 1	---	< 10	---	< 1	< 2	< 1	---	< 1	< 10	< 1	< 1	---	< 1	< 1	< 1	< 1
GMW-O-10	10/22/09	< 1	< 1	< 1	---	< 10	---	< 1	< 2	< 1	---	< 1	< 10	< 1	< 1	---	< 1	< 1	< 1	< 1
GMW-O-14	10/23/09	< 200	560	< 200	---	< 4000	---	< 200	< 800	< 200	---	< 200	< 800	< 200	< 200	---	< 200	< 200	< 200	< 200
GMW-O-14 DUP	10/23/09	< 200	560	< 200	---	< 4000	---	< 200	< 800	< 200	---	< 200	< 800	< 200	< 200	---	< 200	< 200	< 200	< 200
GMW-O-16	10/21/09	< 1	< 1	< 1	---	< 10	---	< 1	< 2	< 1	---	< 1	< 10	< 1	< 1	---	< 1	< 1	< 1	< 1
GMW-O-18	10/21/09	< 5	30	9.2	---	< 100	---	< 5	< 20	< 5	---	< 5	< 20	< 5	< 5	---	< 5	< 5	< 5	< 5
GMW-SF-8	10/21/09	< 1	< 1	< 1	---	< 10	---	3.3	< 2	< 1	---	< 1	< 10	< 1	< 1	---	< 1	< 1	< 1	< 1
GW-3	10/22/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	85 J1	< 1.0	< 10	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 1.0	< 1.0
GW-13	10/23/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	3.8	< 100	< 1.0	< 10	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 1.0	< 1.0
GW-14	10/22/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	< 100	< 1.0	< 10	< 1.0	< 1.0	< 1.0	0.51 J1	< 2.0	< 1.0	< 1.0
MW-7	10/21/09	< 1	< 1	< 1	---	< 10	---	< 1	< 2	2	---	< 1	< 10	< 1	< 1	---	< 1	< 1	< 1	< 1
MW-11	10/22/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	80 J1	2.7	3.7 J1	< 1.0	1.1	< 1.0	0.68 J1	< 2.0	< 1.0	< 1.0
MW-12	10/21/09	< 1	< 1	< 1	---	< 10	---	< 1	< 2	< 1	---	< 1	< 10	< 1	< 1	---	< 1	< 1	< 1	< 1
MW-14	10/22/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	3	61 J1	< 1.0	< 10	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 1.0	< 1.0
MW-19 MID	10/21/09	< 1	< 1	< 1	---	< 10	---	< 1	< 2	16	---	< 1	< 10	< 1	< 1	---	< 1	< 1	< 1	< 1

TABLE 7

SUMMARY OF MISCELLANEOUS COMPOUNDS IN GROUNDWATER  
OCTOBER 2009 SEMIANNUAL EVENT

Defense Fuel Support Point, Norwalk  
Norwalk, California

Results reported in micrograms per liter (µg/L)

Well	Sample Date	1,1-Dichloroethane	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	2-Butanone	Acetone	c-1,2-Dichloroethene	Chloroform	Chloromethane	Diisopropyl Ether (DIPE)	Ethanol	Isopropylbenzene	Naphthalene	n-Butylbenzene	n-Propylbenzene	p-Isopropyltoluene	sec-Butylbenzene	Tert-Amyl-Methyl Ether (TAME)	tert-Butylbenzene	Trichloroethene
MW-20 MID	10/21/09	< 1	< 1	< 1	---	< 10	---	< 1	< 2	14	---	< 1	< 10	< 1	< 1	---	< 1	< 1	< 1	< 1
MW-22 MID	10/23/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	< 100	< 1.0	< 10	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 1.0	< 1.0
MW-23 MID	10/23/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	< 100	< 1.0	< 10	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 1.0	< 1.0
MW-SF-1	10/23/09	< 100	< 100	< 100	---	< 2000	---	< 100	< 400	< 100	---	< 100	< 400	< 100	< 100	---	< 100	< 100	< 100	< 100
MW-SF-9	10/22/09	< 20	< 20	< 20	---	< 400	---	< 20	< 80	< 20	---	< 20	< 80	< 20	< 20	---	< 20	< 20	< 20	< 20
PZ-5	10/23/09	< 10	22	< 10	---	< 200	---	< 10	< 40	< 10	---	< 10	< 40	< 10	< 10	---	< 10	< 10	< 10	< 10
PZ-5 DUP	10/23/09	< 10	23	< 10	---	< 200	---	< 10	< 40	< 10	---	< 10	< 40	< 10	< 10	---	< 10	< 10	< 10	< 10
PZ-10	10/22/09	< 2	< 2	< 2	---	< 40	---	< 2	< 8	< 2	---	< 2	< 10	< 2	< 2	---	< 2	< 2	< 2	< 2
TF-16	10/26/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	< 100	11	4.3 J1	< 1.0	7.7	< 1.0	2.1	0.35 J1	0.54 J1	< 1.0
TF-21	10/26/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	< 100	21	5.9 J1	0.48 J1	8.5	< 1.0	1.8	< 2.0	0.54 J1	< 1.0
WCW-3	10/26/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	0.44 J1	< 100	< 1.0	< 10	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 1.0	< 1.0
WCW-7	10/26/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	3.7	< 100	< 1.0	< 10	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 1.0	< 1.0
WCW-8	10/26/09	< 1.0	< 1.0	< 1.0	< 10	< 50	< 1.0	< 1.0	< 5.0	< 2.0	< 100	< 1.0	< 10	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 1.0	< 1.0

Notes:

1. < 2 = compound not detected at or above the indicated reporting limit.
2. --- = compound not analyzed.
3. DUP = duplicate.
4. J1 = Result reported is below the reporting limit and above the method detection limit.

**TABLE 8**

**SUMMARY OF QUALITY ASSURANCE/QUALITY CONTROL ANALYTICAL DATA  
2009 THIRD QUARTER SENTRY AND SECOND SEMIANNUAL EVENTS**

Defense Fuel Support Point, Norwalk  
Norwalk, California

Results reported in micrograms per liter (µg/L)

Sample ID	Sample Date	Sampled by	TPHg <sup>1</sup>	TPHfp <sup>2</sup>	Benzene	Toluene	Ethyl-benzene	Xylenes <sup>3</sup>	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>	TBA <sup>6</sup>
TB-1	07/20/09	Blaine Tech	---	---	< 0.5	< 0.5	< 0.5	< 1.0	< 0.5	< 0.5	< 10
TB-1	07/20/09	Parsons	---	---	< 0.50	< 0.50	< 0.50	< 1.0	< 0.50	< 0.50	< 10
TB-2	07/21/09	Blaine Tech	---	---	< 0.5	< 0.5	< 0.5	< 1.0	< 0.5	< 0.5	< 10
TB	07/21/09	Parsons	---	---	< 0.50	< 0.50	< 0.50	< 1.0	< 0.50	< 0.50	< 10
TB-3	07/22/09	Blaine Tech	---	---	< 0.5	< 0.5	< 0.5	< 1.0	< 0.5	< 0.5	< 10
TB	10/19/09	Parsons	---	---	< 0.50 <sup>8</sup>	< 0.50	< 0.50	< 1.0	< 0.50	< 0.50	< 10
TB-1	10/19/09	Blaine Tech	---	---	< 0.5	< 0.5	< 0.5	< 1.0	< 0.5	< 0.5	< 10
TB	10/20/09	Parsons	---	---	< 0.5	< 0.5	< 0.5	< 1.0	< 0.5	< 0.5	< 10
TB-2	10/20/09	Blaine Tech	---	---	< 0.5	< 0.5	< 0.5	< 1.0	< 0.5	< 0.5	< 10
TB	10/21/09	Parsons	---	---	< 0.50	< 0.50	< 0.50	< 1.0	< 0.50	< 0.50	< 10
TB-3	10/21/09	Blaine Tech	---	---	< 0.5	< 0.5	< 0.5	< 1.0	< 0.5	< 0.5	< 10
TB-4	10/21/09	Blaine Tech	---	---	< 0.5	< 0.5	< 0.5	< 1.0	< 0.5	< 0.5	< 10
TB	10/22/09	Parsons	---	---	< 0.50	< 0.50	< 0.50	< 1.0	< 0.50	< 0.50	< 10
TB-5	10/22/09	Blaine Tech	---	---	< 0.5	< 0.5	< 0.5	< 1.0	< 0.5	< 0.5	< 10
TB	10/23/09	Parsons	---	---	< 0.50	< 0.50	< 0.50	< 1.0	< 0.50	< 0.50	< 10
TB-6	10/23/09	Blaine Tech	---	---	< 0.5	< 0.5	< 0.5	< 1.0	< 0.5	< 0.5	< 10
TB-7	10/23/09	Blaine Tech	---	---	< 0.5	< 0.5	< 0.5	< 1.0	< 0.5	< 0.5	< 10
TB	10/26/09	Parsons	---	---	< 0.50	< 0.50	< 0.50	< 1.0	< 0.50	< 0.50	< 10
TB	10/27/09	Parsons	---	---	< 0.50	< 0.50	< 0.50	< 1.0	< 0.50	< 0.50	< 10

**Notes:**

- <sup>1</sup> TPHg = total petroleum hydrocarbons quantified using a gasoline standard.
- <sup>2</sup> TPHfp = total petroleum hydrocarbons quantified using a site fuel product standard.
- <sup>3</sup> Xylenes = total of m,p-xylene and o-xylene when detected.
- <sup>4</sup> 1,2-DCA = 1,2-dichloroethane.
- <sup>5</sup> MTBE = methyl tertiary-butyl ether.
- <sup>6</sup> TBA = Tert-butyl Alcohol
- <sup>7</sup> --- = not analyzed.
- <sup>8</sup> < 0.50 = not detected at or above the reporting limit shown.

**TABLE 9****HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**Defense Fuel Support Point, Norwalk  
Norwalk, California

Results reported in micrograms per liter (µg/L)

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
EXP-1	11/27/96	GSI	---	82	<500 <sup>7</sup>	<500	---	1.4	<0.5	<0.5	2.7	<0.5	<1
EXP-1	3/14/97	Groundwater Technology Inc	---	<50	<47	---	---	<0.5	<0.5	<0.5	<0.5	---	---
EXP-1	3/14/97	Groundwater Technology Inc	---	<50	<50	---	---	<0.5	<0.5	<0.5	<0.5	---	---
EXP-1	3/14/97	Groundwater Technology Inc	---	<100	---	---	---	<2	<2	<2	<2	---	---
EXP-1	7/10/97	Groundwater Technology Inc	---	<50	290	<200	---	<5	<5	<5	<5	<5	<5
EXP-1	1/9/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
EXP-1	5/20/98	BBC	---	<300	---	---	---	0.5	0.9	<0.5	<1	<0.5	<0.5
EXP-1	11/4/98	Groundwater Technology Inc	---	<300	---	---	175	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	5/26/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	8/10/99	Alton Geoscience	---	<500	<1000	---	---	<0.5	<1	<1	<1	<0.5	<1
EXP-1	9/23/99	Secor	---	<300	---	---	---	<0.5	<1	<1	<1	<0.5	<1
EXP-1	10/12/99	Secor	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
EXP-1	11/18/99	IT Corporation	---	<300	---	---	<100	<0.5	<1	<0.5	<0.5	<0.5	<0.5
EXP-1	11/19/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	12/21/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	1/20/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	2/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	3/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	4/20/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	5/17/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	5/18/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	6/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	8/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	11/29/00	IT Corporation	---	<300	---	---	<100	0.5	<0.5	<0.5	0.7	<0.5	<0.5
EXP-1	2/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	5/9/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	4/10/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	7/30/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.98
EXP-1	9/6/02	Secor	---	---	---	---	---	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	10/23/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<0.3	<0.5	<5
EXP-1	10/24/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	1/29/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	4/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	4/10/03	Groundwater Technology Inc	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	10/8/03	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	10/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	1/29/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	4/21/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	4/21/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	7/19/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	7/21/04	Parsons	---	200	---	---	<100	<0.5	<0.5	<0.5	---	---	<0.5
EXP-1	11/3/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
EXP-1	2/2/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-1	11/2/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	2/27/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	5/2/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	5/3/06	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	9/19/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	12/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	12/5/06	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-1	3/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	5/2/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	5/2/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-1	8/29/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	11/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	11/13/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-1	2/20/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	4/16/08	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-1	4/16/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	8/14/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	10/15/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-1	10/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	2/24/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	4/20/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-1	4/22/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5



TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toulene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
EXP-1	7/20/09	Blaine Tech	---	< 50	---	---	120	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-1	10/19/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-1	10/19/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	11/27/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<0.1	<0.5	<1
EXP-2	3/14/97	Groundwater Technology Inc	---	<50	75	---	---	<0.5	<0.5	<0.5	<0.5	---	---
EXP-2	3/14/97	Groundwater Technology Inc	---	72	200	---	---	<0.5	<0.5	<0.5	<0.5	---	---
EXP-2	3/14/97	Groundwater Technology Inc	---	<100	---	---	---	<2	<2	<2	<2	---	---
EXP-2	7/10/97	Groundwater Technology Inc	---	<50	<50	<50	---	<5	<5	<5	<5	<5	<5
EXP-2	1/9/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
EXP-2	5/20/98	BBC	---	<300	---	---	---	<0.5	0.6	<0.5	<1	<0.5	<0.5
EXP-2	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	1.5	1	10	<0.5	<0.5
EXP-2	5/7/99	Alton Geoscience	---	<500	<500	---	---	1.6	1.1	<0.5	1.9	<1	1.7
EXP-2	5/26/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.4
EXP-2	7/21/99	Alton Geoscience	---	<50	---	---	---	<0.5	<0.5	<0.5	<0.5	<1	0.83
EXP-2	8/10/99	Alton Geoscience	---	<500	<1000	---	---	<0.5	<1	<1	<1	<0.5	<1
EXP-2	9/23/99	Secor	---	<300	---	---	---	<0.5	<1	<1	<1	<0.5	<1
EXP-2	10/12/99	Secor	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
EXP-2	11/18/99	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	11/19/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	12/21/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	1/20/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	2/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	3/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	4/20/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	5/16/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	5/18/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	6/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	8/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	11/29/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	2/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	5/9/01	IT Corporation	---	<300	---	---	<100	<0.5	0.9	<0.5	0.8	<0.5	<0.5
EXP-2	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	4/10/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	7/30/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	10/23/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
EXP-2	10/24/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	1/28/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	4/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	4/11/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	10/7/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	10/10/03	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	1/29/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	4/21/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	4/22/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	7/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	7/21/04	Parsons	---	120	---	---	<100	<0.5	<0.5	<0.5	---	---	<0.5
EXP-2	11/4/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
EXP-2	2/3/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	5/5/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-2	11/2/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	2/28/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	5/3/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	5/3/06	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	9/19/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	12/6/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	12/6/06	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-2 DUP <sup>6</sup>	12/6/06	Parsons	---	< 100	---	---	< 100	---	---	---	---	---	---
EXP-2	3/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	5/2/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	5/3/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-2	8/29/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	11/14/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	11/14/07	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	2/21/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	4/17/08	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-2	4/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	8/14/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	10/16/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-2	10/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	2/24/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	4/21/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
EXP-2	4/22/09	Blaine Tech	---	< 50	---	---	< 100	1.1	0.59	0.67	1.78	< 0.5	< 0.5
EXP-2	7/20/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-2	10/19/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-2	10/19/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	11/27/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1	<0.5	<1
EXP-3	3/14/97	Groundwater Technology Inc	---	<50	120	---	---	<0.5	<0.5	<0.5	<0.5	---	---
EXP-3	3/14/97	Groundwater Technology Inc	---	<50	250	---	---	<0.5	<0.5	<0.5	<0.5	---	---
EXP-3	3/14/97	Groundwater Technology Inc	---	<100	---	---	---	<2	<2	<2	<2	---	---
EXP-3	7/10/97	Groundwater Technology Inc	---	<50	<50	<50	---	<5	<5	<5	<5	<5	<5
EXP-3	1/9/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
EXP-3	5/20/98	BBC	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
EXP-3	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	5/7/99	Alton Geoscience	---	---	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	0.89
EXP-3	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	8/10/99	Alton Geoscience	---	<500	<1000	---	---	4	6.2	<1	3.4	<0.5	<1
EXP-3	9/23/99	Secor	---	<300	---	---	---	<0.5	<1	<1	<1	<0.5	<1
EXP-3	10/12/99	Secor	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
EXP-3	11/18/99	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	11/19/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	12/21/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	1/20/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	2/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	3/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	4/20/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	5/17/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	5/18/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	6/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	8/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	11/30/00	IT Corporation	---	<300	---	---	<100	<0.5	0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	2/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	5/9/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	11/7/01	IT Corporation	---	<300	---	---	<100	0.8	0.6	<0.5	<0.5	<0.5	<0.5
EXP-3	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.6	<0.5	<0.5	<0.5	<0.5
EXP-3	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	4/12/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	7/30/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	10/22/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<1
EXP-3	10/23/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
EXP-3	1/29/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	4/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	4/11/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	10/7/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	10/10/03	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	1/29/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	4/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	4/22/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	7/19/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	7/21/04	Parsons	---	120	---	---	<100	<0.5	<0.5	<0.5	---	---	<0.5
EXP-3	11/3/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
EXP-3	2/2/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-3	11/2/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	2/27/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	5/2/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	5/5/06	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	9/18/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	12/5/06	Parsons	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	12/6/06	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-3 DUP	12/6/06	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-3	3/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	5/4/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	5/4/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-3	8/30/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	11/15/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	11/16/07	Parsons	---	< 100	---	---	1500	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-3	2/7/08	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-3	2/21/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	4/16/08	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-3	4/16/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	8/14/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	10/14/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	10/15/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-3	2/24/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
EXP-3	4/22/09	Parsons	< 100	< 100	---	---	---	< 0.50	3.4	< 0.50	< 1	< 0.50	< 0.50
EXP-3	4/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	7/20/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-3	7/20/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-3	10/19/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
EXP-3	10/19/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-4	2/3/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<1	<1	<0.5
EXP-4	5/6/99	Alton Geoscience	---	<500	<500	---	---	1.3	4.1	<0.5	1.7	<1	<0.5
EXP-4	7/21/99	Alton Geoscience	---	<50	---	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
EXP-4	8/10/99	Alton Geoscience	---	<500	<1000	---	---	50	80	7.7	44	2.1	4.2
EXP-4	9/23/99	Secor	---	<300	---	---	---	<0.5	<1	<1	<1	<0.5	<1
EXP-4	9/23/99	Secor	---	<300	---	---	---	<0.5	<1	<1	<1	<0.5	<1
EXP-4	9/23/99	Secor	---	<300	---	---	---	<0.5	<1	<1	<1	0.72	1.2
EXP-4	10/12/99	Secor	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
EXP-4	11/19/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.6
EXP-4	12/21/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	12/21/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	1/20/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	0.5	<0.5	<0.5
EXP-4	2/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	3/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	4/20/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	5/18/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	6/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	8/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	11/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	2/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	9/18/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	10/24/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	10/7/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	5/5/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-4	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-4	9/20/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-4	5/1/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-4	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-4	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-4	7/20/09	Blaine Tech	---	< 50	---	---	120	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-4	10/19/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	11/11/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	2/3/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<1	<1	<0.5
EXP-5	5/5/99	Alton Geoscience	---	<500	<500	---	---	7.6	3.9	1.4	7.4	<1	140
EXP-5 DUP	5/5/99	Alton Geoscience	---	<500	<500	---	---	7.4	3.8	1.3	6.8	<1	150
EXP-5	7/21/99	Alton Geoscience	---	<50	---	---	---	<0.5	<0.5	<0.5	<0.5	<1	11
EXP-5	8/10/99	Alton Geoscience	---	<500	<1000	---	---	21	37	4.3	22	<0.5	2.4
EXP-5	9/23/99	Secor	---	<300	---	---	---	<0.5	<1	<1	<1	<0.5	<1
EXP-5	9/23/99	Secor	---	<300	---	---	---	<0.5	<1	<1	<1	<0.5	<1
EXP-5	9/23/99	Secor	---	<300	---	---	---	<0.5	<1	<1	<1	<0.5	<1
EXP-5	10/12/99	Secor	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
EXP-5	11/19/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	12/21/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	1/20/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	2/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	3/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	4/20/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	6/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	8/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	11/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	2/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	7/30/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	10/24/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	1/28/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	4/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	10/7/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	1/29/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	4/21/04	Secor	---	<50	---	---	160	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	7/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	11/4/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
EXP-5	2/3/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
EXP-5	11/1/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	2/28/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	9/19/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	12/7/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	3/12/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	5/3/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	8/28/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	11/15/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	2/20/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	8/14/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	10/15/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	2/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	4/22/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	7/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
EXP-5	10/19/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-1	11/27/96	Terra Services	---	---	---	---	---	13000	11000	2700	14300	<50	<500
GMW-1	7/17/97	Terra Services	---	68000	6900	---	---	10000	5500	2500	11500	<30	<300
GMW-1	1/9/98	Terra Services	---	5800	4500	---	---	5600	590	1200	4570	<30	<300
GMW-1	5/27/98	Terra Services	---	19600	---	---	---	4360	466	930	2279	<0.5	101
GMW-1	11/17/98	Alton Geoscience	---	4260	---	---	32200	950	150	360	320	<50	<50
GMW-1	5/5/99	Alton Geoscience	---	<500	<500	---	---	1.9	8.4	0.58	2.9	<1	<0.5
GMW-1	11/17/99	Secor	---	23000	---	---	25000	4700	440	1100	4040	<5	71
GMW-1	5/16/00	Secor	---	14000	---	---	16000	3100	40	720	2300	<25	50
GMW-1	11/30/00	Secor	---	14000	---	---	28000	2700	80	1000	1780	<0.5	33
GMW-1	5/9/01	Secor	---	1000	---	---	18000	1900	<13	530	468	<13	<13
GMW-1	11/6/01	Secor	---	11000	---	---	18000	2900	35	1300	280	<0.5	27
GMW-1	4/10/02	Secor	---	7600	---	---	13000	2000	26	740	295	<10	18
GMW-1	10/23/02	Secor	---	830	---	---	8400	1300	<5	330	111	<5	17
GMW-1	3/11/03	Geomatrix	---	340	---	---	390	130	<0.5	30	6.05	<0.5	0.68
GMW-1	4/8/03	Secor	---	4500	---	---	2100	2200	<10	240	142	<20	25
GMW-1	8/1/03	Secor	---	4000	---	---	2100	1600	11	360	172	<20	14
GMW-1	10/6/03	Secor	---	7400	---	---	2500	2200	12	520	196	<20	13
GMW-1	1/27/04	Secor	---	4400	---	---	2200	1500	5.7	180	200	<10	12
GMW-1	4/22/04	Secor	---	9100	---	---	5200	3200	<20	270	160	<40	<20
GMW-1	7/19/04	Secor	---	6000	---	---	1800	2100	<10	90	70	<20	20
GMW-1	11/3/04	Secor	---	7900	---	---	3700	3500	<10	88	35	<20	18
GMW-1	2/2/05	Secor	---	2100	---	---	1500	1100	<5	18	29	<10	12
GMW-1	5/6/05	Secor	---	<200	---	---	320	1.2	<1	<1	<1	<2	<1
GMW-1	11/2/05	Secor	---	< 500	---	---	1400	< 2.5	< 2.5	< 2.5	< 5	< 5	< 2.5
GMW-1	2/27/06	Secor	---	< 1000	---	---	1600 *	< 5	< 5	< 5	< 10	< 10	< 5
GMW-1	5/4/06	Secor	---	< 500	---	---	1600 *	4	< 2.5	< 2.5	< 5	< 5	< 2.5
GMW-1	9/18/06	Secor	---	< 500	---	---	1300 *	< 2.5	< 2.5	< 2.5	< 5	< 5	< 2.5
GMW-1	12/6/06	Secor	---	< 500	---	---	4500 *	< 2.5	< 2.5	< 2.5	< 5	< 5	< 2.5
GMW-1 DUP	12/6/06	Secor	---	< 500	---	---	3200 *	< 2.5	< 2.5	< 2.5	< 5	< 5	< 2.5
GMW-1	3/13/07	Secor	---	< 1000	---	---	2000	< 5	< 5	< 5	< 10	< 10	< 5
GMW-1 DUP	3/13/07	Secor	---	< 1000	---	---	2900	< 5	< 5	< 5	< 10	< 10	< 5
GMW-1	5/4/07	Secor	---	< 50	---	---	1500	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-1 DUP	5/4/07	Secor	---	< 100	---	---	1700	< 0.5	< 0.5	< 0.5	< 1	< 1	< 0.5
GMW-1 DUP	8/29/07	Secor	---	560	---	---	910	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-1	8/30/07	Secor	---	520	---	---	910	< 1.5	< 1.5	< 1.5	< 3	< 3	< 1.5
GMW-1	11/14/07	Secor	---	140	---	---	430	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-1 DUP	11/14/07	Secor	---	230	---	---	450	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-1	2/21/08	Secor	---	< 200	---	---	690	41	< 1	4.9	4.8	< 2	< 1
GMW-1	4/16/08	Secor	---	< 200	---	---	1200	14	< 1	< 1	< 2	< 2	< 1
GMW-1 DUP	4/16/08	Secor	---	< 200	---	---	1200	14	< 1	< 1	< 2	< 2	< 1
GMW-1	10/17/08	Secor	---	1600	---	---	2900	52	1.6	58	250	< 2	< 1
GMW-1 DUP	10/17/08	Secor	---	1400	---	---	3000	49	1.5	51	221	< 2	< 1
GMW-1	4/20/09	Blaine Tech	---	600	---	---	2400	63	1.2	25	15.7	< 2	< 1
GMW-1 DUP	4/20/09	Blaine Tech	---	730	---	---	2500	72	1.4	39	21	< 2	< 1
GMW-1	10/22/09	Blaine Tech	---	330	---	---	1900	1.5	< 1	< 1	< 2	< 2	< 1
GMW-1 DUP	10/22/09	Blaine Tech	---	340	---	---	2000	2.1	< 1	< 1	< 2	< 2	< 1
GMW-2	11/21/96	Terra Services	---	---	---	---	---	6500	44	700	960	<30	4800
GMW-2	7/15/97	Terra Services	---	350	<500	---	---	59	1.2	41	20	<0.5	<5
GMW-2	1/8/98	Terra Services	---	<100	<500	---	---	4.1	0.79	1.1	1.1	2.7	220
GMW-2	5/27/98	Terra Services	---	<300	---	---	---	<0.5	58	0.8	0.5	<0.5	21
GMW-2	11/17/98	Alton Geoscience	---	<300	---	---	<100	0.88	2.1	0.9	4.8	<0.5	4.4
GMW-2	5/7/99	Alton Geoscience	---	<500	<500	---	---	8.2	<0.5	<0.5	0.94	<1	42
GMW-2	11/17/99	Secor	---	<300	---	---	<100	0.7	<0.5	<0.5	<0.5	<0.5	66
GMW-2	5/16/00	Secor	---	<300	---	---	200	<0.5	<0.5	<0.5	<0.5	0.6	<0.5
GMW-2	11/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1	140
GMW-2	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.6	51
GMW-2	11/6/01	Secor	---	<300	---	---	<100	7.8	<0.5	<0.5	0.7	1.2	140
GMW-2	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	240

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-2	10/23/02	Secor	---	<300	---	---	240	<0.5	<0.5	<0.5	<0.5	<0.5	260
GMW-2	10/7/03	Secor	---	91	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	81
GMW-2	5/6/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-2	5/6/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	4.2
GMW-2	5/2/07	Secor	---	160	---	---	110	73	< 0.5	< 0.5	2.3	< 1	5.8
GMW-2	4/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-2	4/20/09	Blaine Tech	---	< 50	---	---	<b>100</b>	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-3	11/25/96	Terra Services	---	---	---	---	---	<5	<5	<0.5	<1.5	<5	<50
GMW-3	7/11/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	<0.5	<5
GMW-3	1/5/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-3 DUP	1/9/98	Terra Services	---	---	---	---	---	70	58	410	591	<5	<50
GMW-3	5/26/98	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	0.9	<0.5	<0.5
GMW-3	11/11/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.7
GMW-3	5/7/99	Alton Geoscience	---	<500	<500	---	---	1.1	4.4	<0.5	1.9	<1	<0.5
GMW-3	11/17/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	11/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	4/10/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	10/22/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.1
GMW-3	1/29/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.96
GMW-3	4/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	10/6/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	1/27/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	4/21/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	7/19/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	11/2/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-3	11/3/05	Secor	---	120	---	---	710	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-3	2/27/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-3	5/2/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-3	12/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-3	5/4/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-3	11/14/07	Secor	---	< 200	---	---	1800	< 1	< 1	< 1	< 2	< 2	< 1
GMW-3	4/16/08	Parsons	---	< 100	---	---	750	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-3	4/16/08	Secor	---	< 100	---	---	220	< 0.5	< 0.5	< 0.5	< 1	< 1	< 0.5
GMW-3	10/14/08	Secor	---	< 50	---	---	110	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-3	4/20/09	Blaine Tech	---	< 50	---	---	< 100	<b>0.63</b>	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-3	10/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-4	7/15/97	Terra Services	---	1300	2100	---	---	38	<0.5	35	45	<0.5	<5
GMW-4	1/8/98	Terra Services	---	380	530	---	---	14	1.2	12	18.8	1.6	<5
GMW-4	5/26/98	Terra Services	---	2300	---	---	---	42	<0.3	69	87	<2.5	<2.5
GMW-4	11/18/99	Secor	---	1600	---	---	4100	67	<0.5	51	24.1	<0.5	<0.5
GMW-4	5/19/00	Secor	---	2500	---	---	3400	48	0.5	29	36.9	<0.5	<0.5
GMW-4	4/10/03	Secor	---	500	---	---	1100	8	<0.5	8.2	26	<0.5	<0.5
GMW-4	5/4/07	Secor	---	2000	---	---	13000	110	< 1	27	12.1	< 2	< 1
GMW-4	4/16/08	Parsons	---	16000	---	---	14000	270	< 2.5	110	157	< 2.5	< 2.5
GMW-4	4/17/08	Secor	---	4400	---	---	40000	290	< 5	89	102	< 10	< 5
GMW-4	11/21/08	Secor	---	4900	---	---	16000	260	< 2.5	45	27.9	< 5	< 2.5
GMW-4	4/23/09	Blaine Tech	---	<b>2500</b>	---	---	<b>9500</b>	<b>120</b>	< 0.5	<b>12</b>	<b>8.6</b>	< 1	<b>3.9</b>
GMW-5	11/27/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1	---	---
GMW-5	7/11/97	Groundwater Technology Inc	---	<50	<50	<50	---	<0.5	<1	<1	<2	---	---
GMW-5	1/6/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.3	<0.3	<0.3	<0.6	---	---
GMW-5	5/18/98	BBC	---	---	---	---	---	<0.3	<0.3	<0.3	<0.6	---	---
GMW-5	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-5	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-5	11/18/99	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-5	5/16/00	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-5	11/29/00	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-5	5/9/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-5	11/7/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-5	4/10/02	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-6	11/27/96	GSI	---	5300	<500	<500	---	330	<12	320	300	---	---
GMW-6	7/9/97	Groundwater Technology Inc	---	<50	<50	<50	---	2.7	<1	1.4	<2	<5	---
GMW-6	1/7/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.3	<0.3	<0.3	<0.6	---	---
GMW-6	5/21/98	BBC	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-6	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-6	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-6	11/18/99	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-6	5/16/00	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-6	11/29/00	IT Corporation	---	<300	---	---	550	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-6	5/9/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-6	11/7/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-6	4/10/02	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-6	10/23/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-6	4/10/03	Groundwater Technology Inc	---	---	---	---	<100	<1	<1	<1	<2	---	<3
GMW-6	10/8/03	Parsons	---	---	---	---	130	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-6	4/22/04	Parsons	---	---	---	---	<100	0.41	<0.3	<0.3	<0.3	---	<5
GMW-6	11/6/04	Parsons	---	---	---	---	4100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-6	5/6/05	Parsons	---	---	---	---	<100	<0.3	0.46	<0.3	<0.3	---	<5
GMW-6	11/8/05	Parsons	---	---	---	---	< 100	< 0.3	< 0.3	< 0.3	< 0.3	---	< 5
GMW-6	5/3/06	Parsons	---	---	---	---	< 100	< 0.3	< 0.3	< 0.3	< 0.3	---	< 5
GMW-6	12/8/06	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	1.3	---	< 5.0
GMW-6	5/2/07	Parsons	---	---	---	---	< 100	0.58	0.54	< 0.50	< 1.0	---	< 5.0
GMW-6	11/14/07	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	---	< 5
GMW-6	4/16/08	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-6	10/15/08	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	1.1
GMW-6	4/21/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	---	43
GMW-6	10/20/09	Parsons	110 J <sup>1</sup>	---	---	---	---	1.5	< 0.5	< 0.5	< 1	< 0.5	350
GMW-7	5/21/98	BBC	---	---	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-7	12/1/00	IT Corporation	---	520000	---	---	370000	4800	970	620	12000	---	<2500
GMW-8	11/21/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	12	<5
GMW-8	7/11/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	1.7	<5
GMW-8	1/2/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	5	<5
GMW-8	5/26/98	Terra Services	---	---	---	---	---	<0.3	<0.3	<0.5	<1	<0.5	<0.5
GMW-8	11/6/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	8.6	0.9
GMW-8	5/5/99	Alton Geoscience	---	<500	<500	---	---	2	7.2	0.57	3	<1	<0.5
GMW-8	5/7/99	Alton Geoscience	---	<500	<500	---	---	<0.5	1.7	<0.5	0.51	4.4	<0.5
GMW-8 DUP	5/7/99	Alton Geoscience	---	<500	<500	---	---	0.52	2.1	<0.5	0.65	2.7	<0.5
GMW-8	11/16/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	4.6	<0.5
GMW-8	5/19/00	Secor	---	<300	---	---	380	<0.5	<0.5	<0.5	<0.5	15	<0.5
GMW-8	11/29/00	Secor	---	<300	---	---	780	1	0.9	<0.5	1.5	10	2.9
GMW-8	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-8	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-8	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	2.5	2.4
GMW-8	10/24/02	Secor	---	<300	---	---	120	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-8	4/10/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.62
GMW-8	10/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.52	<0.5
GMW-8	4/21/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-8	11/5/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-8	5/5/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-8	11/3/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-8	5/3/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.78
GMW-8	12/7/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	7.6
GMW-8	5/5/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	6.5
GMW-8	11/14/07	Secor	---	< 50	---	---	130	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-8	4/17/08	Secor	---	< 50	---	---	130	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-8	10/21/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-8	4/22/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-8	10/19/09	Blaine Tech	---	< 50	---	---	120	< 0.5	< 0.5	< 0.5	< 1	< 0.5	1.5
GMW-11	11/21/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-11	7/10/97	Terra Services	---	220	2500	---	---	<0.5	4	0.9	<0.5	<0.5	<5
GMW-11 DUP	7/10/97	Terra Services	---	---	---	---	---	<0.5	2.1	0.93	<1	<0.5	<5
GMW-11	1/7/98	Terra Services	---	4000	220000	---	---	<0.5	<0.5	<0.5	1.6	<0.5	<5
GMW-11	5/20/98	Terra Services	---	42400	---	---	---	<0.3	<0.3	<25	<50	<2.5	<0.5
GMW-11	11/17/98	Alton Geoscience	---	6230	---	---	146000	<5	6	<5	11	<5	24
GMW-11	5/7/99	Alton Geoscience	---	1900	1900	---	---	0.61	2.1	<0.5	0.62	<1	<0.5
GMW-11	11/16/99	Secor	---	1200	---	---	25000	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-11	5/19/00	Secor	---	790	---	---	1900	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-11	11/30/00	Secor	---	1600	---	---	4100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-11	5/10/01	Secor	---	<300	---	---	670	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-11	11/7/01	IT Corporation	---	<300	---	---	560	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-11	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-12	11/27/96	GSI	---	99	<500	<500	---	<0.5	<0.5	<0.5	<1	<0.5	<1
GMW-12	7/10/97	Groundwater Technology Inc	---	110	8600	<7500	---	<5	<5	<5	<5	<5	<5
GMW-12	1/6/98	Groundwater Technology Inc	---	<500	1000	<100	---	<0.5	1.6	<0.5	<1	<0.5	<0.5
GMW-12	5/21/98	BBC	---	<300	---	---	---	<0.3	<0.3	<0.5	<1	<0.5	<0.5
GMW-12	11/5/98	Groundwater Technology Inc	---	<300	---	---	433	4.5	<0.5	3	1.7	<0.5	<0.5
GMW-12	5/27/99	Groundwater Technology Inc	---	<300	---	---	937	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-12	11/18/99	IT Corporation	---	<300	---	---	4900	<0.5	<1	<0.5	<0.5	<0.5	<0.5
GMW-12	5/17/00	IT Corporation	---	<300	---	---	2200	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-12	11/30/00	IT Corporation	---	<300	---	---	1400	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-12	5/9/01	IT Corporation	---	<300	---	---	2100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-12	11/7/01	IT Corporation	---	<300	---	---	2700	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-12	4/11/02	IT Corporation	---	<300	---	---	1900	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-12	10/23/02	Groundwater Technology Inc	---	<300	---	---	1700	<0.5	<1	<1	<1	<0.5	<1
GMW-12	4/10/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-12	4/14/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-12	10/10/03	Parsons	---	<100	---	---	2900	<0.5	<0.5	0.56	<0.5	<0.5	<0.5
GMW-12	4/21/04	Parsons	---	<100	---	---	2000	<0.5	<0.5	<0.5	0.62	<0.5	<0.5
GMW-12	11/4/04	Parsons	---	<100	---	---	2600	<0.5	<0.5	<0.5	---	<0.5	<0.5
GMW-12	5/6/05	Parsons	---	<100	---	---	1400	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toulene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-12	11/8/05	Parsons	---	< 100	---	---	270	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-12	5/4/06	Parsons	---	< 100	---	---	450	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-12 DUP	5/4/06	Parsons	---	---	---	---	440	---	---	---	---	---	---
GMW-12	12/8/06	Parsons	---	< 100	---	---	150	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-12 DUP	12/8/06	Parsons	---	< 100	---	---	160	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-12	5/4/07	Parsons	---	< 100	---	---	440	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-12 DUP	5/4/07	Parsons	---	---	---	---	420	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-12	11/16/07	Parsons	---	---	---	---	150	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-12	4/18/08	Parsons	---	< 100	---	---	480	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-12	10/16/08	Parsons	310	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-12	4/23/09	Parsons	630	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-12	10/20/09	Parsons	480 J	< 100	---	---	---	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.49
GMW-13	11/21/96	Terra Services	---	---	---	---	---	3.2	<0.5	0.73	1.2	<0.5	<5
GMW-13	7/10/97	Terra Services	---	1300	5600	---	---	1.6	3.5	0.93	2.35	<0.5	<5
GMW-13	1/8/98	Terra Services	---	<100	<500	---	---	1.9	1.6	<0.5	<1.5	<0.5	<5
GMW-13	5/20/98	Terra Services	---	<300	---	---	---	<0.3	<0.3	<25	0.8	<2.5	<0.5
GMW-13	11/12/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-13	5/7/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
GMW-13 DUP	5/7/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
GMW-13	11/17/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-13	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-13	11/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-13	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	2.6
GMW-13	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-13	2/1/02	Secor	---	---	---	---	---	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-13	4/10/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-13	10/22/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<1
GMW-13	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	3.1
GMW-13	10/6/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-13	4/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-13	11/2/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-13	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-13	11/1/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-13	5/2/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-13	12/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-13	5/4/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-13	11/14/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-13	4/16/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-13	10/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-13	4/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-13	10/19/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-14	5/7/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
GMW-14	11/17/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-14	5/16/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-14	11/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-14	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-14	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-14	4/10/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-14	10/7/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-14	4/22/04	Secor	---	59	---	---	110	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-14	11/2/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-14	5/6/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-14	11/1/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-14	3/8/06	Parsons	---	520	---	---	2000	2.6	< 0.5	< 0.5	< 1	0.64	4
GMW-14	5/2/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-14	12/7/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-14	5/4/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-14	11/14/07	Secor	---	1500	---	---	2100	< 2.5	< 2.5	34	3	< 5	< 2.5
GMW-14	4/16/08	Secor	---	440	---	---	850	< 0.5	< 0.5	< 0.5	< 1	< 1	< 0.5
GMW-14	7/29/08	Parsons	---	210	---	---	810	< 0.50	< 0.50	< 0.50	< 1	< 0.50	2.2
GMW-14 DUP	7/29/08	Parsons	---	180	---	---	720	< 0.50	< 0.50	< 0.50	< 1	< 0.50	2.3
GMW-14	10/17/08	Secor	---	210	---	---	420	< 0.5	< 0.5	< 0.5	< 1	< 1	< 0.5
GMW-14	4/23/09	Blaine Tech	---	120	---	---	580	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-14	10/22/09	Blaine Tech	---	130	---	---	740	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-15	5/20/98	BBC	---	1300	---	---	---	3.9	<0.3	7.4	6.4	---	---
GMW-15	11/5/98	Groundwater Technology Inc	---	512	---	---	1170	1.8	<0.3	3.7	1	---	---
GMW-15	5/27/99	Groundwater Technology Inc	---	634	---	---	18600	2.5	<0.3	5.3	2	---	---
GMW-15	11/18/99	IT Corporation	---	<300	---	---	3400	<0.3	<0.3	<0.3	<0.6	---	---
GMW-15	5/16/00	IT Corporation	---	610	---	---	11000	<0.3	<0.3	<0.3	<0.6	---	---
GMW-15	12/1/00	IT Corporation	---	450	---	---	4000	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-15	5/10/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-15	11/7/01	IT Corporation	---	<300	---	---	13000	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-15	4/10/02	IT Corporation	---	1900	---	---	18000	1.2	<0.3	1.6	3.8	---	<5
GMW-15	10/23/02	Groundwater Technology Inc	---	840	---	---	16000	0.58	<0.3	0.72	1.5	---	<5
GMW-15	4/10/03	Groundwater Technology Inc	---	---	---	---	5060	<1	<1	<1	<2	---	<3
GMW-15	10/8/03	Parsons	---	---	---	---	11000	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-15	4/22/04	Parsons	---	---	---	---	4200	0.7	<0.3	<0.3	0.47	---	<5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-15	11/6/04	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-15	5/6/05	Parsons	---	---	---	---	670	<0.3	0.47	<0.3	<0.3	---	<5
GMW-15	11/8/05	Parsons	---	---	---	---	200	<0.3	0.31	<0.3	<0.3	---	<5
GMW-15	5/3/06	Parsons	---	---	---	---	330	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-15	12/8/06	Parsons	---	---	---	---	160	<0.50	<0.50	<0.50	<1.0	---	<5.0
GMW-15	5/2/07	Parsons	---	---	---	---	710	<0.50	<0.50	<0.50	1.2	---	<5.0
GMW-15 DUP	5/2/07	Parsons	---	---	---	---	740	<0.50	<0.50	<0.50	<1.0	---	<5.0
GMW-15	11/14/07	Parsons	---	---	---	---	890	<0.5	<0.5	<0.5	<1	---	<5
GMW-15 DUP	11/14/07	Parsons	---	---	---	---	670	<0.5	<0.5	<0.5	<1	---	<5
GMW-15	4/16/08	Parsons	---	---	---	---	1400	<0.50	<0.50	<0.50	<1.0	---	<5.0
GMW-15	10/15/08	Parsons	1400	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<0.50
GMW-15	4/21/09	Parsons	3600	180	---	---	---	<0.50	<0.50	<0.50	<1	---	5.4
GMW-15	10/20/09	Parsons	4900 J	---	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	3.1
GMW-16	11/21/96	GSI	---	<38	<500	<500	---	<0.5	<0.5	0.8	<1.5	<0.5	---
GMW-16	7/9/97	Groundwater Technology Inc	---	<50	110	<50	---	5.7	<5	9.2	7.5	<5	<5
GMW-16	1/6/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-16	5/20/98	BBC	---	<300	---	---	---	<0.3	<0.3	<0.3	<0.6	---	---
GMW-16	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-16	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-16	11/18/99	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-16	5/16/00	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-16	11/29/00	IT Corporation	---	<300	---	---	140	0.64	1.2	0.85	3.2	---	<5
GMW-16	5/10/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-16	11/7/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	9.1
GMW-16	4/10/02	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-16	10/23/02	Groundwater Technology Inc	---	<300	---	---	110	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-16	4/11/03	Groundwater Technology Inc	---	---	---	---	<100	<1	<1	<1	<2	---	<3
GMW-16	10/8/03	Parsons	---	---	---	---	310	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-16	4/22/04	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-16	11/6/04	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	0.59	---	<5
GMW-16	5/6/05	Parsons	---	---	---	---	<100	<0.3	0.58	<0.3	<0.3	---	<5
GMW-16	11/8/05	Parsons	---	---	---	---	<100	<0.3	0.48	<0.3	<0.3	---	<5
GMW-16 DUP	11/8/05	Parsons	---	---	---	---	100	<0.3	0.42	<0.3	<0.3	---	<5
GMW-16	5/3/06	Parsons	---	---	---	---	100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-16	12/6/06	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1.0	---	<5.0
GMW-16	5/2/07	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1.0	---	<5.0
GMW-16	11/14/07	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	---	<5
GMW-16	4/16/08	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1.0	---	<5.0
GMW-16	10/15/08	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<0.50
GMW-16	4/21/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	---	<0.50
GMW-16	10/20/09	Parsons	<100	---	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-17	5/10/01	IT Corporation	---	6800	---	---	1500000	52	25	<15	330	---	<250
GMW-17	10/24/02	Groundwater Technology Inc	---	49000	---	---	170000	91	<30	<30	160	---	<500
GMW-17	4/14/03	Groundwater Technology Inc	---	---	---	---	10100	572	5.55	75.1	367	---	<15
GMW-17	10/10/03	Parsons	---	---	---	---	8700	240	1.5	9.5	41	---	<10
GMW-17	4/22/04	Parsons	---	---	---	---	2400	540	4.6	24	190	---	63
GMW-17	11/6/04	Parsons	---	---	---	---	3000	110	<0.3	2.1	6.1	---	19
GMW-17	5/10/05	Parsons	---	---	---	---	760	7.9	3.6	<1.5	2.6	---	<25
GMW-17 DUP	5/10/05	Parsons	---	---	---	---	800	---	---	---	---	---	---
GMW-17	11/8/05	Parsons	---	---	---	---	290	3.7	<0.3	0.37	1.9	---	7
GMW-17	5/5/06	Parsons	---	---	---	---	1200	3.7	2.2	1.6	4.5	---	<5
GMW-17	12/5/06	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
GMW-17	12/8/06	Parsons	---	---	---	---	1400	34	<0.50	1.9	30	---	<5.0
GMW-17	5/3/07	Parsons	---	---	---	---	12000	9.1	<0.50	0.92	9	---	7.7
GMW-17	11/14/07	Parsons	---	---	---	---	1200	4.8	<0.5	<0.5	<1	---	<5
GMW-17	4/18/08	Parsons	---	---	---	---	<100	5.3	<0.50	0.62	1.4	---	<5.0
GMW-17	10/17/08	Parsons	1600	---	---	---	---	2.6	<0.50	0.57	<1	<0.50	<0.50
GMW-17	4/22/09	Parsons	760	450	---	---	---	27	<0.50	2.4	<1	---	<0.50
GMW-17 DUP	4/22/09	Parsons	1000	470	---	---	---	25	<0.50	1.9	<1	---	<0.50
GMW-17	10/20/09	Parsons	2400	---	---	---	---	0.42 J1 <sup>10</sup>	<0.5	<0.5	<1	<0.5	<0.5
GMW-17 DUP	10/20/09	Parsons	2100	---	---	---	---	0.46 J1	<0.5	<0.5	<1	<0.5	<0.5
GMW-18	4/14/03	Groundwater Technology Inc	---	---	---	---	16500000	3410	3510	3070	17800	---	<150
GMW-18	10/8/03	Parsons	---	---	---	---	170000	2600	120	360	3100	---	<1000
GMW-18	4/21/04	Parsons	---	---	---	---	45000	2700	<50	380	4288	---	<50
GMW-18	11/4/04	Parsons	---	---	---	---	51000	1300	<3	220	2400	---	<50
GMW-18	5/6/05	Parsons	---	---	---	---	5900	1100	22	140	1200	---	<50
GMW-18	11/8/05	Parsons	---	---	---	---	17000	650	11	17	470	---	<100
GMW-18	5/4/06	Parsons	---	---	---	---	19000	200	1.9	15	100	---	6.9
GMW-18	12/8/06	Parsons	---	---	---	---	6800	320	<0.50	25	190	---	11
GMW-18	5/3/07	Parsons	---	---	---	---	10000	200	<2.5	13	56	---	<25
GMW-18	11/15/07	Parsons	---	---	---	---	1900	160	<0.50	4.1	26	---	5.5
GMW-18	4/17/08	Parsons	---	---	---	---	3400	180	0.87	13	100	---	6.7
GMW-18 DUP	4/17/08	Parsons	---	---	---	---	5000	180	1	13	100	---	6.8
GMW-18	10/16/08	Parsons	2800	---	---	---	---	33	<0.50	2.2	10.64	<0.50	4.7
GMW-18	4/23/09	Parsons	1100	880	---	---	---	60	<0.50	1.4	5	<0.50	3
GMW-18	10/20/09	Parsons	2700	---	---	---	---	15	<0.5	0.55	5.55	<0.5	7
GMW-19	11/27/96	GSI	---	3000	<500	<500	---	85	<2.5	23	<5	---	---



TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-19	7/10/97	Groundwater Technology Inc	---	<50	<50	<50	---	2.5	<1	<1	<2	---	---
GMW-19	1/7/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.3	<0.3	<0.3	<0.6	---	---
GMW-19	5/21/98	BBC	---	<300	---	---	---	<0.3	<0.3	<0.3	<0.6	---	---
GMW-19	11/6/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-19	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-19	11/18/99	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-19	5/17/00	IT Corporation	---	<300	---	---	<100	0.47	0.45	<0.3	0.95	---	---
GMW-19	12/1/00	IT Corporation	---	<300	---	---	440	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-19	5/9/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-19	11/8/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-19	4/11/02	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-19	10/23/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-19	4/14/03	Groundwater Technology Inc	---	---	---	---	<100	<1	<1	<1	<2	---	<3
GMW-19	10/10/03	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	15
GMW-19	4/21/04	Parsons	---	---	---	---	260	<0.5	<1	<1	<1	---	28
GMW-19	11/4/04	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-19	5/6/05	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	0.69	---	<5
GMW-19	11/8/05	Parsons	---	---	---	---	<100	0.52	0.71	0.4	2	---	<5
GMW-19	5/4/06	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-19	12/8/06	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1.0	---	<5.0
GMW-19	5/3/07	Parsons	---	---	---	---	210	<0.50	<0.50	<0.50	<1.0	---	<5.0
GMW-19	11/15/07	Parsons	---	---	---	---	<100	0.5	<0.50	<0.50	<1.0	---	<5.0
GMW-19	4/17/08	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1.0	---	<5.0
GMW-19	10/16/08	Parsons	140	---	---	---	---	0.6	<0.50	<0.50	<1	<0.50	<0.50
GMW-19	4/23/09	Parsons	<100	---	---	---	---	<b>0.7</b>	<0.50	<0.50	<1	---	<b>0.67</b>
GMW-19	10/20/09	Parsons	<100	---	---	---	---	<b>3.8</b>	<0.5	<0.5	<1	<0.5	<b>1.5</b>
GMW-20	11/27/96	GSI	---	1100	<500	<500	---	<2.5	<2.5	<2.5	<5	<2.5	---
GMW-20	7/10/97	Groundwater Technology Inc	---	160	1400	<1200	---	<5	<5	<5	<5	<5	<5
GMW-20	1/6/98	Groundwater Technology Inc	---	<500	1100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-20	5/21/98	BBC	---	400	---	---	---	<0.3	<0.5	<0.5	<0.1	<0.5	<0.5
GMW-20	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-20	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-20	11/18/99	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-20	5/17/00	IT Corporation	---	<300	---	---	120	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-20	11/30/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.5
GMW-20	5/9/01	IT Corporation	---	<300	---	---	110	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-20	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-20	4/11/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-26	11/27/96	Terra Services	---	---	---	---	---	46	2.7	18	8.8	110	950
GMW-26	7/10/97	Terra Services	---	430	<500	---	---	100	2.1	6.9	5.9	67	760
GMW-26	1/8/98	Terra Services	---	200	<500	---	---	23	11	5	<15	64	1200
GMW-26	5/22/98	Terra Services	---	500	---	---	---	<0.3	<0.5	<0.5	<0.1	260	460
GMW-26	11/17/98	Alton Geoscience	---	1810	---	---	<100	310	<5	8	<5	<5	3460
GMW-26	5/7/99	Alton Geoscience	---	2300	<500	---	---	490	26	70	140	<5	6100
GMW-26	11/19/99	Secor	---	6700	---	---	5700	3700	160	42	530	<25	8500
GMW-26	5/16/00	Secor	---	2000	---	---	490	1.9	<0.5	<0.5	<0.5	0.8	82
GMW-26	11/30/00	Secor	---	780	---	---	180	<0.5	<0.5	<0.5	<0.5	3.1	17
GMW-26	5/8/01	Secor	---	300	---	---	120	<0.5	<0.5	<0.5	<0.5	13	390
GMW-26	11/6/01	Secor	---	<300	---	---	<100	0.7	<0.5	<0.5	<0.5	75	130
GMW-26	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	57	130
GMW-26	7/7/03	Geomatrix	---	---	---	---	---	<0.5	<1	<1	<1	1.2	61
GMW-26	4/27/04	Geomatrix	---	63	---	---	<100	<0.5	<0.5	<0.5	<0.5	16	59
GMW-26	7/8/04	Geomatrix	---	62	---	---	290	<0.5	<0.5	<0.5	<0.5	17	27
GMW-27	5/27/98	Terra Services	---	2800	---	---	---	940	6	4	11	76	1570
GMW-27	11/17/98	Alton Geoscience	---	4220	---	---	4940	3200	<50	<50	<50	<50	530
GMW-27	5/7/99	Alton Geoscience	---	6300	<500	---	---	3600	16	11	<10	<25	720
GMW-27	11/18/99	Secor	---	3300	---	---	1500	1100	<25	<25	<25	<25	1000
GMW-27	5/16/00	Secor	---	5500	---	---	3600	2600	<25	25	34	<25	1800
GMW-27	11/30/00	Secor	---	4900	---	---	4100	2100	<25	<25	<25	<25	1600
GMW-27	5/8/01	Secor	---	5300	---	---	4000	2600	<25	<25	<25	<25	2200
GMW-27	11/6/01	Secor	---	4100	---	---	1500	1600	6.4	6.7	27.6	<0.5	1900
GMW-27	4/9/02	Secor	---	4900	---	---	590	2300	<10	15	<10	<10	1800
GMW-27	10/23/02	Secor	---	590	---	---	680	1800	13	<10	13	<10	1400
GMW-27	4/8/03	Secor	---	4600	---	---	640	2700	<15	<15	17	<30	2000
GMW-27	10/7/03	Secor	---	10000	---	---	890	4400	<20	47	120	<40	1800
GMW-27	1/27/04	Secor	---	8100	---	---	480	3600	19	29	115	<30	1500
GMW-27	4/21/04	Secor	---	13000	---	---	1900	6200	<25	51	<25	<50	2500
GMW-27	7/8/04	Geomatrix	---	1900	---	---	540	260	<2.5	<2.5	<2.5	<5	790
GMW-27	11/3/04	Secor	---	21000	---	---	1500	8800	<50	53	170	<100	700
GMW-27	5/6/05	Secor	---	1100	---	---	<100	440	<2.5	<2.5	4.3	<5	42
GMW-27	11/3/05	Secor	---	4100	---	---	330	2000	<10	<10	17	<20	250
GMW-27	5/6/06	Secor	---	5500	---	---	400	2800	<15	22	<30	<30	180
GMW-27	12/6/06	Secor	---	12000	---	---	740	6400	<50	120	<100	<100	210
GMW-27	5/2/07	Secor	---	13000	---	---	860	7400	<50	<50	<100	<100	230
GMW-27	11/13/07	Secor	---	11000	---	---	550	6000	<25	<25	<50	<50	57
GMW-27	4/18/08	Secor	---	380	---	---	270	130	<1.5	<1.5	<3	<3	21
GMW-27	8/14/08	Secor	---	1000	---	---	490	280	<1.5	1.5	1.6	<3	17

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toulene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-27	11/21/08	Secor	---	3100	---	---	340	1100	< 10	< 10	< 20	< 20	26
GMW-27 DUP	11/21/08	Secor	---	2700	---	---	250	1000	< 10	< 10	< 20	< 20	25
GMW-27	4/20/09	Blaine Tech	---	100	---	---	130	1.8	< 0.5	< 0.5	< 1	< 0.5	4.2
GMW-27	10/22/09	Blaine Tech	---	130	---	---	140	< 0.5	< 0.5	< 0.5	< 1	< 0.5	5.7
GMW-28	5/7/99	Alton Geoscience	---	43000	<500	---	---	22000	780	1400	3000	<130	1900
GMW-28	5/17/00	Secor	---	19000	---	---	21000	9600	<50	370	160	<50	1300
GMW-28	11/28/00	Secor	---	26000	---	---	30000	13000	53	650	1139	<0.5	1600
GMW-28	5/8/01	Secor	---	30000	---	---	27000	15000	190	660	310	<5	4000
GMW-28	11/6/01	Secor	---	20000	---	---	19000	14000	51	460	241	<0.5	3200
GMW-28	4/9/02	Secor	---	24000	---	---	1900	9100	79	320	110	<50	1200
GMW-28	7/7/03	Geomatrix	---	---	---	---	---	18000	140	800	450	<50	530
GMW-28	4/28/04	Geomatrix	---	40000	---	---	4700	22000	180	1200	570	<200	280
GMW-28	7/8/04	Geomatrix	---	46000	---	---	5100	20000	120	1000	560	<200	280
GMW-29	11/28/00	Secor	---	1600	---	---	1700	170	97	8	300	<0.5	54
GMW-29	5/8/01	Secor	---	2200	---	---	950	1300	59	21	30	<0.5	<0.5
GMW-29	4/9/02	Secor	---	13000	---	---	11000	5400	4500	240	1120	<1	34
GMW-29	7/8/03	Geomatrix	---	---	---	---	---	4100	670	410	880	<25	<50
GMW-29	4/28/04	Geomatrix	---	40000	---	---	6400	8700	6000	910	2800	<200	<100
GMW-29	7/8/04	Geomatrix	---	45000	---	---	5300	8900	6500	900	4000	<100	<50
GMW-31	11/27/96	GSI	---	1100	<500	<500	---	<2.5	<2.5	<2.5	<5	---	---
GMW-31	7/10/97	Groundwater Technology Inc	---	55	550	<450	---	2	<1	<1	<2	---	---
GMW-31	1/7/98	Groundwater Technology Inc	---	<500	<100	<100	---	1.6	<0.3	<0.3	<0.6	---	---
GMW-31	5/21/98	BBC	---	<300	---	---	---	<0.3	<0.3	<0.3	<0.6	---	---
GMW-31	11/6/98	Groundwater Technology Inc	---	<300	---	---	<100	4.8	<0.3	3.5	<0.6	---	---
GMW-31	5/27/99	Groundwater Technology Inc	---	<300	---	---	1020	<0.3	<0.3	0.52	<0.6	---	---
GMW-31	11/18/99	IT Corporation	---	<300	---	---	490	<0.3	<0.3	<0.3	<0.6	---	---
GMW-31	5/17/00	IT Corporation	---	<300	---	---	470	<0.3	<0.3	<0.3	<0.6	---	---
GMW-31	12/1/00	IT Corporation	---	530	---	---	680	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-31	5/10/01	IT Corporation	---	<300	---	---	120	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-31	11/7/01	IT Corporation	---	<300	---	---	170	0.8	0.49	<0.3	<0.6	---	9.9
GMW-31	4/10/02	IT Corporation	---	<300	---	---	120	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-31	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	0.49	<0.3	<0.3	---	<5
GMW-31	4/14/03	Groundwater Technology Inc	---	---	---	---	647	<1	<1	<1	<2	---	<3
GMW-31	10/10/03	Parsons	---	---	---	---	200	0.39	<0.3	<0.3	<0.3	---	<5
GMW-31	4/22/04	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-31	11/6/04	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-31	5/7/05	Parsons	---	---	---	---	<100	<0.3	0.64	<0.3	<0.3	---	<5
GMW-31	11/8/05	Parsons	---	---	---	---	< 100	< 0.3	< 0.3	< 0.3	< 0.3	---	< 5
GMW-31	5/5/06	Parsons	---	---	---	---	< 100	< 0.3	0.79	0.5	2.4	---	< 5
GMW-31	12/8/06	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-31 DUP	12/8/06	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-31	5/3/07	Parsons	---	---	---	---	170	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-31	11/14/07	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	---	< 5
GMW-31	4/18/08	Parsons	---	---	---	---	810	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-31	10/17/08	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-31	4/22/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	---	< 0.50
GMW-31	10/20/09	Parsons	140	---	---	---	---	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.57
GMW-32	11/27/96	GSI	---	430	<500	<500	---	13	<0.5	25	<1	---	---
GMW-32	7/10/97	Groundwater Technology Inc	---	63	1800	<1600	---	1.7	<1	<1	<2	---	---
GMW-32	1/6/98	Groundwater Technology Inc	---	<500	<100	<100	---	0.4	<0.3	0.7	<0.6	---	---
GMW-32	5/21/98	BBC	---	<300	---	---	---	<0.3	<0.3	<0.3	<0.6	---	---
GMW-32	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	0.62	<0.6	---	---
GMW-32	11/6/98	Groundwater Technology Inc	---	---	---	---	158	---	---	---	---	---	---
GMW-32	5/27/99	Groundwater Technology Inc	---	<300	---	---	307	3.1	<0.3	5	1.4	---	---
GMW-32	11/18/99	IT Corporation	---	<300	---	---	6500	4.3	<0.3	6.9	1.2	---	---
GMW-32	5/17/00	IT Corporation	---	500	---	---	8600	8	3.4	16	14	---	---
GMW-32	11/30/00	IT Corporation	---	330	---	---	2100	<0.3	<0.3	4.2	<0.6	---	<5
GMW-32	5/9/01	IT Corporation	---	1000	---	---	9500	4.7	<0.3	1.2	2.8	---	<5
GMW-32	11/7/01	IT Corporation	---	660	---	---	6900	4.2	0.63	5.7	2	---	<5
GMW-32	2/1/02	Secor	---	---	---	---	---	0.89	<0.5	0.53	0.69	<0.5	0.77
GMW-32	4/11/02	IT Corporation	---	<300	---	---	210	1.5	<0.3	7.2	<0.6	---	<5
GMW-32	10/23/02	Groundwater Technology Inc	---	<300	---	---	1300	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-32	4/9/03	Groundwater Technology Inc	---	---	---	---	2100	<1	1.18	<1	<2	---	<3
GMW-32	10/10/03	Parsons	---	---	---	---	530	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-32	4/21/04	Parsons	---	---	---	---	1500	0.52	<1	<1	<1	---	<1
GMW-32	11/4/04	Parsons	---	---	---	---	910	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-32	5/6/05	Parsons	---	---	---	---	700	0.31	0.64	<0.3	0.76	---	<5
GMW-32 DUP	5/6/05	Parsons	---	---	---	---	680	<0.3	0.43	<0.3	0.42	---	<5
GMW-32	11/8/05	Parsons	---	---	---	---	480	< 0.3	0.41	< 0.3	0.7	---	< 5
GMW-32	5/4/06	Parsons	---	---	---	---	690	0.46	0.39	0.62	1.4	---	< 5
GMW-32	12/8/06	Parsons	---	---	---	---	110	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-32	5/3/07	Parsons	---	---	---	---	190	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-32	11/16/07	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-32	4/17/08	Parsons	---	---	---	---	150	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-32	10/16/08	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-32	4/24/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-32	10/20/09	Parsons	250 J	---	---	---	---	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-33	11/21/96	GSI	---	<38	<500	<500	---	<0.5	<0.5	<0.5	<1.5	<0.5	---
GMW-33	7/10/97	Groundwater Technology Inc	---	<50	700	<400	---	<5	<5	<5	<5	<5	<5
GMW-33	1/6/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-33	5/20/98	BBC	---	<300	---	---	---	<0.3	<0.5	<0.5	<1	<0.5	<0.5
GMW-33	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-33	5/27/99	Groundwater Technology Inc	---	<300	---	---	122	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-33	11/18/99	IT Corporation	---	<300	---	---	120	<0.5	<1	<0.5	<0.5	<0.5	<0.5
GMW-33	5/17/00	IT Corporation	---	<300	---	---	210	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-33	11/30/00	IT Corporation	---	<300	---	---	430	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-33	5/9/01	IT Corporation	---	<300	---	---	150	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-33	11/7/01	IT Corporation	---	<300	---	---	200	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-33	2/1/02	Secor	---	---	---	---	---	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-33	4/11/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.8
GMW-34	11/18/99	IT Corporation	---	9500	---	---	17000	30	3.5	8.3	81	<0.5	24
GMW-34	5/17/00	IT Corporation	---	740	---	---	3700	<0.5	<0.5	1.5	11.4	<0.5	30
GMW-34	12/1/00	IT Corporation	---	<300	---	---	110	<0.5	<0.5	<0.5	<0.5	<0.5	10
GMW-34	5/10/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	7.3
GMW-34	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.2
GMW-34	4/12/02	IT Corporation	---	960	---	---	1500	240	1.4	33	81	<0.5	2.5
GMW-35	5/9/01	IT Corporation	---	20000	---	---	22000	1300	11	580	4100	<10	<10
GMW-35	4/10/03	Groundwater Technology Inc	---	---	---	---	15600	65.2	30.6	109	159	---	<3
GMW-35	10/10/03	Parsons	---	---	---	---	16000	100	<15	120	650	---	<250
GMW-35	4/21/04	Parsons	---	---	---	---	19000	110	<1	45	7.3	---	1.5
GMW-35	11/4/04	Parsons	---	---	---	---	18000	62	<3	13	28	---	<50
GMW-35	5/5/05	Parsons	---	---	---	---	4700	10	1.4	33	22	---	<10
GMW-35	11/5/05	Parsons	---	---	---	---	3100	9.1	2.2	31	17	---	< 25
GMW-35	5/3/06	Parsons	---	---	---	---	17000	7.9	2.9	20	12	---	< 5
GMW-35	12/8/06	Parsons	---	---	---	---	4800	14	< 0.50	9	6.9	---	< 5.0
GMW-35	5/4/07	Parsons	---	---	---	---	4700	21	0.86	1.3	5.3	---	6.1
GMW-35	11/15/07	Parsons	---	---	---	---	2400	26	< 0.50	< 0.50	< 1.0	---	7.7
GMW-35	4/17/08	Parsons	---	---	---	---	1300	18	< 0.50	1.8	2.5	---	< 5.0
GMW-35	4/24/09	Parsons	<b>520</b>	---	---	---	---	<b>63</b>	< 5.0	< 5.0	< 10	---	<b>210</b>
GMW-36	7/10/97	Terra Services	---	430	<500	---	---	---	---	---	---	---	---
GMW-36	1/9/98	Terra Services	---	4000	4300	---	---	22	21	6.1	100	<5	7700
GMW-36	5/20/98	Terra Services	---	1400	---	---	---	<0.3	<0.3	<10	<20	<0.5	19600
GMW-36	11/17/98	Alton Geoscience	---	7900	---	---	6650	2100	1370	70	650	<50	34800
GMW-36	5/7/99	Alton Geoscience	---	2800	<500	---	---	<10	<10	<10	<10	<25	14000
GMW-36	11/18/99	Secor	---	51000	---	---	22000	8100	5600	<250	1770	<250	47000
GMW-36	5/17/00	Secor	---	59000	---	---	53000	14000	6700	480	4100	<130	45000
GMW-36	11/30/00	Secor	---	110000	---	---	66000	20000	19000	1600	8100	<0.5	13000
GMW-36	2/6/01	Secor	---	75000	---	---	55000	18000	13000	1400	6100	<50	9100
GMW-36	5/10/01	Secor	---	12000	---	---	5100	3700	2500	420	1730	<0.5	1600
GMW-36	9/19/01	Secor	---	21000	---	---	37000	5800	3600	580	2080	<13	1000
GMW-36	11/6/01	Secor	---	63000	---	---	40000	16000	13000	1600	7700	<25	3200
GMW-36	1/30/02	Secor	---	130000	---	---	68000	21000	20000	1700	9000	<125	42000
GMW-36	4/10/02	Secor	---	150000	---	---	49000	25000	22000	1800	10000	<50	67000
GMW-36	7/30/02	IT Corporation	---	81000	---	---	110000	28000	29000	2200	11800	<50	37000
GMW-36	12/6/06	Secor	---	32000	---	---	10000 **	5300	4300	480	4300	< 50	1600
GMW-36	3/13/07	Secor	---	54000	---	---	7200	9400	12000	1100	8200	< 200	3800
GMW-36	5/5/07	Secor	---	69000	---	---	11000	9800	11000	1200	8000	< 200	3900
GMW-36	8/29/07	Secor	---	30000	---	---	9800	4100	4200	420	4500	120	890
GMW-36	2/20/08	Secor	---	34000	---	---	9100	3900	6000	750	4600	< 50	43
GMW-36	4/16/08	Secor	---	42000	---	---	11000	5200	8300	940	6200	< 200	< 100
GMW-36	10/16/08	Secor	---	17000	---	---	32000	2100	2000	160	2300	< 20	26
GMW-36 DUP	10/16/08	Secor	---	17000	---	---	67000	2000	1900	160	2300	< 20	27
GMW-36	7/22/09	Blaine Tech	---	<b>24000</b>	---	---	<b>15000</b>	<b>3800</b>	<b>5400</b>	<b>720</b>	<b>3380</b>	< 50	<b>28</b>
GMW-37	11/25/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-37	7/11/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	<0.5	<5
GMW-37	1/6/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-37	5/26/98	Terra Services	---	<300	---	---	---	<0.3	<0.3	<0.5	0.6	<0.5	<0.5
GMW-37	11/11/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	11
GMW-37	5/7/99	Alton Geoscience	---	<500	<500	---	---	1.1	4.5	<0.5	1.9	<1	14
GMW-37	11/18/99	Secor	---	<416	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	16
GMW-37	5/17/00	Secor	---	<300	---	---	760	<0.5	<0.5	<0.5	<0.5	<0.5	16
GMW-37	11/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	34
GMW-37	2/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	54
GMW-37	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-37	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	11
GMW-37	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	49
GMW-37	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.3
GMW-37	4/10/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	7.2
GMW-37	10/22/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	49
GMW-37	1/29/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.75
GMW-37	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.86
GMW-37	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-37	10/6/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	4.3
GMW-37	1/27/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toulene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-37	4/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-37	7/19/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	2.6
GMW-37	11/2/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-37	2/2/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-37	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-37	11/1/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-37	2/27/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-37	5/2/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-37	9/18/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-37	12/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-37	5/4/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-37	11/14/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-37	4/16/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-37	10/14/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-37	4/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-37	10/19/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-38	11/26/96	Terra Services	---	---	---	---	---	1.8	<0.5	<0.5	<1.5	<0.5	7.7
GMW-38	7/10/97	Terra Services	---	<100	<500	---	---	<0.5	2	<0.5	0.83	<0.5	<5
GMW-38	1/5/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-38	5/21/98	Terra Services	---	<300	---	---	---	<0.3	<0.5	<0.5	<1	<0.5	1.2
GMW-38	11/12/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	25
GMW-38	5/7/99	Alton Geoscience	---	<500	<500	---	---	<0.5	1.5	<0.5	<0.5	<1	7.9
GMW-38	11/18/99	Secor	---	<416	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.7
GMW-38	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-38	11/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.8
GMW-38	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-38	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.6
GMW-38	2/1/02	Secor	---	---	---	---	---	<0.5	<0.5	<0.5	<0.5	<0.5	1.7
GMW-38	4/10/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-38	10/23/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-38	1/29/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-38	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.5
GMW-38	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-38	10/6/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-38	1/28/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-38	4/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.4
GMW-38	7/19/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-38	11/2/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-38	2/2/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-38	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.1
GMW-38	11/1/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-38	2/28/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.66
GMW-38	5/2/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-38	9/18/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-38	12/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-38	3/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-38	5/5/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-38	8/30/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-38	11/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-38	4/22/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>0.74</b>
GMW-38	7/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>0.55</b>
GMW-38	10/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-39	11/21/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-39	7/10/97	Terra Services	---	<100	<500	---	---	<0.5	0.5	<0.5	<1	<0.5	<5
GMW-39	1/5/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-39	5/19/98	Terra Services	---	---	---	---	---	<0.3	<0.5	<0.5	<1	<0.5	0.9
GMW-39	11/12/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	3.2
GMW-39	5/7/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	2.9
GMW-39	11/18/99	Secor	---	<416	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	12
GMW-39	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	9.4
GMW-39	11/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	16
GMW-39	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-39	11/6/01	Secor	---	<300	---	---	<100	1.2	<0.5	<0.5	<0.5	<0.5	39
GMW-39	2/1/02	Secor	---	---	---	---	---	<0.5	<0.5	<0.5	<0.5	<0.5	36
GMW-39	4/10/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	20
GMW-39	10/22/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	89
GMW-39	1/29/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	32
GMW-39	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	23
GMW-39	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	3.3
GMW-39	10/6/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	6.6
GMW-39	1/28/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	3.6
GMW-39	4/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	4.8
GMW-39	7/19/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	3.7
GMW-39	11/3/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	3.7
GMW-39	2/2/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.7
GMW-39	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-39	11/1/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-39	2/27/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.59
GMW-39	5/2/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-39	9/19/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	3.7
GMW-39	12/6/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	4
GMW-39 DUP	12/6/06	Secor	---	< 50	---	---	130	< 0.5	< 0.5	< 0.5	< 1	< 0.5	3.5
GMW-39	3/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	4.5
GMW-39	5/4/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	2.9
GMW-39 DUP	5/4/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	2.8
GMW-39	8/29/07	Secor	---	< 500	---	---	< 100	< 2.5	< 2.5	< 2.5	< 5	< 5	3.6
GMW-39	11/13/07	Secor	---	160	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	2.6
GMW-39 DUP	11/13/07	Secor	---	120	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	2.4
GMW-39	2/20/08	Secor	---	110	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	2.9
GMW-39	4/16/08	Secor	---	90	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	1.9
GMW-39 DUP	4/16/08	Secor	---	96	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	2
GMW-39	8/14/08	Secor	---	< 100	---	---	120	< 0.5	< 0.5	< 0.5	< 1	< 1	1.1
GMW-39	10/15/08	Secor	---	< 500	---	---	< 100	< 2.5	< 2.5	< 2.5	< 5	< 5	5.6
GMW-39	2/24/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-39	4/22/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-39 DUP	4/22/09	Blaine Tech	---	< 50	---	---	< 100	0.53	< 0.5	< 0.5	< 1	< 0.5	0.5
GMW-39	7/21/09	Blaine Tech	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	< 0.5
GMW-39 DUP	7/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-39	10/22/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.5
GMW-39 DUP	10/22/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-40	11/27/96	Terra Services	---	400	<500	<500	---	0.5	<0.5	5.8	5.9	<0.5	<5
GMW-40 DUP	11/27/96	GSI	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<0.5
GMW-40	7/10/97	Groundwater Technology Inc	---	210	2600	<300	---	---	---	---	---	---	---
GMW-40	1/7/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-40	5/21/98	BBC	---	<300	---	---	---	<0.3	<0.5	<0.5	<1	<0.5	<0.5
GMW-40	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	3.8	7.6	<0.5	<0.5
GMW-40	5/26/99	Groundwater Technology Inc	---	<300	---	---	<100	0.9	<0.5	<0.5	<0.5	<0.5	4.4
GMW-40	11/18/99	IT Corporation	---	<300	---	---	220	2.8	<0.5	0.9	2.8	<0.5	9.3
GMW-40	5/17/00	IT Corporation	---	<300	---	---	430	<0.5	<0.5	<0.5	<0.5	<0.5	11
GMW-40	12/1/00	IT Corporation	---	<300	---	---	320	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-40	5/10/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-40	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	1.1	3.1	<0.5	19
GMW-40	4/12/02	IT Corporation	---	<300	---	---	<100	1.7	<0.5	0.7	0.9	<0.5	17
GMW-40	4/16/03	Groundwater Technology Inc	---	---	---	---	<100	5.17	<0.5	2.74	4.65	<0.5	54.7
GMW-40	10/8/03	Parsons	---	---	---	---	170	<0.5	<0.5	<0.5	<0.5	<0.5	52
GMW-40	4/22/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	39
GMW-40	11/6/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
GMW-40	5/7/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	0.7	<0.5	0.76
GMW-40	11/8/05	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.76
GMW-40	5/5/06	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	4.9
GMW-40 DUP	5/5/06	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	5.4
GMW-40	12/8/06	Parsons	---	---	---	---	110	0.87	< 0.50	< 0.50	13.7	< 0.50	15
GMW-40	5/3/07	Parsons	---	---	---	---	440	3.7	< 0.50	2.2	27	< 0.50	46
GMW-40 DUP	5/3/07	Parsons	---	---	---	---	660	3.8	< 0.50	2.1	26.5	< 0.50	46
GMW-40	11/16/07	Parsons	---	---	---	---	< 100	0.61	< 0.50	1.9	8.4	< 0.50	< 0.50
GMW-40	4/18/08	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-40	10/17/08	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	1.2
GMW-40	4/24/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-40	10/21/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	0.4
GMW-41	11/27/96	GSI	---	250	<500	<500	---	<0.5	<0.5	<0.5	<1	<0.5	---
GMW-41	7/10/97	Groundwater Technology Inc	---	75	1200	<1000	---	<5	<5	<5	<5	<5	<5
GMW-41	1/7/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-41	5/21/98	BBC	---	<300	---	---	---	<0.3	<0.5	<0.5	<1	<0.5	<0.5
GMW-41	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1
GMW-41	5/26/99	Groundwater Technology Inc	---	<300	---	---	116	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-41	11/18/99	IT Corporation	---	<300	---	---	390	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-41	5/17/00	IT Corporation	---	<300	---	---	280	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-41	11/30/00	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-41	5/10/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-41	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-41	4/12/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.8
GMW-41	10/24/02	Groundwater Technology Inc	---	<300	---	---	1000	<0.5	<1	<1	<1	<0.5	1.1
GMW-41	4/16/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-41	10/8/03	Parsons	---	---	---	---	350	<0.5	<0.5	<0.5	<0.5	<0.5	2.4
GMW-41	4/22/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	3.3
GMW-41	11/6/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	3.6
GMW-41	5/7/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-41	11/8/05	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-41 DUP	11/8/05	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-41	5/5/06	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-41	12/8/06	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-41	5/3/07	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	0.51
GMW-41	11/16/07	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-41 DUP	11/16/07	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-41	4/18/08	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-41 DUP	4/18/08	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-41	10/17/08	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-41	4/22/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-41	10/21/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	0.43
GMW-42	11/5/98	Groundwater Technology Inc	---	7530	---	---	3340	800	<7.5	55	810	---	---
GMW-42	5/27/99	Groundwater Technology Inc	---	6510	---	---	14200	1100	110	60	580	---	---
GMW-42	11/18/99	IT Corporation	---	7900	---	---	17000	810	490	180	1200	---	---
GMW-42	5/17/00	IT Corporation	---	3800	---	---	20000	9.9	1.2	26	230	---	---
GMW-42	12/1/00	IT Corporation	---	380	---	---	2700	1	<0.3	<0.3	<0.6	---	18
GMW-42	5/10/01	IT Corporation	---	490	---	---	620	24	40	11	79	---	5.3
GMW-42	11/7/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	1.6	---	<5
GMW-42	4/10/02	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	7
GMW-43	11/27/96	GSI	---	620	<500	<500	---	<0.5	<0.5	<0.5	<1	---	---
GMW-43	7/10/97	Groundwater Technology Inc	---	<50	<50	<50	---	<0.5	<1	<1	<2	---	---
GMW-43	1/7/98	Groundwater Technology Inc	---	<500	<100	<100	---	0.3	<0.3	<0.3	<0.6	---	---
GMW-43	5/21/98	BBC	---	<300	---	---	---	<0.3	<0.3	<0.3	<0.6	---	---
GMW-43	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-43	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-43	11/18/99	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-43	5/17/00	IT Corporation	---	<300	---	---	170	0.92	<0.3	0.45	<0.6	---	---
GMW-43	11/30/00	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-43	5/9/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-43	11/7/01	IT Corporation	---	<300	---	---	150	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-43	4/11/02	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-43	10/23/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-43	4/14/03	Groundwater Technology Inc	---	---	---	---	<100	<1	<1	<1	<2	---	<3
GMW-43	10/8/03	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-43	4/21/04	Parsons	---	---	---	---	<100	<0.5	<1	<1	<1	---	<1
GMW-43	11/6/04	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-43	5/10/05	Parsons	---	---	---	---	<100	<0.3	0.68	<0.3	<0.3	---	<5
GMW-43	11/8/05	Parsons	---	---	---	---	200	< 0.3	0.47	< 0.3	0.31	---	< 5
GMW-43	5/4/06	Parsons	---	---	---	---	180	< 0.3	< 0.3	< 0.3	< 0.3	---	< 5
GMW-43	12/8/06	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-43	5/3/07	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1.0	---	8
GMW-43	11/15/07	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-43	4/17/08	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-43	10/16/08	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-43	4/23/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	---	< 0.50
GMW-43	10/21/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-44	11/27/96	GSI	---	820	<500	<500	---	<0.5	<0.5	<0.5	<1	---	---
GMW-44	7/10/97	Groundwater Technology Inc	---	68	1100	<1000	---	<0.5	<1	<1	<2	---	---
GMW-44	1/6/98	Groundwater Technology Inc	---	<500	700	<100	---	<0.3	<0.3	<0.3	<0.6	---	---
GMW-44	5/21/98	BBC	---	<300	---	---	---	<0.3	<0.3	<0.3	<0.6	---	---
GMW-44	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-44	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-44	11/18/99	IT Corporation	---	<300	---	---	310	<0.3	<0.3	<0.3	<0.6	---	---
GMW-44	5/17/00	IT Corporation	---	<300	---	---	240	<0.3	<0.3	<0.3	1.9	---	---
GMW-44	11/30/00	IT Corporation	---	<300	---	---	280	0.98	<0.3	0.95	<0.6	---	<5
GMW-44	5/9/01	IT Corporation	---	<300	---	---	190	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-44	11/7/01	IT Corporation	---	<300	---	---	270	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-44	4/11/02	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-44	10/23/02	Groundwater Technology Inc	---	<300	---	---	120	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-44	4/14/03	Groundwater Technology Inc	---	---	---	---	<100	<1	<1	<1	<2	---	<3
GMW-44	10/8/03	Parsons	---	---	---	---	230	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-44	4/21/04	Parsons	---	---	---	---	160	<0.5	<1	<1	<1	---	<1
GMW-44	11/4/04	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
GMW-44	5/6/05	Parsons	---	---	---	---	120	0.45	0.68	<0.3	<0.3	---	<5
GMW-44	11/8/05	Parsons	---	---	---	---	< 100	< 0.3	< 0.3	< 0.3	0.39	---	< 5
GMW-44	5/4/06	Parsons	---	---	---	---	< 100	< 0.3	< 0.3	< 0.3	< 0.3	---	< 5
GMW-44	12/8/06	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-44	5/4/07	Parsons	---	---	---	---	160	< 0.50	< 0.50	< 0.50	< 1.0	---	8.3
GMW-44	11/15/07	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-44	4/17/08	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
GMW-44	10/16/08	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-44	4/23/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	---	< 0.50
GMW-44	10/21/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-45	11/22/96	GSI	---	23000	<500	<500	---	1100	230	580	2900	<0.5	---
GMW-45	7/9/97	Groundwater Technology Inc	---	1100	2700	<2000	---	330	<5	280	930	---	---
GMW-45	1/6/98	Groundwater Technology Inc	---	3200	3400	4700	---	286	1.3	188	543	---	---
GMW-45	5/20/98	BBC	---	4200	---	---	---	270	221	109	569	---	---
GMW-45	11/5/98	Groundwater Technology Inc	---	1400	---	---	<100	81	<0.3	40	75	---	---
GMW-45	5/27/99	Groundwater Technology Inc	---	3750	---	---	3890	420	<0.6	180	390	---	---
GMW-45	11/18/99	IT Corporation	---	3960	---	---	3100	380	<3	140	100	---	---
GMW-45	5/17/00	IT Corporation	---	5200	---	---	5500	620	8	87	37	---	---
GMW-45	11/29/00	IT Corporation	---	2400	---	---	3100	330	1.3	6	4	---	<10
GMW-45	5/9/01	IT Corporation	---	6500	---	---	4100	620	74	51	420	---	<50

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toulene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-45	11/7/01	IT Corporation	---	5700	---	---	3000	730	<3	8.5	19	---	<50
GMW-45	4/10/02	IT Corporation	---	9800	---	---	6500	900	21	69	240	---	240
GMW-45	10/23/02	Groundwater Technology Inc	---	3200	---	---	1300	770	5.5	120	290	---	<5
GMW-45	4/10/03	Groundwater Technology Inc	---	---	---	---	1570	344	10.8	5.56	10.1	---	<6
GMW-45	10/8/03	Parsons	---	---	---	---	3400	470	<0.6	6.5	3.7	---	<10
GMW-45	4/21/04	Parsons	---	---	---	---	1400	140	<1	2.5	1.1	---	<1
GMW-45	11/4/04	Parsons	---	---	---	---	1500	84	<0.3	3	2.9	---	<5
GMW-45	5/5/05	Parsons	---	---	---	---	6900	670	17	520	720	---	<50
GMW-45	11/5/05	Parsons	---	---	---	---	2200	340	0.46	130	250	---	10
GMW-45	5/3/06	Parsons	---	---	---	---	2400	76	4.1	11	16	---	< 5
GMW-45 DUP	5/3/06	Parsons	---	---	---	---	2600	79	< 0.3	12	17	---	< 5
GMW-45	12/5/06	Parsons	---	---	---	---	1200	67	1.9	3.6	6.4	---	< 5.0
GMW-45	5/2/07	Parsons	---	---	---	---	1500	37	0.56	2	3	---	11
GMW-45	11/14/07	Parsons	---	---	---	---	590	42	< 0.5	< 0.5	< 1	---	9.6
GMW-45	4/16/08	Parsons	---	---	---	---	1500	21	0.52	1.4	2.9	---	< 5.0
GMW-45	10/15/08	Parsons	730	---	---	---	---	9.7	< 0.50	1.9	< 1	< 0.50	< 0.50
GMW-45	4/21/09	Parsons	1200	---	---	---	---	11	< 2.0	< 2.0	< 4	---	< 2.0
GMW-45	10/21/09	Parsons	1600	---	---	---	---	15	< 0.50	2.2	< 1	< 0.50	< 0.50
GMW-47	11/27/96	GSI	---	9600	<500	<500	---	1800	<25	160	660	---	---
GMW-47	7/9/97	Groundwater Technology Inc	---	420	93	<400	---	350	<1	170	79	---	---
GMW-47	1/6/98	Groundwater Technology Inc	---	1900	<100	1800	---	438	11	75	253	<2.5	<2.5
GMW-47	5/20/98	BBC	---	<300	---	---	---	1	<0.3	<0.3	<0.6	---	---
GMW-47	11/5/98	Groundwater Technology Inc	---	1700	---	---	<100	910	4.9	18	140	---	---
GMW-47	5/26/99	Groundwater Technology Inc	---	<300	---	---	<100	130	<0.3	0.33	3	---	---
GMW-47	11/18/99	IT Corporation	---	2100	---	---	1200	1100	0.77	5.8	27	---	---
GMW-47	5/17/00	IT Corporation	---	7200	---	---	8000	2300	700	200	1100	---	---
GMW-47	11/29/00	IT Corporation	---	990	---	---	1100	280	0.59	2.2	<0.6	---	<5
GMW-47	3/30/01	IT Corporation	---	---	---	---	<50	---	---	---	---	---	---
GMW-47	5/9/01	IT Corporation	---	7600	---	---	4100	1400	110	55	590	---	16
GMW-47	11/7/01	IT Corporation	---	1500	---	---	350	410	8.2	8.7	150	---	<50
GMW-47	4/10/02	IT Corporation	---	4100	---	---	1200	710	150	9.2	360	---	<25
GMW-47	10/23/02	Groundwater Technology Inc	---	4000	---	---	2900	430	<5	26	99.9	<2.5	<5
GMW-47	4/9/03	Groundwater Technology Inc	---	---	---	---	<100	1.37	<0.5	<0.5	<0.5	<1	<0.5
GMW-47	9/18/03	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-47	10/8/03	Parsons	---	140	---	---	380	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-47	2/21/04	Parsons	---	---	---	<100	---	4.2	<0.5	<0.5	---	---	<0.5
GMW-47	4/21/04	Parsons	---	160	---	---	640	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-47	7/21/04	Parsons	---	330	---	---	330	<0.5	<0.5	<0.5	---	---	<0.5
GMW-47	11/3/04	Parsons	---	<100	---	---	430	<0.5	<0.5	<0.5	---	<0.5	<0.5
GMW-47	3/2/05	Parsons	---	170	---	---	110	33	<1	5.8	5.4	---	<1
GMW-47 DUP	3/2/05	Parsons	---	140	---	---	<100	30	<1	4.5	4.8	---	<1
GMW-47	5/5/05	Parsons	---	420	---	---	530	22	<0.5	6	17.55	<0.5	<0.5
GMW-47	8/4/05	Parsons	---	< 100	---	---	110	3.4	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-47	11/5/05	Parsons	---	< 100	---	---	250	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-47	3/8/06	Parsons	---	< 100	---	---	160	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-47	5/3/06	Parsons	---	< 100	---	---	340	2.3	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-47 DUP	5/3/06	Parsons	---	< 100	---	---	300	3	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-47	7/28/06	Parsons	---	< 100	---	---	440	0.95	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-47	12/5/06	Parsons	---	< 100	---	---	200	5.4	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47	3/23/07	Parsons	---	< 100	---	---	420	11	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47	5/2/07	Parsons	---	< 100	---	---	320	4.8	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47	8/31/07	Parsons	---	< 100	---	---	400	1.8	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47	11/13/07	Parsons	---	< 100	---	---	180	0.83	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47 DUP	11/13/07	Parsons	---	< 100	---	---	130	1	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47	2/7/08	Parsons	---	< 100	---	---	290	1.7	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47	4/16/08	Parsons	---	< 100	---	---	270	1.6	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47 DUP	4/16/08	Parsons	---	< 100	---	---	290	1.6	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47	7/29/08	Parsons	---	< 100	---	---	450	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47	10/15/08	Parsons	300	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47	2/12/09	Parsons	460	170	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47	4/20/09	Parsons	730	180	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47	7/20/09	Parsons	1400	200	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-47	10/19/09	Parsons	1200	170	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-48	11/22/96	GSI	---	56000	<500	<500	---	10000	1800	1500	6900	0.8	---
GMW-56	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	16	<0.6	---	---
GMW-56	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-56	11/18/99	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-56	5/17/00	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
GMW-56	11/29/00	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-56	5/9/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-56	11/7/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
GMW-56	4/10/02	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	12
GMW-56	4/10/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-56	10/8/03	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-56	4/21/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-56	11/4/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
GMW-56	5/5/05	Parsons	---	---	---	---	120	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-56	11/5/05	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-56	5/3/06	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-56	12/8/06	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-56	5/2/07	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-56	11/14/07	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-56	4/16/08	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	0.94	< 0.50	< 0.50
GMW-56	10/15/08	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-56	4/21/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-56	10/21/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	12	0.63	4.5	0.97	---	---
GMW-57	5/26/99	Groundwater Technology Inc	---	379	---	---	<100	150	15	12	55	---	---
GMW-57	11/18/99	IT Corporation	---	4000	---	---	3600	950	240	150	750	---	---
GMW-57	5/17/00	IT Corporation	---	17000	---	---	<100	3200	2200	750	4300	---	---
GMW-57	11/29/00	IT Corporation	---	11000	---	---	7100	2300	21	340	1800	---	<100
GMW-57	3/30/01	IT Corporation	---	---	---	---	1800	---	---	---	---	---	---
GMW-57	5/9/01	IT Corporation	---	28000	---	---	12000	3300	3100	690	3600	---	<50
GMW-57	11/7/01	IT Corporation	---	19000	---	---	11000	3900	1600	390	3400	---	<500
GMW-57	4/10/02	IT Corporation	---	5000	---	---	5300	720	150	8.2	360	<2.5	<2.5
GMW-57	10/23/02	Groundwater Technology Inc	---	1700	---	---	2000	690	<0.3	3.2	5.7	---	<5
GMW-57	4/9/03	Groundwater Technology Inc	---	---	---	---	<100	<1	<1	<1	<2	---	<3
GMW-57	9/18/03	Parsons	---	---	---	---	170	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-57	10/11/03	Parsons	---	200	---	---	650	47	<0.5	0.57	<0.5	<0.5	<0.5
GMW-57	2/21/04	Parsons	---	---	---	470	---	190	<0.5	<0.5	---	---	<0.5
GMW-57	4/21/04	Parsons	---	110	---	---	710	21	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-57	7/21/04	Parsons	---	340	---	---	720	48	<0.5	<0.5	---	---	<0.5
GMW-57	11/3/04	Parsons	---	120	---	---	270	22	<0.5	<0.5	---	<0.5	<0.5
GMW-57	3/2/05	Parsons	---	400	---	---	170	190	<1	2.5	5.8	---	<1
GMW-57	5/5/05	Parsons	---	280	---	---	170	57	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-57 DUP	5/5/05	Parsons	---	230	---	---	160	61	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-57	8/4/05	Parsons	---	170	---	---	430	120	< 0.5	0.54	< 1	< 0.5	< 0.5
GMW-57	11/5/05	Parsons	---	120	---	---	100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-57	3/8/06	Parsons	---	180	---	---	180	4.8	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-57	5/3/06	Parsons	---	< 100	---	---	280	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-57	7/28/06	Parsons	---	180	---	---	1100	1.8	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-57	12/5/06	Parsons	---	< 100	---	---	290	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	3/23/07	Parsons	---	120	---	---	540	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	5/2/07	Parsons	---	120	---	---	720	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	8/31/07	Parsons	---	110	---	---	700	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	11/13/07	Parsons	---	160	---	---	450	0.72	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	2/7/08	Parsons	---	150	---	---	720	4	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	4/16/08	Parsons	---	< 100	---	---	540	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	7/29/08	Parsons	---	< 100	---	---	390	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	10/15/08	Parsons	210	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	2/12/09	Parsons	<b>140</b>	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	4/20/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	7/21/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-57	10/19/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-58	11/4/98	Groundwater Technology Inc	---	2590	---	---	1700	200	210	67	280	---	---
GMW-58	5/26/99	Groundwater Technology Inc	---	1360	---	---	451	310	62	42	170	---	---
GMW-58	11/18/99	IT Corporation	---	1600	---	---	1900	82	26	20	100	---	---
GMW-58	5/17/00	IT Corporation	---	21000	---	---	36000	3500	5900	730	3900	---	---
GMW-58	3/2/05	Parsons	---	5800	---	---	22000	1700	<20	250	400	---	<20
GMW-58	5/5/05	Parsons	---	12000	---	---	36000	410	<2.5	13	600	<2.5	<2.5
GMW-58	8/4/05	Parsons	---	5800	---	---	24000	500	< 2.5	56	124	< 2.5	< 2.5
GMW-58	11/5/05	Parsons	---	6300	---	---	9700	560	< 2.5	380	196	< 2.5	< 2.5
GMW-58	3/8/06	Parsons	---	5300	---	---	34000	250	< 2.5	140	21.1	< 2.5	< 2.5
GMW-58	5/3/06	Parsons	---	2900	---	---	16000	260	< 1	85	27.3	< 1	< 1
GMW-58	7/28/06	Parsons	---	3200	---	---	15000	310	< 1	78	22.7	< 1	< 1
GMW-58	3/23/07	Parsons	---	1700	---	---	4100	350	< 1.0	5.9	1.5	< 1.0	< 1.0
GMW-58	5/2/07	Parsons	---	2200	---	---	2500	320	< 1.0	9.5	2.4	< 1.0	< 1.0
GMW-58	8/31/07	Parsons	---	3000	---	---	2400	240	< 2.5	< 2.5	< 5	< 2.5	< 2.5
GMW-58	11/13/07	Parsons	---	2000	---	---	720	240	< 1.0	7.4	< 2	< 1.0	< 1.0
GMW-58	2/7/08	Parsons	---	1100	---	---	5000	270	< 1.0	1.8	6.4	< 1.0	< 1.0
GMW-58	4/16/08	Parsons	---	1100	---	---	720	310	< 2.5	< 2.5	< 5	8.4	< 2.5
GMW-58	7/29/08	Parsons	---	870	---	---	750	45	< 0.50	< 0.50	< 1	< 0.50	0.77
GMW-58	10/15/08	Parsons	840	1200	---	---	---	62	< 0.50	0.67	0.62	< 0.50	< 0.50
GMW-58 DUP	10/15/08	Parsons	3600	1700	---	---	---	59	< 0.50	0.65	0.57	< 0.50	1.3
GMW-58	2/12/09	Parsons	<b>2200</b>	<b>1000 J</b>	---	---	---	<b>36</b>	< 0.50	<b>0.85</b>	< 1	< 0.50	<b>0.55</b>
GMW-58	4/20/09	Parsons	<b>230</b>	<b>130 J</b>	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	<b>13</b>
GMW-58 DUP	4/20/09	Parsons	<b>250</b>	<b>220 J</b>	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	<b>13</b>
GMW-58	7/20/09	Parsons	<b>300</b>	<b>100</b>	---	---	---	<b>1.2</b>	< 0.50	< 0.50	< 1	< 0.50	<b>6.4</b>
GMW-58 DUP	7/20/09	Parsons	<b>290</b>	---	---	---	---	<b>1.2</b>	< 0.50	< 0.50	< 1	< 0.50	<b>6.1</b>
GMW-58	10/19/09	Parsons	<b>2200 J</b>	<b>1000</b>	---	---	---	<b>9.5</b>	< 0.50	<b>0.24</b>	< 1	< 0.50	<b>1.5</b>
GMW-58 DUP	10/19/09	Parsons	<b>16000 J</b>	<b>1100</b>	---	---	---	<b>11</b>	< 0.50	<b>0.3</b>	< 1	< 0.50	<b>1.5</b>
GMW-59	11/4/98	Groundwater Technology Inc	---	9880	---	---	12400	950	600	210	620	---	---
GMW-59	11/29/00	IT Corporation	---	67000	---	---	21000	3500	900	750	3600	---	<130
GMW-59	4/10/03	Groundwater Technology Inc	---	---	---	---	29600	261	4.8	18.4	110	---	<3



TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-59	10/8/03	Parsons	---	---	---	---	4900	760	<3	65	450	---	<50
GMW-59	4/21/04	Parsons	---	---	---	---	5000	590	<1	100	275.6	---	380
GMW-59	11/3/04	Parsons	---	---	---	---	4000	95	<0.6	15	18	---	<10
GMW-59	3/2/05	Parsons	---	4200	---	---	23000	400	<5	130	22	---	35
GMW-59	5/5/05	Parsons	---	11000	---	---	9400	170	<0.5	60	7.8	<0.5	11
GMW-59	8/4/05	Parsons	---	6400	---	---	17000	140	<1	56	6.6	<1	<1
GMW-59	11/5/05	Parsons	---	9500	---	---	26000	270	<0.5	26	2.2	<0.5	<0.5
GMW-59	3/8/06	Parsons	---	4600	---	---	13000	260	<1	7.4	<2	<1	<1
GMW-59 DUP	3/8/06	Parsons	---	7600	---	---	13000	230	<1	6.7	<2	<1	<1
GMW-59	5/3/06	Parsons	---	9900	---	---	9300	210	<1	4	<2	<1	<1
GMW-59	7/28/06	Parsons	---	3200	---	---	37000	540	<1	3.1	<2	<1	4.8
GMW-59	12/5/06	Parsons	---	---	---	---	9000	800	4.3	5.2	11	---	<10
GMW-59	3/23/07	Parsons	---	8200	---	---	15000	840	<2.5	<2.5	<5	<2.5	<2.5
GMW-59	5/2/07	Parsons	---	4800	---	---	7400	1100	<2.5	<2.5	<5	<2.5	<2.5
GMW-59	8/31/07	Parsons	---	4800	---	---	3500	720	<2.5	<2.5	<5	<2.5	<2.5
GMW-59	11/13/07	Parsons	---	4700	---	---	2200	660	<5.0	<5.0	<10	<5.0	<5.0
GMW-59	2/7/08	Parsons	---	3200	---	---	3900	490	<2.5	3.8	<5	<2.5	2.7
GMW-59	4/16/08	Parsons	---	3600	---	---	2100	580	<2.5	3.5	<5	15	3.7
GMW-59	7/29/08	Parsons	---	2300	---	---	2900	580	<2.5	<2.5	<5	<2.5	3.3
GMW-59	10/15/08	Parsons	2400	2500	---	---	---	830	<2.5	<2.5	<5	<2.5	5.5
GMW-59 DUP	10/15/08	Parsons	14000	2200	---	---	---	770	<2.5	<2.5	<5	<2.5	4
GMW-59	2/12/09	Parsons	2600	2500 J	---	---	---	650	<2.5	<2.5	<5	<2.5	3.2
GMW-59	4/20/09	Parsons	19000 J	8500 J	---	---	---	610	<2.5	<2.5	<5	<2.5	2.7
GMW-59 DUP	4/20/09	Parsons	12000 J	7300 J	---	---	---	610	<2.5	<2.5	<5	<2.5	3
GMW-59	7/20/09	Parsons	11000	6700 J	---	---	---	520	<2.5	<2.5	<5	<2.5	3.5
GMW-59 DUP	7/20/09	Parsons	9100	---	---	---	---	520	<2.5	<2.5	<5	<2.5	3.4
GMW-59	10/21/09	Parsons	3000 J	2600 J	---	---	---	1700	<2.5	1.4	<5	<2.5	16
GMW-59 DUP	10/21/09	Parsons	4200 J	3400 J	---	---	---	1600	<2.5	1.3	<5	<2.5	16
GMW-60	7/21/04	Parsons	---	15000	---	---	5300	1700	160	710	---	---	<0.5
GMW-60	11/3/04	Parsons	---	12000	---	---	3500	1700	70	900	---	<5	<5
GMW-60	3/2/05	Parsons	---	8300	---	---	4900	1300	<20	860	2040	---	<20
GMW-60	5/5/05	Parsons	---	9400	---	---	4600	1100	<5	790	1740	<5	<5
GMW-60	8/4/05	Parsons	---	6200	---	---	5600	1000	<5	680	1070	<5	<5
GMW-60	11/5/05	Parsons	---	7200	---	---	4400	970	<5	710	1130	<5	<5
GMW-60	3/8/06	Parsons	---	5900	---	---	5200	680	<5	640	800	<5	<5
GMW-60	5/3/06	Parsons	---	3900	---	---	2200	770	<5	230	235	<5	<5
GMW-60	7/28/06	Parsons	---	4600	---	---	4900	850	<5	170	102	<5	<5
GMW-60	12/5/06	Parsons	---	4100	---	---	920	660	<5.0	130	92	<5.0	<5.0
GMW-60	3/23/07	Parsons	---	3500	---	---	1700	490	<2.5	87	80	<2.5	<2.5
GMW-60	5/2/07	Parsons	---	2800	---	---	630	300	<2.5	18	23	<2.5	<2.5
GMW-60	8/31/07	Parsons	---	2000	---	---	660	250	<2.5	18	5.9	<2.5	<2.5
GMW-60	11/13/07	Parsons	---	1500	---	---	<100	180	<0.50	21	4.3	<0.50	<0.50
GMW-60	2/7/08	Parsons	---	1700	---	---	290	270	0.8	65	47.9	<0.50	<0.50
GMW-60	4/16/08	Parsons	---	1400	---	---	920	160	<1.0	24	2.6	<1.0	<1.0
GMW-60	7/29/08	Parsons	---	2000	---	---	610	240	<1.0	3.9	<2	<1.0	<1.0
GMW-60	10/15/08	Parsons	270	1400	---	---	---	220	<1.0	2.7	<2	<1.0	<1.0
GMW-60	2/12/09	Parsons	490	1600 J	---	---	---	200	<1.0	2.5	<2	<1.0	<1.0
GMW-60	4/20/09	Parsons	1100	3500 J	---	---	---	800	<5.0	7.9	<10	<5.0	<5.0
GMW-60	7/20/09	Parsons	1700	3200 J	---	---	---	940	<5.0	11	<10	<5.0	<5.0
GMW-60	10/19/09	Parsons	930	2600 J	---	---	---	800	<5.0	8.8	<10	<5.0	<5.0
GMW-61	7/21/04	Parsons	---	19000	---	---	14000	2400	1700	1000	---	---	<0.5
GMW-61	11/3/04	Parsons	---	23000	---	---	5700	2500	2200	1200	---	<5	<5
GMW-61	3/2/05	Parsons	---	20000	---	---	10000	2700	1900	1100	5900	---	<20
GMW-61	5/5/05	Parsons	---	11000	---	---	7000	2000	310	840	2500	<10	<10
GMW-61	8/4/05	Parsons	---	11000	---	---	12000	1900	740	740	3500	<10	<10
GMW-61 DUP	8/4/05	Parsons	---	11000	---	---	12000	1800	700	710	3400	<10	<10
GMW-61	11/5/05	Parsons	---	16000	---	---	10000	2600	480	1100	4900	<10	<10
GMW-61	3/8/06	Parsons	---	11000	---	---	7900	2100	280	1000	2700	<10	<10
GMW-61	5/3/06	Parsons	---	9600	---	---	7300	1900	89	810	2030	<10	<10
GMW-61	7/28/06	Parsons	---	7200	---	---	9900	1400	20	460	1290	<10	<10
GMW-61 DUP	7/28/06	Parsons	---	6700	---	---	8100	1300	19	470	1330	<10	<10
GMW-61	12/5/06	Parsons	---	7900	---	---	4000	1500	19	330	2050	<5.0	<5.0
GMW-61	3/23/07	Parsons	---	7500	---	---	3100	1200	16	220	1340	<5.0	<5.0
GMW-61	5/2/07	Parsons	---	11000	---	---	3000	1600	27	290	2090	<5.0	<5.0
GMW-61	8/31/07	Parsons	---	9200	---	---	1600	1500	17	190	1170	<0.50	<0.50
GMW-61	11/13/07	Parsons	---	2300	---	---	<100	580	6.3	99	360	<5.0	<5.0
GMW-61	2/7/08	Parsons	---	2600	---	---	890	330	8.6	70	363	<2.5	<2.5
GMW-61	4/16/08	Parsons	---	2000	---	---	1100	480	5	64	399	<2.5	<2.5
GMW-61	7/29/08	Parsons	---	1500	---	---	790	400	<2.5	28	129.3	<2.5	<2.5
GMW-61	10/15/08	Parsons	500	1300	---	---	---	450	<2.5	34	149.5	<2.5	<2.5
GMW-61	2/12/09	Parsons	<100	1100 J	---	---	---	340	<2.5	13	57	<2.5	<2.5
GMW-61	4/20/09	Parsons	550	1100 J	---	---	---	490	<2.5	<2.5	<5	<2.5	<2.5
GMW-61	7/20/09	Parsons	560	760 J	---	---	---	350	<2.5	<2.5	<5	<2.5	<2.5
GMW-61	10/19/09	Parsons	410	620 J	---	---	---	320	<2.5	1.2	<5	<2.5	<2.5
GMW-62	7/17/07	Parsons	---	11000	---	---	2500	1400	1200	360	1720	<0.5	<0.5
GMW-62	8/31/07	Parsons	---	3400	---	---	1100	400	96	45	188	<0.50	<0.50
GMW-62 DUP	8/31/07	Parsons	---	3200	---	---	1300	380	89	41	164	<0.50	<0.50

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-62	11/14/07	Parsons	---	4200	---	---	< 100	1400	85	160	92	< 5	< 5
GMW-62 DUP	11/14/07	Parsons	---	3800	---	---	< 100	1300	84	150	92	< 5	< 5
GMW-62	2/7/08	Parsons	---	4100	---	---	1400	2100	190	450	610	< 5.0	< 5.0
GMW-62	4/17/08	Parsons	---	1000	---	---	500	430	15	50	23.9	< 5.0	< 5.0
GMW-62 DUP	4/17/08	Parsons	---	1000	---	---	360	400	13	48	23.3	< 5.0	< 5.0
GMW-62	7/29/08	Parsons	---	2400	---	---	1000	1300	33	160	109	< 2.5	< 2.5
GMW-62	10/15/08	Parsons	180	2800	---	---	---	1700	19	220	161	< 5.0	< 5.0
GMW-62	2/12/09	Parsons	1600	3600 J	---	---	---	1800	5.1	150	164	< 5.0	< 5.0
GMW-62	4/23/09	Parsons	150	1500	---	---	---	370	< 2.5	25	5.2	< 2.5	< 2.5
GMW-62	7/21/09	Parsons	1100	1800	---	---	---	1200	< 2.5	67	36	< 2.5	< 2.5
GMW-62	10/21/09	Parsons	480	2200 J	---	---	---	1700	< 2.5	43	12.9	< 2.5	< 2.5
GMW-63	10/15/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-63	2/12/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-63	4/23/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-63 DUP	4/23/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-63	7/21/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-63	10/22/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-63 DUP	10/22/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-64	10/15/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-64	2/12/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-64	4/23/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-64	7/21/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-64	10/21/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-65	7/21/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-65	10/22/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-66	10/22/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GMW-O-1	11/21/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	0.53	<5
GMW-O-1	7/9/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	0.85	<5
GMW-O-1	1/6/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-O-1	5/20/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-1	8/24/98	Geomatix	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	11/4/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	2/2/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<1	<1	<0.5
GMW-O-1	8/10/99	Alton Geoscience	---	<500	<1000	---	---	<0.5	<1	<1	<1	<0.5	<1
GMW-O-1	11/17/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	2/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	8/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.5	<0.5
GMW-O-1	11/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	2/5/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	11/6/01	Secor	---	<300	---	---	<100	11	<0.5	0.7	0.6	0.5	<0.5
GMW-O-1	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	7/30/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	10/24/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	1/28/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	4/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	10/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	1/29/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	4/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	7/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	11/4/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	2/3/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-1	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.1	<0.5
GMW-O-1	11/1/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	2/28/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	9/20/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	12/8/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	3/12/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	5/4/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1 DUP	5/4/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	8/28/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	11/14/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	2/20/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	8/13/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	10/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	2/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	7/20/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-1	10/20/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	11/21/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	12	<5
GMW-O-2	7/9/97	Terra Services	---	<100	<500	---	---	<0.5	0.5	<0.5	<1	<0.5	<5

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-O-2	1/7/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	13	<5
GMW-O-2	5/20/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	14	<0.5
GMW-O-2	11/11/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-2	5/5/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
GMW-O-2	11/16/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-2	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.7	<0.5
GMW-O-2	11/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.6	<0.5
GMW-O-2	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	11	<0.5
GMW-O-2	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.6	<0.5
GMW-O-2	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-2	7/30/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-2	10/24/02	Secor	---	<300	---	---	460	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-2	1/15/03	Geomatrix	---	<300	---	---	<100	---	---	---	---	---	---
GMW-O-2	1/28/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	4.1	<0.5
GMW-O-2	4/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	1	<0.5
GMW-O-2	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-2	10/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-2	1/29/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-2	4/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-2	7/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-2	11/4/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-2	2/3/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-2	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	5	<0.5
GMW-O-2	11/1/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	2/28/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	9/20/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	12/8/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	3/12/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	5/3/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	8/28/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	11/14/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	2/20/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	8/13/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	10/16/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	2/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	4/22/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	7/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-2	10/20/09	Blaine Tech	---	< 50	---	---	130	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-3	11/27/96	Terra Services	---	---	---	---	---	2900	1000	1200	1950	<10	260
GMW-O-3	7/14/97	Terra Services	---	14000	1300	---	---	1500	410	700	1200	<10	<100
GMW-O-3	1/9/98	Terra Services	---	3200	720	---	---	930	55	390	599	38	<50
GMW-O-3	5/26/98	Terra Services	---	5400	---	---	---	850	20	170	140	<5	<5
GMW-O-3	8/26/98	Geomatrix	---	3290	---	---	1710	329	31	140	300	<2.5	<2.5
GMW-O-3	11/17/98	Alton Geoscience	---	4800	---	---	5810	1500	<100	350	400	<100	<100
GMW-O-3	2/3/99	Alton Geoscience	---	3800	<500	---	---	250	<2.5	34	17	<5	<2.5
GMW-O-3	5/7/99	Alton Geoscience	---	2900	<500	---	---	170	1.2	3.4	5.3	<1	<0.5
GMW-O-3	8/10/99	Alton Geoscience	---	<500	<1000	---	---	56	1.6	2.3	2.4	1.2	<1
GMW-O-3	11/17/99	Secor	---	340	---	---	<100	15	0.5	1.9	1.9	<0.5	<0.5
GMW-O-3	2/29/00	Secor	---	<300	---	---	170	12	<0.5	1.2	1.1	<0.5	<0.5
GMW-O-3	5/17/00	Secor	---	1800	---	---	1000	290	32	33	180	<0.5	<0.5
GMW-O-3	8/29/00	Secor	---	580	---	---	3600	130	2.5	13	23	<0.5	<0.5
GMW-O-3	11/28/00	Secor	---	1500	---	---	820	350	13	43	93.1	<0.5	<0.5
GMW-O-3	2/5/01	Secor	---	1800	---	---	770	420	26	40	55	<10	<10
GMW-O-3	5/10/01	Secor	---	2000	---	---	560	380	4.5	32	42	<2.5	<2.5
GMW-O-3	9/19/01	Secor	---	840	---	---	360	230	<2.5	17	11	<2.5	<2.5
GMW-O-3	11/7/01	IT Corporation	---	520	---	---	<100	120	<2.5	7.2	6	<2.5	<2.5
GMW-O-3	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-3	4/9/02	Secor	---	1200	---	---	<100	260	2.6	13	9.8	<0.5	<0.5
GMW-O-3	7/30/02	IT Corporation	---	380	---	---	250	150	1.6	5.1	4.6	<0.5	<0.5
GMW-O-3	10/24/02	Secor	---	310	---	---	120	79	0.65	1.9	1.2	<0.5	<0.5
GMW-O-3	1/15/03	Geomatrix	---	<300	---	---	<100	---	---	---	---	---	---
GMW-O-3	1/28/03	Secor	---	550	---	---	160	140	3	9.1	14.2	<0.5	<0.5
GMW-O-3	4/8/03	Secor	---	660	---	---	200	170	1.6	9.2	3.1	<2	<1
GMW-O-3	7/30/03	Secor	---	830	---	---	140	200	2	18	8.2	<3	<1.5
GMW-O-3	10/8/03	Secor	---	660	---	---	280	96	0.74	9.6	1.4	<1	<0.5
GMW-O-3	1/29/04	Secor	---	850	---	---	160	120	0.63	3	0.72	<1	<0.5
GMW-O-3	4/20/04	Secor	---	<50	---	---	130	65	<0.5	<0.5	0.56	<0.5	<0.5
GMW-O-3	7/20/04	Secor	---	370	---	---	<100	29	<0.5	1.4	<0.5	<0.5	<0.5
GMW-O-3	11/4/04	Secor	---	850	---	---	190	71	<0.5	2.7	<0.5	<1	<0.5
GMW-O-3	2/3/05	Secor	---	210	---	---	<100	16	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-3	5/4/05	Secor	---	380	---	---	<100	32	0.67	2.1	4.6	<0.5	<0.5
GMW-O-3	11/1/05	Secor	---	1300	---	---	560	35	2.3	67	50	< 1	< 0.5
GMW-O-3	2/28/06	Secor	---	640	---	---	320	26	< 0.5	7.1	6	< 0.5	< 0.5
GMW-O-3	5/4/06	Secor	---	400	---	---	250	19	< 0.5	0.71	1.2	< 0.5	< 0.5
GMW-O-3	9/19/06	Secor	---	110	---	---	< 100	0.71	< 0.5	< 0.5	< 1	< 0.5	< 0.5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-O-3	12/8/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-3	3/13/07	Secor	---	51	---	---	< 100	< 0.5	< 0.5	1.1	< 1	< 0.5	< 0.5
GMW-O-3	5/3/07	Secor	---	72	---	---	< 100	< 0.5	< 0.5	0.64	< 1	< 0.5	< 0.5
GMW-O-3	8/28/07	Secor	---	65	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-3	11/14/07	Secor	---	170	---	---	< 100	3.1	< 0.5	9.7	< 1	< 0.5	< 0.5
GMW-O-3	2/20/08	Secor	---	96	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-3	4/15/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-3	8/14/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-3	10/16/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-3	2/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-3	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-3	7/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-3	10/20/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4	11/22/96	Terra Services	---	---	---	---	---	< 0.5	< 0.5	< 0.5	< 1.5	< 0.5	< 5
GMW-O-4	7/9/97	Terra Services	---	< 100	< 500	---	---	< 0.5	1.9	< 0.5	< 1	< 0.5	< 5
GMW-O-4	1/2/98	Terra Services	---	< 100	< 500	---	---	< 0.5	< 0.5	< 0.5	< 1.5	< 0.5	< 5
GMW-O-4	5/21/98	Terra Services	---	---	---	---	---	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.7
GMW-O-4	11/12/98	Alton Geoscience	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	5/6/99	Alton Geoscience	---	< 500	< 500	---	---	< 0.5	< 0.5	< 0.5	< 0.5	< 1	< 0.5
GMW-O-4	11/16/99	Secor	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	11/17/99	Secor	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	5/17/00	Secor	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	11/29/00	Secor	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	5/10/01	Secor	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	11/7/01	IT Corporation	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	4/9/02	Secor	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	10/24/02	Secor	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	4/9/03	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	10/8/03	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	4/20/04	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	11/4/04	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	5/4/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4	11/1/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4	5/4/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4	12/7/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4	5/3/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4	11/15/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4	4/15/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4	10/15/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4	10/20/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4 (MID)	11/22/96	Terra Services	---	---	---	---	---	< 0.5	< 0.5	< 0.5	< 1.5	< 0.5	< 5
GMW-O-4 (MID)	7/9/97	Terra Services	---	< 100	< 500	---	---	< 0.5	0.99	< 0.5	< 0.1	< 0.5	< 5
GMW-O-4 (MID)	1/2/98	Terra Services	---	< 100	< 500	---	---	< 0.5	< 0.5	< 0.5	< 1.5	< 0.5	< 5
GMW-O-4 (MID)	5/21/98	Terra Services	---	< 300	---	---	---	---	---	---	---	---	---
GMW-O-4 (MID)	11/4/98	Alton Geoscience	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4 (MID)	5/6/99	Alton Geoscience	---	< 500	< 500	---	---	---	---	---	---	< 1	---
GMW-O-4 (MID)	5/6/99	Alton Geoscience	---	---	---	---	---	---	---	---	---	---	< 0.5
GMW-O-4 (MID)	5/17/00	Secor	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4 (MID)	11/28/00	Secor	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4 (MID)	5/10/01	Secor	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4 (MID)	11/7/01	IT Corporation	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4 (MID)	4/9/02	Secor	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4 (MID)	10/24/02	Secor	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4 (MID)	4/9/03	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4 (MID)	10/8/03	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4 (MID)	4/20/04	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4 (MID)	11/4/04	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4 (MID)	5/4/05	Secor	---	< 50	---	---	220	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-4 MID	11/1/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4 MID	5/4/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4 MID	12/7/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4 MID	5/3/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4 MID	11/15/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4 MID	4/15/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4 MID	10/15/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4 MID	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-4 MID	10/20/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-5	11/22/96	Terra Services	---	---	---	---	---	11	5.7	9.2	32.1	< 0.5	< 5
GMW-O-5	7/9/97	Terra Services	---	< 100	< 500	---	---	< 0.5	1.9	< 0.5	< 1	< 0.5	< 5
GMW-O-5	1/7/98	Terra Services	---	< 100	< 500	---	---	< 0.5	< 0.5	< 0.5	< 1.5	< 0.5	15
GMW-O-5	5/21/98	Terra Services	---	---	---	---	---	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-5	8/24/98	Geomatrix	---	< 300	---	---	< 100	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-5	11/4/98	Alton Geoscience	---	---	---	---	< 100	---	---	---	---	---	---
GMW-O-5	11/4/98	Alton Geoscience	---	< 300	---	---	---	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5
GMW-O-5	2/3/99	Alton Geoscience	---	< 500	< 500	---	---	< 0.5	< 0.5	< 0.5	< 1	< 1	< 0.5
GMW-O-5	5/5/99	Alton Geoscience	---	< 500	< 500	---	---	< 0.5	< 0.5	< 0.5	< 0.5	< 1	< 0.5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-O-5	8/10/99	Alton Geoscience	---	<500	<1000	---	---	2.3	4.4	<1	2.9	<0.5	<1
GMW-O-5	11/16/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	2/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	8/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	11/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	2/5/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	10/24/02	Secor	---	<300	---	---	2300	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	1/15/03	Geomatrix	---	<300	---	---	<100	---	---	---	---	---	---
GMW-O-5	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	10/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	4/21/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	11/4/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-5	11/1/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-5	5/5/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-5	12/7/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-5	5/3/07	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-5	11/15/07	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-5	4/18/08	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-5	10/15/08	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-5	4/21/09	Blaine Tech	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-5	10/20/09	Blaine Tech	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-6	11/22/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-O-6	7/9/97	Terra Services	---	<100	<500	---	---	<0.5	0.9	<0.5	<1	<0.5	<5
GMW-O-6	1/2/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	<0.5	<5
GMW-O-6	5/21/98	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-6	11/4/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-6	5/5/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
GMW-O-6	11/17/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-6	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-6	11/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.9
GMW-O-6	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-6	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-6	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-6	10/24/02	Secor	---	<300	---	---	190	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-6	10/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-6	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-6	5/5/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-6	5/4/07	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-6	4/18/08	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-6	4/21/09	Blaine Tech	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-7	5/7/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
GMW-O-8	10/24/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.5	2.4
GMW-O-8	1/16/03	Geomatrix	---	---	---	---	---	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-8	4/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-8	10/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-8	4/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-8	11/4/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-8	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-8	11/1/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-8	5/4/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-8	12/8/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-8	5/4/07	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-8	11/14/07	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-8	4/18/08	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-8	10/16/08	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-8	4/22/09	Blaine Tech	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-8	10/21/09	Blaine Tech	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-9	11/22/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	46	<5
GMW-O-9	7/10/97	Terra Services	---	<100	<500	---	---	<0.5	3.6	<0.5	<1	<0.5	<5
GMW-O-9	1/7/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-O-9	5/21/98	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<0.6	12	<0.5
GMW-O-9	11/16/98	Alton Geoscience	---	<300	---	---	<100	3	7	1	6	5.8	<0.5
GMW-O-9	5/5/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
GMW-O-9	11/17/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	17	<0.5
GMW-O-9	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	72	<0.5
GMW-O-9	11/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	53	<0.5
GMW-O-9	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	87	<0.5
GMW-O-9	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	53	<0.5
GMW-O-9	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-9	10/24/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	35	<0.5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-O-9	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	50	<0.5
GMW-O-9	10/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	35	<0.5
GMW-O-9	4/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	15	<0.5
GMW-O-9	11/4/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	9.9	<0.5
GMW-O-9	5/6/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	61	<0.5
GMW-O-9	11/2/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-9	5/5/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	1.8	<0.5
GMW-O-9	12/7/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	2.5	<0.5
GMW-O-9	5/4/07	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-9	11/14/07	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	5.9	<0.5
GMW-O-9	4/18/08	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-9	10/17/08	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-9	4/22/09	Blaine Tech	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-9	10/20/09	Blaine Tech	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-10	11/26/96	Terra Services	---	---	---	---	---	450	18	37	21.8	81	1300
GMW-O-10	7/14/97	Terra Services	---	17000	900	---	---	4200	2800	650	1600	<30	890
GMW-O-10	1/9/98	Terra Services	---	25000	12000	---	---	3900	2800	510	1470	<10	1200
GMW-O-10	5/27/98	Terra Services	---	<300	---	---	---	1	<0.5	<0.5	0.8	<0.5	1
GMW-O-10	11/16/98	Alton Geoscience	---	6840	---	---	297	2900	540	320	310	<13	2000
GMW-O-10	5/7/99	Alton Geoscience	---	<500	<500	---	---	6.2	<0.5	0.61	<0.5	<1	0.64
GMW-O-10	11/16/99	Secor	---	32000	---	---	27000	8300	5700	860	2640	<25	2600
GMW-O-10	5/17/00	Secor	---	18000	---	---	32000	4500	3300	450	1420	<25	1300
GMW-O-10	11/29/00	Secor	---	18000	---	---	10000	4200	2900	430	1260	<25	1400
GMW-O-10	5/10/01	Secor	---	7900	---	---	4600	2400	810	150	280	<10	950
GMW-O-10	11/7/01	IT Corporation	---	8100	---	---	1300	1200	120	<10	540	<10	1100
GMW-O-10	4/11/02	Secor	---	960	---	---	1000	190	18	5.1	157	10	610
GMW-O-10	10/24/02	Secor	---	2000	---	---	2500	270	27	<5	60	<5	290
GMW-O-10	4/10/03	Secor	---	13000	---	---	1900	3600	370	460	780	<50	520
GMW-O-10	8/1/03	Secor	---	5800	---	---	1600	2600	220	320	460	20	580
GMW-O-10	10/8/03	Secor	---	4900	---	---	940	1500	240	160	275	24	460
GMW-O-10	4/21/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-10	11/4/04	Secor	---	8900	---	---	1200	3900	85	400	409	<30	590
GMW-O-10	5/6/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-10	11/2/05	Secor	---	52	---	---	<100	19	0.5	<0.5	<1	1	10
GMW-O-10	5/5/06	Secor	---	12000	---	---	850	4100	1800	380	640	<50	160
GMW-O-10	12/7/06	Secor	---	8900	---	---	810	4000	470	320	310	<50	190
GMW-O-10	5/4/07	Secor	---	3800	---	---	260	1600	10	<10	120	<20	160
GMW-O-10	11/14/07	Secor	---	12000	---	---	600	5100	54	340	325	<50	190
GMW-O-10	4/18/08	Secor	---	1300	---	---	130	680	<5	14	11	<10	23
GMW-O-10	8/14/08	Secor	---	1600	---	---	160	820	5.3	31	42	<10	<5
GMW-O-10	10/21/08	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	0.58
GMW-O-10	4/22/09	Blaine Tech	---	<b>180</b>	---	---	<100	<b>37</b>	<0.5	<0.5	<1	<0.5	<b>1.2</b>
GMW-O-10	10/22/09	Blaine Tech	---	<b>99</b>	---	---	<100	<b>6.9</b>	<0.5	<0.5	<1	<0.5	<b>0.77</b>
GMW-O-14	11/27/96	Terra Services	---	88000	74000	---	---	4500	3200	520	2600	440	<300
GMW-O-14	7/17/97	Terra Services	---	160000	610000	---	---	7600	4900	2200	43000	<500	<5000
GMW-O-14	1/9/98	Terra Services	---	33000	780000	---	---	7200	4500	510	2300	<30	<300
GMW-O-14	5/27/98	Terra Services	---	3500	---	---	---	330	<2.5	80	88	<2.5	<0.5
GMW-O-14	11/17/98	Alton Geoscience	---	3850	---	---	---	5000	3840	1040	4510	<100	<100
GMW-O-14	11/17/98	Alton Geoscience	---	---	---	---	117000	---	---	---	---	---	---
GMW-O-14	5/7/99	Alton Geoscience	---	23000	54000	---	---	5100	3400	650	2800	<50	<20
GMW-O-14	11/18/99	Secor	---	26000	---	---	23000	5900	4100	780	2500	<50	<50
GMW-O-14	5/17/00	Secor	---	10000	---	---	9300	2300	630	370	820	<50	<100
GMW-O-14	11/29/00	Secor	---	42000	---	---	59000	8800	5000	1200	4400	<50	<50
GMW-O-14	5/10/01	Secor	---	5200	---	---	17000	100	34	96	237	<1	<1
GMW-O-14	11/7/01	IT Corporation	---	15000	---	---	20000	3900	890	640	1280	<1	<2
GMW-O-14	4/9/02	Secor	---	38000	---	---	13000	7400	2700	990	3200	<13	24
GMW-O-14	7/30/02	IT Corporation	---	11000	---	---	24000	4900	2300	550	1890	<13	14
GMW-O-14	10/24/02	Secor	---	26000	---	---	29000	7100	3500	970	3500	<25	<25
GMW-O-14	1/28/03	Secor	---	39000	---	---	47000	12000	8400	1500	5600	<25	38
GMW-O-14	3/12/03	Geomatrix	---	1500	---	---	710	760	72	66	115	<2.5	14
GMW-O-14	4/9/03	Secor	---	33000	---	---	27000	5100	2900	990	3300	<40	<20
GMW-O-14	7/30/03	Secor	---	20000	---	---	12000	3100	1900	790	3200	74	<15
GMW-O-14	10/9/03	Secor	---	43000	---	---	18000	8700	4200	1300	5300	180	<50
GMW-O-14	1/29/04	Secor	---	55000	---	---	19000	13000	6900	1400	5600	240	<50
GMW-O-14	4/20/04	Secor	---	54000	---	---	32000	11000	5700	1500	6100	170	<50
GMW-O-14	7/20/04	Secor	---	72000	---	---	18000	13000	8200	1700	7400	200	<50
GMW-O-14	11/4/04	Secor	---	41000	---	---	23000	9000	7000	1300	5500	<200	<100
GMW-O-14	2/3/05	Secor	---	34000	---	---	4600	8600	2300	950	3100	69	34
GMW-O-14	5/4/05	Secor	---	420	---	---	680	11	1.6	18	18.8	6.5	<0.5
GMW-O-14	11/2/05	Secor	---	14000	---	---	14000	320	350	160	2690	<40	<20
GMW-O-14	2/28/06	Secor	---	8200	---	---	12000 **	860	87	18	1020	15	<5
GMW-O-14	5/5/06	Secor	---	6700	---	---	9600 **	1500	77	<10	450	35	<10
GMW-O-14	9/20/06	Secor	---	6900	---	---	4200 **	1400	250	39	640	30	<10
GMW-O-14	12/7/06	Secor	---	9000	---	---	17000 **	1400	150	27	501	36	<10
GMW-O-14 DUP	12/7/06	Secor	---	9400	---	---	13000 **	1500	160	27	531	35	<10
GMW-O-14	3/12/07	Secor	---	4700	---	---	1300	1000	180	26	400	23	<5
GMW-O-14 DUP	3/12/07	Secor	---	4400	---	---	4800	1000	170	24	375	23	<5

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-O-14	5/4/07	Secor	---	8200	---	---	3300	1700	330	48	570	44	< 10
GMW-O-14 DUP	5/4/07	Secor	---	8400	---	---	4300	1800	340	50	580	46	10
GMW-O-14	8/28/07	Secor	---	12000	---	---	6200	75	110	200	1000	< 5	< 2.5
GMW-O-14 DUP	8/28/07	Secor	---	8900	---	---	14000	83	110	170	840	< 5	< 2.5
GMW-O-14	11/15/07	Secor	---	16000	---	---	74000	320	300	520	2470	< 20	< 10
GMW-O-14 DUP	11/15/07	Secor	---	20000	---	---	14000	70	190	450	2500	< 10	< 5
GMW-O-14	2/20/08	Secor	---	35000	---	---	7700	7900	1900	1200	3400	< 100	< 50
GMW-O-14 DUP	2/20/08	Secor	---	35000	---	---	11000	7700	1900	1200	3400	< 100	< 50
GMW-O-14	4/15/08	Secor	---	28000	---	---	31000	4900	1800	840	2800	59	< 25
GMW-O-14 DUP	4/15/08	Secor	---	23000	---	---	42000	4200	1500	690	2400	50	< 20
GMW-O-14	8/14/08	Secor	---	25000	---	---	44000	4300	1100	730	2800	70	< 25
GMW-O-14 DUP	8/14/08	Secor	---	24000	---	---	63000	2900	750	500	2900	< 50	< 25
GMW-O-14	10/16/08	Secor	---	21000	---	---	12000	3200	940	500	3000	< 30	< 15
GMW-O-14 DUP	10/16/08	Secor	---	22000	---	---	9000	3000	910	630	3600	< 30	< 15
GMW-O-14	2/23/09	Blaine Tech	---	30000	---	---	12000	6100	3500	1200	3900	77	< 25
GMW-O-14 DUP	2/23/09	Blaine Tech	---	30000	---	---	12000	6100	3300	1200	3900	80	< 25
GMW-O-14	4/22/09	Blaine Tech	---	36000	---	---	8300	9300	2300	1300	3500	120	< 50
GMW-O-14 DUP	4/22/09	Blaine Tech	---	36000	---	---	11000	9200	2400	1300	3500	120	< 50
GMW-O-14	7/22/09	Blaine Tech	---	32000	---	---	12000	7800	1900	1500	4100	86	< 25
GMW-O-14 DUP	7/22/09	Blaine Tech	---	31000	---	---	15000	7800	1900	1400	3900	93	< 25
GMW-O-14	10/23/09	Blaine Tech	---	40000	---	---	21000	14000	1900	1500	3500	< 200	< 100
GMW-O-14 DUP	10/23/09	Blaine Tech	---	39000	---	---	12000	14000	1800	1400	3500	< 200	< 100
GMW-O-15	10/16/08	Secor	---	1700	---	---	2800	550	3	37	34.1	< 5	110
GMW-O-16	11/27/96	Terra Services	---	---	---	---	---	570	67	14	360	<5	120
GMW-O-16	7/17/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	<0.5	310
GMW-O-16	1/6/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-O-16 DUP	1/9/98	Terra Services	---	4600	730	---	---	---	---	---	---	---	---
GMW-O-16	5/20/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	76
GMW-O-16	11/13/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.7
GMW-O-16	5/7/99	Alton Geoscience	---	<500	<500	---	---	0.66	<0.5	<0.5	0.72	<1	7.6
GMW-O-16	11/18/99	Secor	---	<416	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-16	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.8
GMW-O-16	11/30/00	Secor	---	<300	---	---	<100	0.8	<0.5	<0.5	<0.5	<0.5	0.6
GMW-O-16	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-16	4/10/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-16	10/22/02	Secor	---	<300	---	---	<100	1.6	0.98	<0.5	<0.5	<0.5	<0.5
GMW-O-16	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-16	10/7/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-16	4/22/04	Secor	---	<50	---	---	3600	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-16	7/20/04	Secor	---	---	---	---	<100	---	---	---	---	---	---
GMW-O-16	11/2/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-16	5/5/05	Secor	---	92	---	---	<100	1.6	<0.5	<0.5	<0.5	<0.5	110
GMW-O-16	11/2/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	57
GMW-O-16	2/28/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	5.3
GMW-O-16	5/4/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	6.3
GMW-O-16	9/19/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.57
GMW-O-16	12/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-16	5/5/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-16	11/14/07	Secor	---	< 50	---	---	1400	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-16	2/20/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.68
GMW-O-16	4/16/08	Secor	---	< 50	---	---	< 100	< 0.5	1.2	0.59	5.5	< 0.5	0.63
GMW-O-16	10/14/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	0.6	< 0.5	0.65
GMW-O-16	4/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>0.55</b>
GMW-O-16	10/21/09	Blaine Tech	---	< 50	---	---	<b>250</b>	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-17	11/22/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-O-17	7/10/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	<0.5	<5
GMW-O-17	1/7/98	Terra Services	---	<100	<500	---	---	<0.5	0.64	<0.5	<1.5	<0.5	<5
GMW-O-17	5/21/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-O-17	11/4/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-17	5/5/99	Alton Geoscience	---	<500	<500	---	---	0.64	<0.5	<0.5	<0.5	<1	0.58
GMW-O-17	11/16/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-17	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-17	11/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-17	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-17	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-17	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-17	10/24/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-17	10/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-17	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-17	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-17	5/3/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-17	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-17	4/22/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-18	11/26/96	Terra Services	---	---	---	---	---	<10	<10	<10	<30	<10	10000
GMW-O-18 DUP	11/27/96	Terra Services	---	---	---	---	---	<10	66	<10	<30	<5	120
GMW-O-18	7/11/97	Terra Services	---	<100	<500	---	---	<3	<3	<3	<3	<3	3000
GMW-O-18	1/7/98	Terra Services	---	<100	<500	---	---	<5	<5	<5	<15	<5	3200

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-O-18	5/21/98	Terra Services	---	2000	---	---	---	<100	<100	<100	<200	<100	5600
GMW-O-18	11/17/98	Alton Geoscience	---	543	---	---	<100	<0.5	1	<0.5	2.6	<0.5	1420
GMW-O-18	5/6/99	Alton Geoscience	---	2700	<500	---	---	<5	<5	<5	<5	<13	15000
GMW-O-18	11/18/99	Secor	---	2900	---	---	<100	<13	<12.5	<12.5	<12.5	<13	6700
GMW-O-18	5/19/00	Secor	---	3500	---	---	<100	<25	<25	<25	<25	<25	10000
GMW-O-18	11/2/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	1.4
GMW-O-18	5/6/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	2.1
GMW-O-18	12/7/06	Secor	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	0.65
GMW-O-18	5/4/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.62
GMW-O-18	11/15/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	1.6
GMW-O-18	4/15/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-18	10/15/08	Secor	---	< 200	---	---	< 100	< 1	< 1	< 1	< 2	< 2	< 1
GMW-O-18	4/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	1
GMW-O-18 DUP	4/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>0.99</b>
GMW-O-18	10/21/09	Blaine Tech	---	<b>2400</b>	---	---	<b>680</b>	<b>170</b>	<b>440</b>	<b>17</b>	<b>410</b>	< 5	<b>490</b>
GMW-O-19	11/25/96	Terra Services	---	---	---	---	---	<0.5	<0.87	2.8	5.1	<0.5	<5
GMW-O-19	7/16/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	<0.5	<5
GMW-O-19	1/6/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-O-19	5/20/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	2
GMW-O-19	11/12/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-19	5/6/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	0.51
GMW-O-19	11/18/99	Secor	---	<416	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.5
GMW-O-19	5/17/00	Secor	---	<300	---	---	180	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-19	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-19	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-19	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-19	4/9/03	Secor	---	<50	---	---	500	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-19	8/1/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-19	10/7/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-19	4/22/04	Secor	---	<50	---	---	1400	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-19	7/20/04	Secor	---	---	---	---	<100	---	---	---	---	---	---
GMW-O-19	11/2/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-O-19	5/5/05	Secor	---	510	---	---	110	110	<0.5	17	24.5	<1	150
GMW-O-19	11/2/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-19	2/28/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-19	5/4/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-19	12/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-19	5/5/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-19	11/15/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-19	4/16/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-19	10/14/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-19	4/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-19	10/20/09	Blaine Tech	---	< 50	---	---	< 200	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-O-21	10/7/03	Secor	---	47000	---	---	20000	15000	5200	500	3160	<100	5200
GMW-SF-7	11/25/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	5.8	<0.5	<5
GMW-SF-7	7/11/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	<0.5	8.7
GMW-SF-7	1/2/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
GMW-SF-7	5/19/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
GMW-SF-7	11/11/98	Alton Geoscience	---	<300	---	---	<100	0.96	<0.5	0.5	1.3	<0.5	<0.5
GMW-SF-7	5/7/99	Alton Geoscience	---	<500	<500	---	---	1	4.1	<0.5	1.8	<1	1.3
GMW-SF-7	11/18/99	Secor	---	350	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	200
GMW-SF-7	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-7	11/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-7	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-7	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-7	2/1/02	Secor	---	---	---	---	---	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-7	4/10/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.9
GMW-SF-7	10/22/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	2.5
GMW-SF-7	1/29/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	4.1
GMW-SF-7	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.73
GMW-SF-7	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-7	10/6/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-7	1/28/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-7	4/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	32
GMW-SF-7	7/19/04	Secor	---	550	---	---	<100	<1	<1	<1	<1	<2	680
GMW-SF-7	11/2/04	Secor	---	220	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	340
GMW-SF-7	2/2/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-7	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-7	11/1/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-7	2/27/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-7	5/2/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-7	9/18/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-7	12/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-7	3/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-7	5/5/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-7	8/30/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-7	11/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5



TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
 NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GMW-SF-7	4/16/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-7	10/14/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-7	4/22/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-7	10/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-8	11/22/96	Terra Services	---	<100	<500	---	---	4.5	<1	<1	<3	<1	920
GMW-SF-8	7/11/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	<0.5	140
GMW-SF-8	1/6/98	Terra Services	---	<100	<500	---	---	4.1	<0.5	<0.5	<1.5	<0.5	450
GMW-SF-8	5/22/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<1	0.9
GMW-SF-8	11/12/98	Alton Geoscience	---	<300	---	---	---	<0.5	<0.5	<0.5	<0.5	<0.5	40
GMW-SF-8	5/7/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	4.8
GMW-SF-8	11/18/99	Secor	---	660	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	800
GMW-SF-8	5/17/00	Secor	---	<300	---	---	250	<0.5	<0.5	<0.5	<0.5	<0.5	42
GMW-SF-8	11/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	220
GMW-SF-8	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	20
GMW-SF-8	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	260
GMW-SF-8	4/10/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	3.8
GMW-SF-8	10/22/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	5.2
GMW-SF-8	1/29/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.5
GMW-SF-8	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	6.5
GMW-SF-8	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-8	10/6/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-8	1/27/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-8	4/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-8	7/19/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-8	11/3/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-8	2/2/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-8	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GMW-SF-8	11/1/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-8	2/27/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-8	5/2/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-8	9/18/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	< 0.5
GMW-SF-8	12/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-8	5/4/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-8	11/14/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-8	4/16/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-8	10/14/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-8	4/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-8	10/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GMW-SF-9	9/24/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	9.2
GMW-SF-9	10/10/03	Geomatrix	---	79	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	14
GMW-SF-10	9/24/03	Secor	---	90	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	210
GMW-SF-10	10/10/03	Geomatrix	---	100	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	120
GW-3	4/11/03	Groundwater Technology Inc	---	---	---	---	134	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GW-3	10/11/03	Parsons	---	---	---	---	300	<0.5	<0.5	<0.5	<0.5	<0.5	2.9
GW-3	4/22/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.3
GW-3	11/4/04	Parsons	---	---	---	---	3900	<0.5	<0.5	<0.5	---	<0.5	<0.5
GW-3	5/10/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GW-3	11/8/05	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GW-3	5/3/06	Parsons	---	---	---	---	200	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GW-3	12/6/06	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GW-3	5/3/07	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GW-3	11/14/07	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GW-3	4/17/08	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GW-3	10/16/08	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GW-3	4/24/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GW-3	10/22/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GW-6	11/6/98	Groundwater Technology Inc	---	339	---	---	<100	9.3	1.1	8.4	6.6	<0.5	<0.5
GW-6	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	62	<0.5	12	<0.5	<0.5	<0.5
GW-6	11/18/99	IT Corporation	---	690	---	---	930	90	<1	80	<0.5	<0.5	<0.5
GW-6	5/17/00	IT Corporation	---	<300	---	---	160	1.7	<0.5	2.5	<0.5	<0.5	19
GW-6	12/1/00	IT Corporation	---	<300	---	---	180	3.7	<0.5	1.6	<0.5	<0.5	21
GW-6	5/10/01	IT Corporation	---	<300	---	---	140	0.7	<0.5	<0.5	<0.5	<0.5	23
GW-6	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	21
GW-6	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	9.6
GW-6	4/11/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GW-6	10/10/03	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.71
GW-6	4/22/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GW-6	11/4/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
GW-6	5/10/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
GW-6	11/8/05	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GW-6	5/5/06	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
GW-6	5/2/07	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GW-6	11/15/07	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GW-6	4/17/08	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GW-6	10/15/08	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GW-6	4/21/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	1.5
GW-6	10/22/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	1.8

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toulene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
GW-7	4/12/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.8
GW-13	5/3/07	Parsons	---	---	---	---	2800	< 0.50	< 0.50	< 0.50	< 1	0.83	5.3
GW-13	11/15/07	Parsons	---	---	---	---	1400	< 0.50	< 0.50	< 0.50	< 1	0.94	3.5
GW-13 DUP	11/15/07	Parsons	---	---	---	---	1400	< 0.50	< 0.50	< 0.50	< 1	1	3.5
GW-13	4/17/08	Parsons	---	230	---	---	1300	< 0.50	< 0.50	< 0.50	< 1	0.99	4.4
GW-13	10/17/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	0.84	2.3
GW-13	4/24/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	<b>14</b>	<b>11</b>
GW-13	10/23/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	<b>23</b>	<b>9.5</b>
GW-14	5/3/07	Parsons	---	---	---	---	4000	200	5.2	220	900	---	39
GW-14	11/15/07	Parsons	---	---	---	---	950	35	< 0.50	14	3.94	< 0.50	18
GW-14	4/18/08	Parsons	---	900	---	---	1000	78	< 0.50	< 0.50	2.25	< 0.50	18
GW-14	10/16/08	Parsons	2700	820	---	---	---	40	< 0.50	2.1	1	< 0.50	22
GW-14	4/24/09	Parsons	<b>1600</b>	<b>690</b>	---	---	---	<b>66</b>	< 0.50	<b>0.99</b>	<b>0.64</b>	< 0.50	<b>13</b>
GW-14	10/22/09	Parsons	<b>900</b>	<b>110</b>	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GW-15	5/3/07	Parsons	---	8500	---	---	1600	1100	1000	130	570	< 0.50	< 0.50
GW-16	8/3/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GW-16	10/23/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
GWR-1	11/26/96	Terra Services	---	---	---	---	---	1500	21	150	102	<5	2700
GWR-1	7/16/97	Terra Services	---	1300	920	---	---	220	<5	360	28.8	<5	1800
GWR-1	1/9/98	Terra Services	---	210	<500	---	---	2.9	<0.5	40	240	<0.5	330
GWR-1	5/27/98	Terra Services	---	4100	---	---	---	960	90	90	240	<0.5	630
GWR-1	11/17/98	Alton Geoscience	---	3830	---	---	3320	1200	74	99	387	<25	1070
GWR-1	5/7/99	Alton Geoscience	---	4200	530	---	---	1600	22	96	290	<13	910
GWR-1	11/18/99	Secor	---	1300	---	---	800	220	<10	14	14	<10	690
GWR-1	5/16/00	Secor	---	880	---	---	1400	160	<10	16	16	6.1	550
GWR-1	11/30/00	Secor	---	3200	---	---	5300	1600	8.6	87	33	<0.5	360
GWR-1	5/8/01	Secor	---	4400	---	---	6900	1800	170	160	235	<10	370
GWR-1	11/6/01	Secor	---	2300	---	---	710	240	13	31	56	<0.5	2400
GWR-1	4/9/02	Secor	---	2500	---	---	1000	580	<10	18	57	<10	4000
GWR-1	10/23/02	Secor	---	1900	---	---	1900	270	<10	<10	<10	<10	2500
GWR-1	10/7/03	Secor	---	1400	---	---	500	150	1.7	7.5	19.7	110	1300
GWR-1	5/6/05	Secor	---	16000	---	---	39000	260	610	460	2060	<5	11
GWR-1	5/4/06	Secor	---	3700	---	---	1900**	980	23	120	343	< 10	19
GWR-1	9/18/06	Secor	---	960	---	---	880	220	4.4	19	63.6	< 2	5.4
GWR-1	5/2/07	Secor	---	750	---	---	720	170	1.3	12	22	< 2	4.1
GWR-1	4/17/08	Secor	---	3600	---	---	1500	1700	17	87	60	< 30	21
GWR-1	4/20/09	Blaine Tech	---	<b>5100</b>	---	---	<b>1700</b>	<b>3000</b>	< 15	<b>48</b>	< 30	< 30	<b>31</b>
HL-2	11/27/96	Terra Services	---	---	---	---	---	2600	100	560	390	170	3000
HL-2	7/16/97	Terra Services	---	1400	530	---	---	200	1.2	150	13.3	74	810
HL-2	1/9/98	Terra Services	---	150	---	---	---	<0.5	0.79	3.5	<1.5	40	570
HL-2	1/12/98	Terra Services	---	<500	---	---	---	---	---	---	---	---	---
HL-2	5/27/98	Terra Services	---	500	---	---	---	72	9	6	42	60	308
HL-2 DUP	5/27/98	Terra Services	---	---	---	---	---	33	4	3	19	72	202
HL-2	11/17/98	Alton Geoscience	---	<300	---	---	<100	0.95	<0.5	<0.5	0.6	0.94	13.8
HL-2	5/7/99	Alton Geoscience	---	<500	<500	---	---	1.8	5.1	<0.5	1.8	<1	4.8
HL-2	11/19/99	Secor	---	<300	---	---	<100	2	<0.5	<0.5	<0.5	2.6	36
HL-2	5/16/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.4	14
HL-2	11/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	3.2
HL-2	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	7.3
HL-2	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.8
HL-2	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
HL-2	4/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.85
HL-2	7/8/03	Geomatrix	---	---	---	---	---	<0.5	<1	<1	<1	<0.5	<1
HL-2	10/7/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.96
HL-2	4/21/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	7.9
HL-2	7/8/04	Geomatrix	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.67
HL-2	5/6/05	Secor	---	280	---	---	<100	78	<0.5	<0.5	1.2	15	130
HL-2	11/3/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	1.8
HL-2	5/6/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	1.7
HL-2	12/6/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
HL-2	5/2/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
HL-2	11/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
HL-2	4/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.56
HL-2	10/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
HL-2	4/20/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
HL-2	10/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
HL-3	5/10/01	Secor	---	<300	---	---	300	<0.5	<0.5	<0.5	<0.5	1.4	110
HL-3	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.6	93
HL-3	4/10/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.1	77
HL-3	10/23/02	Secor	---	<300	---	---	360	<0.5	<0.5	<0.5	<0.5	<0.5	85
HL-3	10/7/03	Secor	---	80	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	67
HL-3	5/6/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
HL-3	5/3/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
HL-3	5/2/07	Secor	---	81	---	---	290	< 0.5	< 0.5	< 0.5	< 1	< 0.5	38
HL-3	4/17/08	Secor	---	< 50	---	---	100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	4.7
HL-3	4/20/09	Blaine Tech	---	< 50	---	---	<b>130</b>	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>1.2</b>
HL-4	11/25/96	Terra Services	---	---	---	---	---	<10	3.2	350	8.5	<3	1200

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
HL-4	7/16/97	Terra Services	---	270	<500	---	---	76	<1	<1	16.5	33	1500
HL-4	1/8/98	Terra Services	---	590	660	---	---	170	13	7.1	5	90	2300
HL-4	5/27/98	Terra Services	---	1100	---	---	---	156	26	15	120	28	440
HL-4 DUP	5/27/98	Terra Services	---	---	---	---	---	153	25	15	117000	28	5
HL-4	11/17/98	Alton Geoscience	---	2030	---	---	1380	700	76.2	20	107.8	<0.5	904
HL-4	5/7/99	Alton Geoscience	---	2800	<500	---	---	1100	31	130	84	<6	1500
HL-4	11/18/99	Secor	---	2500	---	---	1100	720	<10	<10	118	<10	520
HL-4	5/16/00	Secor	---	1200	---	---	1000	300	<10	<10	29	51	740
HL-4	11/29/00	Secor	---	1900	---	---	1200	26	<10	<10	<10	89	2800
HL-4	5/8/01	Secor	---	1700	---	---	1100	39	<0.5	0.5	1.7	27	3300
HL-4	11/6/01	Secor	---	950	---	---	140	97	<0.5	<0.5	0.9	<0.5	930
HL-4	4/9/02	Secor	---	1600	---	---	230	940	<5	<5	35	<5	200
HL-4	10/23/02	Secor	---	<300	---	---	320	8.5	<5	<5	<5	<5	1100
HL-4	4/8/03	Secor	---	1500	---	---	<100	2.8	<2.5	<2.5	<2.5	36	2200
HL-4	10/7/03	Secor	---	690	---	---	110	140	<1	<1	1.6	<2	480
HL-4	4/21/04	Secor	---	340	---	---	<100	39	<0.5	<0.5	<0.5	<1	370
HL-4	11/3/04	Secor	---	200	---	---	120	54	<0.5	<0.5	<0.5	<0.5	13
HL-5	7/14/97	Terra Services	---	950	3200	---	---	---	---	---	---	---	---
HP-1	8/7/97	Groundwater Technology Inc	---	---	---	170	---	<5	<5	<5	<10	<5	<5
HP-2	8/7/97	Groundwater Technology Inc	---	---	---	130	---	<5	<5	<5	<10	<5	<5
HP-3	8/7/97	Groundwater Technology Inc	---	---	---	<50	---	<5	<5	<5	<10	<5	<5
HP-6	8/8/97	Groundwater Technology Inc	---	---	---	230	---	<5	<5	<5	<10	<5	<5
HP-8	8/8/97	Groundwater Technology Inc	---	---	---	35000	---	11000	12000	1200	7300	<500	<500
MW-6	11/22/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	130	70
MW-6	7/16/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	32	62
MW-6 DUP	7/16/97	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1	33	63
MW-6	1/5/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	11	39
MW-6 DUP	1/5/98	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	10	36
MW-6	5/26/98	Terra Services	---	<300	---	---	---	<2.5	<2.5	<2.5	<5	118	107
MW-6	11/17/98	Alton Geoscience	---	<300	---	---	<100	4.8	11.6	1.5	9.9	9.2	12.7
MW-6	5/7/99	Alton Geoscience	---	<500	<500	---	---	<0.5	1.5	<0.5	<0.5	83	120
MW-6	11/16/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	20	18
MW-6	5/19/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	14	12
MW-6	11/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	12	3
MW-6	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	9.8	11
MW-6	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	11	6.2
MW-6	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	7.6	6
MW-6	10/24/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	9.4	4.6
MW-6	4/10/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	7.4	3.2
MW-6	10/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	9.1	2.5
MW-6	4/21/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	4.9	2.8
MW-6	11/5/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	4	4
MW-6	5/5/05	Secor	---	89	---	---	100	<0.5	<0.5	<0.5	<0.5	16	61
MW-6	11/3/05	Secor	---	<50	---	---	120	<0.5	<0.5	<0.5	<1	9.9	30
MW-6	5/3/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	6.8	2.5
MW-6	12/7/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	7.1	2.7
MW-6	5/5/07	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	4	2.5
MW-6	11/14/07	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	3.4	2.3
MW-6	4/17/08	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	2.2	2.7
MW-6	10/17/08	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	2.5	4
MW-6	4/22/09	Blaine Tech	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	1.6	0.69
MW-6	10/21/09	Blaine Tech	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	1.5	1
MW-7	11/25/96	Terra Services	---	---	---	---	---	3.5	<1	16	<3	6.8	1000
MW-7	7/14/97	Terra Services	---	540	<500	---	---	88	<3	<3	<3	<3	790
MW-7	1/8/98	Terra Services	---	150	<500	---	---	9	<0.5	<0.5	<1.5	4.1	400
MW-7 DUP	1/8/98	Terra Services	---	150	<500	---	---	10	<0.5	<0.5	<1.5	4.5	<0.5
MW-7	5/26/98	Terra Services	---	400	---	---	---	<5	<5	<5	7	10	380
MW-7	11/17/98	Alton Geoscience	---	<300	---	---	<100	5.4	7	<5	<5	<5	351
MW-7	5/7/99	Alton Geoscience	---	<500	<500	---	---	0.79	2.2	<0.5	0.71	6.8	540
MW-7	11/16/99	Secor	---	540	---	---	<100	8.5	<0.5	<0.5	<0.5	4.7	670
MW-7	5/17/00	Secor	---	590	---	---	880	<5	<5	<5	<5	14	900
MW-7	11/30/00	Secor	---	590	---	---	320	4.1	<0.5	<0.5	<0.5	5.4	640
MW-7	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	3.1	36
MW-7	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	2.4	8.2
MW-7	4/10/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.6	71
MW-7	10/23/02	Secor	---	<300	---	---	180	<0.5	<0.5	<0.5	<0.5	2	5
MW-7	4/10/03	Secor	---	57	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.6	1.3
MW-7	10/7/03	Secor	---	67	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.5	1.2
MW-7	4/21/04	Secor	---	62	---	---	120	<0.5	<0.5	<0.5	<0.5	0.68	1.4
MW-7	11/3/04	Secor	---	58	---	---	140	<0.5	<0.5	<0.5	<0.5	<0.5	0.85
MW-7	5/6/05	Secor	---	58	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.82
MW-7	11/3/05	Secor	---	<100	---	---	<100	<0.5	<0.5	<0.5	<1	<1	<0.5
MW-7	5/3/06	Secor	---	<50	---	---	110 *	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-7	12/6/06	Secor	---	<50	---	---	270	<0.5	<0.5	<0.5	<1	0.65	1.5
MW-7	5/2/07	Secor	---	<50	---	---	160	<0.5	<0.5	<0.5	<1	0.64	0.83
MW-7	11/13/07	Secor	---	<50	---	---	120	<0.5	<0.5	<0.5	<1	0.57	0.83
MW-7	4/17/08	Secor	---	<50	---	---	110	<0.5	<0.5	<0.5	<1	<0.5	0.8

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
MW-7	10/17/08	Secor	---	< 50	---	---	190	< 0.5	< 0.5	< 0.5	< 1	1.8	0.94
MW-7	4/20/09	Blaine Tech	---	< 50	---	---	<b>110</b>	< 0.5	< 0.5	< 0.5	< 1	<b>2.1</b>	<b>0.6</b>
MW-7	10/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	<b>2.8</b>	<b>0.56</b>
MW-8	11/26/96	Terra Services	---	---	---	---	---	4400	<30	<30	<80	<30	26000
MW-8	7/17/97	Terra Services	---	<100	520	---	---	<10	<10	<10	<20	<10	11000
MW-8	1/2/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	<0.5	14
MW-8	5/20/98	Terra Services	---	400	---	---	---	<2.5	<2.5	<2.5	<5	<2.5	554
MW-8	11/17/98	Alton Geoscience	---	<300	---	---	<100	2.4	6	0.8	4.6	<0.5	55.6
MW-8	5/7/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	52
MW-8	11/18/99	Secor	---	<416	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	7.2
MW-8	5/17/00	Secor	---	<300	---	---	170	<0.5	<0.5	<0.5	<0.5	<0.5	3
MW-8	11/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	15
MW-8	2/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	380
MW-8	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	430
MW-8	9/19/01	Secor	---	790	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1000
MW-8	1/30/02	Secor	---	1700	---	---	<100	<10	<10	<10	<10	<10	1900
MW-8	4/10/02	Secor	---	1500	---	---	<100	11	<10	<10	<10	<10	2200
MW-8	10/22/02	Secor	---	<300	---	---	<100	150	<10	11.5	<10	<10	750
MW-8	1/29/03	Secor	---	<300	---	---	<100	<1	<1	<1	<1	<1	190
MW-8	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	28
MW-8	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	13
MW-8	10/6/03	Secor	---	79	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	4.7
MW-8	1/28/04	Secor	---	100	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	4
MW-8	4/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.61
MW-8	7/19/04	Secor	---	80	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.95
MW-8	11/2/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-8	2/2/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.8
MW-8	5/4/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.2
MW-8	11/1/05	Secor	---	110	---	---	270	< 0.5	< 0.5	< 0.5	4.2	< 0.5	0.6
MW-8	2/27/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.65
MW-8	5/2/06	Secor	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	1.1
MW-8	9/19/06	Secor	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	1.6
MW-8	12/6/06	Secor	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	0.61
MW-8 DUP	12/6/06	Secor	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	0.63
MW-8	3/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
MW-8	5/4/07	Secor	---	< 200	---	---	< 100	< 1	< 1	< 1	< 2	< 2	< 1
MW-8 DUP	5/4/07	Secor	---	< 200	---	---	< 100	< 1	< 1	< 1	< 2	< 2	< 1
MW-8	8/29/07	Secor	---	< 200	---	---	< 100	< 1	< 1	< 1	< 2	< 2	< 1
MW-8	11/13/07	Secor	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	1.9
MW-8 DUP	11/13/07	Secor	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	1.8
MW-8	2/20/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	1.7
MW-8	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	3.3
MW-8 DUP	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	3.2
MW-8	10/14/08	Secor	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	0.59
MW-8 DUP	10/14/08	Secor	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	0.59
MW-8	4/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>1</b>
MW-8 DUP	4/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>0.86</b>
MW-8	10/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>0.69</b>
MW-8 DUP	10/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	<b>0.68</b>
MW-9	11/26/96	Terra Services	---	---	---	---	---	18	<0.5	69	1.6	<0.5	<5
MW-9	7/17/97	Terra Services	---	1400	2900	---	---	40	<1	140	21.5	<1	<10
MW-9	1/8/98	Terra Services	---	1100	570	---	---	19	0.74	55	2.4	<0.5	<5
MW-9	5/26/98	Terra Services	---	4700	---	---	---	69	<0.3	51	97.2	<2.5	10
MW-9	11/18/99	Secor	---	1800	---	---	4500	24	<0.5	2.7	2	<0.5	<0.5
MW-9	5/19/00	Secor	---	1300	---	---	3900	12	<0.5	0.8	0.5	<0.5	1.8
MW-9	11/5/04	Secor	---	2500	---	---	21000	27	<0.5	0.84	0.52	<1	52
MW-9	5/6/05	Secor	---	780	---	---	3300	2.3	<1	25	<1	<2	110
MW-9	11/1/05	Secor	---	1700	---	---	5400	9.3	< 1	4.7	5.3	< 2	120
MW-9	5/4/06	Secor	---	1000	---	---	10000*	13	< 0.5	2.2	1.4	< 1	140
MW-9	12/8/06	Secor	---	1400	---	---	14000	16	< 0.5	< 0.5	< 1	< 0.5	160
MW-9	5/4/07	Secor	---	1700	---	---	61000	9.2	< 0.5	0.5	< 1	< 1	130
MW-9	4/18/08	Secor	---	2500	---	---	11000	51	< 1	1.7	1.9	< 2	16
MW-9	10/14/08	Secor	---	1600	---	---	4700	27	< 1	< 1	< 2	< 2	26
MW-9	4/23/09	Blaine Tech	---	<b>1600</b>	---	---	<b>11000</b>	<b>33</b>	< 2.5	< 2.5	< 5	< 5	<b>6.2</b>
MW-10	11/21/96	GSI	---	<38	<500	<500	---	<0.5	<0.5	5.1	2.3	<0.5	---
MW-10	7/9/97	Groundwater Technology Inc	---	<50	170	<50	---	<0.5	<1	2	<2	---	---
MW-10	1/6/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.3	<0.3	<0.3	<0.6	---	---
MW-10	5/20/98	BBC	---	<300	---	---	---	<0.3	<0.3	<0.3	<0.6	---	---
MW-10	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
MW-10	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
MW-10	11/18/99	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
MW-10	5/16/00	IT Corporation	---	<300	---	---	120	<0.3	<0.3	<0.3	<0.6	---	---
MW-10	11/29/00	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	2.4	---	<5
MW-10	5/9/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
MW-10	11/7/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
MW-10	4/10/02	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
MW-11	12/1/00	IT Corporation	---	<300	---	---	290	<0.3	<0.3	<0.3	<0.6	---	<5

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
MW-11	5/10/01	IT Corporation	---	<300	---	---	180	1	<0.3	0.61	<0.6	---	13
MW-11	11/7/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
MW-11	4/10/02	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	19
MW-11	4/14/03	Groundwater Technology Inc	---	---	---	---	6120	83.6	1.54	58.8	51	---	<3
MW-11	10/10/03	Parsons	---	---	---	---	1000	<0.3	<0.3	0.42	0.95	---	12
MW-11	4/22/04	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	6.4
MW-11	11/6/04	Parsons	---	---	---	---	1300	2.3	<0.3	0.64	5.9	---	8.1
MW-11	5/7/05	Parsons	---	---	---	---	<100	0.34	0.61	<0.3	0.6	---	13
MW-11	11/8/05	Parsons	---	---	---	---	<100	0.33	<0.3	<0.3	0.69	---	37
MW-11	5/5/06	Parsons	---	---	---	---	2300	1.6	3.4	3.4	6.9	---	11
MW-11	12/8/06	Parsons	---	---	---	---	740	3.1	<0.50	<0.50	<1.0	---	20
MW-11	5/3/07	Parsons	---	---	---	---	1300	4.3	<0.50	0.86	1.1	---	43
MW-11	11/14/07	Parsons	---	---	---	---	450	<0.5	<0.5	<0.5	<1	---	18
MW-11	4/18/08	Parsons	---	---	---	---	1100	<0.50	<0.50	1	1.5	---	<5.0
MW-11	10/17/08	Parsons	880	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	12
MW-11	4/24/09	Parsons	520	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	8.7
MW-11	10/22/09	Parsons	670	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	3.9
MW-12	5/22/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.1	<0.5
MW-12	11/11/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-12	5/7/99	Alton Geoscience	---	<500	<500	---	---	1.2	4.8	<0.5	2.1	<1	<0.5
MW-12	11/16/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-12	5/19/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-12	11/30/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-12	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-12	11/7/01	IT Corporation	---	<300	---	---	<100	1.3	1.1	<0.5	0.7	<0.5	<0.5
MW-12	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-12	10/24/02	Secor	---	<300	---	---	2800	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-12	4/10/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-12	10/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-12	4/22/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-12	11/5/04	Secor	---	<50	---	---	120	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-12	5/5/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-12	11/3/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-12	5/3/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-12	12/7/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-12	5/5/07	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-12	11/14/07	Secor	---	<50	---	---	190	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-12	4/17/08	Secor	---	<50	---	---	120	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-12	10/21/08	Secor	---	<50	---	---	170	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-12	4/22/09	Blaine Tech	---	<50	---	---	100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-12	10/21/09	Blaine Tech	---	<50	---	---	150	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-13	11/22/96	GSI	---	1100	<500	<500	---	<0.5	<0.5	<0.5	<1.5	<0.5	---
MW-13	7/9/97	Groundwater Technology Inc	---	<50	<50	<50	---	<0.5	<1	<1	<2	---	---
MW-13	1/6/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.3	<0.3	<0.3	<0.6	---	---
MW-13	5/20/98	BBC	---	<300	---	---	---	<0.3	<0.3	<0.3	<0.6	---	---
MW-13	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
MW-13	5/26/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
MW-13	11/18/99	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
MW-13	5/17/00	IT Corporation	---	<300	---	---	20000	<0.3	1.2	<0.3	0.91	---	---
MW-13	11/29/00	IT Corporation	---	<300	---	---	410	<0.3	<0.3	<0.3	0.89	---	<5
MW-13	3/30/01	IT Corporation	---	---	---	---	<50	---	---	---	---	---	---
MW-13	5/9/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
MW-13	11/7/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	14
MW-13	4/10/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-13	10/23/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
MW-13	4/9/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-13	10/8/03	Parsons	---	---	---	---	110	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-13	4/21/04	Parsons	---	---	---	---	160	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-13	11/3/04	Parsons	---	---	---	---	320	<0.5	<0.5	<0.5	---	<0.5	<0.5
MW-13	5/5/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-13	11/5/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-13	5/3/06	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-13	12/5/06	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-13	5/2/07	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-13	11/13/07	Parsons	---	<100	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-13	4/16/08	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-13	10/15/08	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-13	4/20/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-13	10/22/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-14	11/21/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1.5	<0.5	99
MW-14	7/9/97	Groundwater Technology Inc	---	<50	200	<50	---	<5	<5	<5	<5	<5	<5
MW-14	1/6/98	Groundwater Technology Inc	---	<500	<100	800	---	107	<0.5	4	10	2	15
MW-14	5/20/98	BBC	---	400	---	---	---	24	<0.5	7	14	<0.5	12
MW-14	8/26/98	Geomatrix	---	<300	---	---	367	<0.5	<0.5	0.7	2.1	<0.5	109
MW-14	11/4/98	Groundwater Technology Inc	---	<300	---	---	361	<0.5	2.8	4.8	24.6	<0.5	48.6
MW-14	2/3/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<1	<1	86
MW-14	5/7/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	0.53	<1	450

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toulene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
MW-14	5/26/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	0.7	1.1	<0.5	230
MW-14	8/10/99	Alton Geoscience	---	<500	<1000	---	---	<0.5	<1	<1	<1	<2.9	110
MW-14	11/18/99	IT Corporation	---	<300	---	---	<100	<2.5	<5	<5	<5	12	26
MW-14	2/29/00	Secor	---	<300	---	---	420	<0.5	<0.5	<0.5	<0.5	36	15
MW-14	5/16/00	IT Corporation	---	<300	---	---	370	<0.5	<0.5	<0.5	1.4	42	7.7
MW-14	8/29/00	Secor	---	<300	---	---	3800	<0.5	<0.5	<0.5	0.6	38	9.6
MW-14	11/29/00	IT Corporation	---	<300	---	---	130	<0.5	<0.5	0.5	0.9	15	18
MW-14	2/6/01	Secor	---	<300	---	---	230	<0.5	<0.5	<0.5	0.5	11	13
MW-14	5/9/01	IT Corporation	---	<300	---	---	310	<0.5	<0.5	1.8	7.4	32	8.2
MW-14	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	1.1	23	15
MW-14	11/7/01	IT Corporation	---	<300	---	---	190	<0.5	<0.5	0.8	2.3	29	10
MW-14	1/30/02	Secor	---	<300	---	---	450	<0.5	<0.5	<0.5	1.5	8.1	25
MW-14	4/10/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	2.7	6.4	4.1	24
MW-14	7/30/02	IT Corporation	---	<300	---	---	500	<0.5	<0.5	0.98	2.4	3.9	25
MW-14	10/23/02	Groundwater Technology Inc	---	<300	---	---	300	<0.5	<1	<1	<1	4.3	22
MW-14	1/28/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	0.67	5.9	17
MW-14	4/11/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.84	16.8
MW-14	10/10/03	Parsons	---	---	---	---	580	<0.5	<0.5	1.2	4.03	7.4	19
MW-14	4/22/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	0.89	4.7	19
MW-14	7/21/04	Parsons	---	250	---	---	290	<0.5	<0.5	0.61	---	---	22
MW-14	11/4/04	Parsons	---	---	---	---	610	<0.5	<0.5	<0.5	---	5.6	19
MW-14	3/2/05	Parsons	---	---	---	---	320	<0.5	<1	<1	<1	---	14
MW-14	5/7/05	Parsons	---	---	---	---	430	1.3	<0.5	<0.5	<0.5	<0.5	9.3
MW-14	11/8/05	Parsons	---	---	---	---	2200	6.5	<0.5	1.3	3.6	1	3.6
MW-14	5/3/06	Parsons	---	---	---	---	2600	<0.5	<0.5	<0.5	<1	0.78	4.2
MW-14	7/28/06	Parsons	---	290	---	---	4300	<0.5	<0.5	<0.5	<1	0.83	4.2
MW-14	12/6/06	Parsons	---	---	---	---	1900	<0.50	<0.50	<0.50	<1	0.98	3.3
MW-14	3/23/07	Parsons	---	670	---	---	3400	<0.50	<0.50	<0.50	<1	0.94	3.5
MW-14 DUP	3/23/07	Parsons	---	570	---	---	3800	<0.50	<0.50	0.64	<1	0.96	3.4
MW-14	5/3/07	Parsons	---	---	---	---	3100	<0.50	<0.50	<0.50	<1	0.94	3.6
MW-14	8/31/07	Parsons	---	480	---	---	2800	<0.50	<0.50	<0.50	<1	<0.50	3.6
MW-14	11/15/07	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	0.97	4
MW-14	2/7/08	Parsons	---	180	---	---	1400	<0.50	<0.50	<0.50	<1	0.86	5.2
MW-14 DUP	2/7/08	Parsons	---	200	---	---	1200	<0.50	<0.50	<0.50	<1	0.78	5.1
MW-14	4/17/08	Parsons	---	---	---	---	1700	<0.50	<0.50	<0.50	<1	1.2	4.6
MW-14	10/16/08	Parsons	570	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	2.3
MW-14	2/12/09	Parsons	<100	<100	---	---	---	<0.50	<0.50	<0.50	<1	1.1	1.6
MW-14 DUP	2/12/09	Parsons	<100	<100	---	---	---	<0.50	<0.50	<0.50	<1	1	1.5
MW-14	4/22/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	16	1.9
MW-14	7/20/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	13	1.5
MW-14	10/22/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	16	2.5
MW-15	11/26/96	Terra Services	---	---	---	---	---	1.4	0.66	1	0.62	<0.5	27
MW-15	7/14/97	Terra Services	---	1000	3500	---	---	1.5	1.1	<0.5	<1	<0.5	<5
MW-15 DUP	7/14/97	Terra Services	---	---	---	---	---	1.6	0.87	<0.5	<1	<0.5	<5
MW-15	1/7/98	Terra Services	---	<500	1500	---	---	0.62	0.73	<0.5	<1.5	<0.5	<5
MW-15 DUP	1/7/98	Terra Services	---	570	1600	---	---	0.51	<0.5	<0.5	<1.5	<0.5	<0.5
MW-15	5/22/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	0.7	<1	<0.5
MW-15	11/13/98	Alton Geoscience	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-15	5/7/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
MW-15	11/17/99	Secor	---	<300	---	---	910	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-15	5/16/00	Secor	---	340	---	---	1200	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-15	11/30/00	Secor	---	2100	---	---	1700	<0.5	0.8	<0.5	1.1	<0.5	<0.5
MW-15	5/9/01	Secor	---	<300	---	---	690	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-15	11/6/01	Secor	---	<300	---	---	740	<0.5	<0.5	<0.5	<0.5	<0.5	0.6
MW-15	4/10/02	Secor	---	59000	---	---	21000	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-15	7/30/02	IT Corporation	---	780	---	---	550000	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-15	12/8/06	Secor	---	420	---	---	6400	<0.5	<0.5	<0.5	1	<0.5	0.6
MW-15	5/4/07	Secor	---	<500	---	---	6100	<2.5	<2.5	<2.5	<5	<5	<2.5
MW-16	11/27/96	GSI	---	50	<500	<500	---	<0.5	<0.5	<0.5	1.5	140	71
MW-16	7/10/97	Groundwater Technology Inc	---	<50	<50	<50	---	<5	<5	<5	<5	<5	<5
MW-16	1/6/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-16	5/21/98	BBC	---	<300	---	---	---	<0.5	0.7	<0.5	0.6	<0.5	<0.5
MW-16	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-16	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-16	11/18/99	IT Corporation	---	<300	---	---	<100	<0.5	<1	<0.5	<0.5	<0.5	<0.5
MW-16	5/17/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-16	11/30/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-16	5/9/01	IT Corporation	---	<300	---	---	3100	2.6	<0.5	<0.5	0.6	<0.5	<0.5
MW-16	11/7/01	IT Corporation	---	<300	---	---	2100	1.2	<0.5	<0.5	<0.5	<0.5	31
MW-16	2/1/02	Secor	---	---	---	---	---	<0.5	<0.5	<0.5	<0.5	<0.5	220
MW-16	4/11/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	260
MW-16	10/23/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	14
MW-16	1/29/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	6.8
MW-16	4/9/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<1	16.2
MW-16	8/1/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	110
MW-16	10/11/03	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	100
MW-16	1/28/04	Secor	---	51	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	89

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
MW-16	4/21/04	Parsons	---	---	---	---	180	<0.5	<0.5	<0.5	<0.5	<0.5	83
MW-16	7/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	22
MW-16	11/4/04	Parsons	---	---	---	---	300	<0.5	<0.5	<0.5	---	<0.5	3.3
MW-16	2/2/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-16	5/6/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-16	11/8/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-16 DUP	11/8/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-16	5/4/06	Parsons	---	---	---	---	180	0.87	<0.5	<0.5	<1	<0.5	<0.5
MW-16	9/19/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-16	12/8/06	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-16	5/3/07	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-16	11/16/07	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-16	4/17/08	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-16	10/16/08	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-16	4/23/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-16	10/23/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-17	11/27/96	GSI	---	45	<500	<500	---	<0.5	<0.5	<0.5	<1	<0.5	---
MW-17	7/9/97	Groundwater Technology Inc	---	<50	<50	<50	---	<5	<5	<5	<5	<5	<5
MW-17	1/6/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-17	5/20/98	BBC	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-17	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-17	5/26/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-17	11/18/99	IT Corporation	---	<300	---	---	<100	<0.5	<1	<0.5	<0.5	<0.5	0.5
MW-17	5/17/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-17	11/29/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-17	5/9/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-17	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-17	4/10/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-17	10/23/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
MW-17	4/10/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-17	10/8/03	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-17	4/21/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-17	11/3/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
MW-17	5/5/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-17	11/5/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-17	5/3/06	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-17	5/2/07	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-17 DUP	5/2/07	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-17	11/13/07	Parsons	---	<100	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-17	4/16/08	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-17	10/15/08	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-17	4/20/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-17	10/23/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-18 (MID)	7/16/97	Terra Services	---	<100	<500	---	---	---	---	---	---	---	---
MW-18 (MID)	1/5/98	Terra Services	---	420	<500	---	---	---	---	---	---	---	---
MW-18 (MID)	10/8/03	Secor	---	530	---	---	240	1.2	<1	<1	<1	16	640
MW-19 (MID)	11/26/96	Terra Services	---	---	---	---	---	48	<0.5	17	1.76	7.7	600
MW-19 (MID)	7/16/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	9.1	810
MW-19 (MID)	1/5/98	Terra Services	---	<100	<500	---	---	<5	<50	<5	<15	<5	1400
MW-19 (MID)	5/27/98	Terra Services	---	500	---	---	---	<5	<0.5	<5	<10	14	590
MW-19 (MID)	8/26/98	Geomatrix	---	514	---	---	233	<2.5	<2.5	<2.5	<2.5	11.1	779
MW-19 (MID)	11/17/98	Alton Geoscience	---	491	---	---	<100	<5	<5	<5	<5	11	850
MW-19 (MID)	2/3/99	Alton Geoscience	---	<10000	<500	---	---	<10	<10	<10	<20	<20	1300
MW-19 (MID)	5/6/99	Alton Geoscience	---	540	<500	---	---	42	<1	<1	<1	<2.5	1500
MW-19 (MID)	8/10/99	Alton Geoscience	---	600	<1000	---	---	<0.5	<1	<1	<1	6.8	980
MW-19 (MID) DUF	8/10/99	Alton Geoscience	---	600	<1000	---	---	<5	<10	<10	<10	<5	990
MW-19 (MID)	11/17/99	Secor	---	1100	---	---	310	26	<5	<5	<5	<5	1100
MW-19 (MID)	2/29/00	Secor	---	2000	---	---	1800	530	<5	<5	<5	<5	1100
MW-19 (MID)	5/17/00	Secor	---	5200	---	---	5100	1900	<25	<25	<25	<25	2600
MW-19 (MID)	8/29/00	Secor	---	2700	---	---	19000	560	<10	<10	<10	<10	3200
MW-19 (MID)	11/30/00	Secor	---	2100	---	---	1200	520	3.6	0.9	6.1	<0.5	1200
MW-19 (MID)	2/6/01	Secor	---	780	---	---	410	66	<10	<10	<10	<10	720
MW-19 (MID)	5/9/01	Secor	---	360	---	---	230	4.4	<2.5	<2.5	<2.5	6.5	490
MW-19 (MID)	9/19/01	Secor	---	<300	---	---	<100	<2.5	<2.5	<2.5	<2.5	8.2	200
MW-19 (MID)	11/6/01	Secor	---	<300	---	---	120	<1	<1	<1	<1	6.5	180
MW-19 (MID)	1/30/02	Secor	---	<300	---	---	150	<0.5	<0.5	<0.5	<0.5	5.1	33
MW-19 (MID)	4/10/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	4.3	11
MW-19 (MID)	10/23/02	Secor	---	<300	---	---	330	1.1	<0.5	<0.5	<0.5	3.5	7.4
MW-19 (MID)	4/10/03	Secor	---	92	---	---	<100	<0.5	<0.5	<0.5	<0.5	2.5	4.3
MW-19 (MID)	10/7/03	Secor	---	84	---	---	<100	<0.5	<0.5	<0.5	<0.5	2.3	1
MW-19 (MID)	4/21/04	Secor	---	99	---	---	150	<0.5	<0.5	<0.5	<0.5	2.6	<0.5
MW-19 (MID)	11/3/04	Secor	---	<100	---	---	200	<0.5	<0.5	<0.5	<0.5	2	0.81
MW-19 (MID)	5/6/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-19 MID	11/3/05	Secor	---	68	---	---	140	<0.5	<0.5	<0.5	<1	4.2	1.2
MW-19 MID	5/3/06	Secor	---	76	---	---	110	<0.5	<0.5	<0.5	<1	13	2.2
MW-19 MID	12/6/06	Secor	---	<50	---	---	260	<0.5	<0.5	<0.5	<1	1.3	<0.5
MW-19 MID	5/2/07	Secor	---	61	---	---	200	<0.5	<0.5	<0.5	<1	2.2	1.1

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
MW-19 MID	11/13/07	Secor	---	57	---	---	130	< 0.5	< 0.5	< 0.5	< 1	2.9	0.86
MW-19 MID	4/17/08	Secor	---	< 50	---	---	110	< 0.5	< 0.5	< 0.5	< 1	3	1.2
MW-19 MID	10/17/08	Secor	---	< 50	---	---	190	< 0.5	< 0.5	< 0.5	< 1	3.2	1.3
MW-19 MID	4/20/09	Blaine Tech	---	< 50	---	---	120	< 0.5	< 0.5	< 0.5	< 1	3.8	0.81
MW-19 MID	10/21/09	Blaine Tech	---	< 50	---	---	140	< 0.5	< 0.5	< 0.5	< 1	5	0.79
MW-20 (MID)	11/22/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	1.5	66	36
MW-20 (MID)	7/11/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	33	13
MW-20 (MID)	1/5/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	17	9.2
MW-20 (MID)	5/27/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	35	22
MW-20 (MID)	11/16/98	Alton Geoscience	---	<300	---	---	<100	14	41	4.8	29.8	31	33
MW-20 (MID)	5/7/99	Alton Geoscience	---	<500	<500	---	---	5.6	22	1.7	9.8	22	13
MW-20 (MID)	11/16/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	21	19
MW-20 (MID)	5/19/00	Secor	---	<300	---	---	220	<0.5	<0.5	<0.5	<0.5	22	11
MW-20 (MID)	11/28/00	Secor	---	<300	---	---	340	<0.5	<0.5	<0.5	<0.5	17	8.1
MW-20 (MID)	5/9/01	Secor	---	<300	---	---	180	<50	<50	<50	<50	2200	1300
MW-20 (MID)	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	23	11
MW-20 (MID)	11/7/01	IT Corporation	---	<300	---	---	170	<0.5	<0.5	<0.5	<0.5	23	14
MW-20 (MID)	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	17	12
MW-20 (MID)	10/24/02	Secor	---	<300	---	---	220	<0.5	<0.5	<0.5	<0.5	20	20
MW-20 (MID)	4/10/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	17	11
MW-20 (MID)	10/8/03	Secor	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	29	19
MW-20 (MID)	4/21/04	Secor	---	56	---	---	<100	<0.5	<0.5	<0.5	<0.5	27	18
MW-20 (MID)	11/5/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	23	15
MW-20 (MID) DUF	11/5/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	25	17
MW-20 (MID)	5/5/05	Secor	---	97	---	---	<100	<0.5	<0.5	<0.5	<0.5	33	57
MW-20 MID	11/3/05	Secor	---	58	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	25	46
MW-20 MID	5/3/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	21	32
MW-20 MID	12/7/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	21	25
MW-20 MID	5/5/07	Secor	---	59	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	20	25
MW-20 MID	11/14/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	20	23
MW-20 MID	4/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	15	21
MW-20 MID	10/17/08	Secor	---	< 50	---	---	100	< 0.5	< 0.5	< 0.5	< 1	17	18
MW-20 MID	4/22/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	17	16
MW-20 MID	10/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	16	18
MW-21 (MID)	5/7/99	Alton Geoscience	---	<500	590	---	---	<1	<1	<1	<1	75	39
MW-21 (MID)	11/29/00	Secor	---	<300	---	---	4600	3.6	<0.5	<0.5	<0.5	16	62
MW-21 (MID)	5/9/01	Secor	---	<300	---	---	1900	<0.5	<0.5	<0.5	<0.5	9.8	50
MW-21 (MID)	11/6/01	Secor	---	<300	---	---	1400	0.5	<0.5	<0.5	<0.5	12	69
MW-21 (MID)	4/10/02	Secor	---	<300	---	---	1100	<0.5	<0.5	<0.5	<0.5	8.6	71
MW-21 (MID)	10/23/02	Secor	---	<300	---	---	1400	<0.5	<0.5	<0.5	<0.5	7.4	61
MW-21 (MID)	10/7/03	Secor	---	87	---	---	290	<0.5	<0.5	<0.5	<0.5	5.6	55
MW-21 (MID)	5/6/05	Secor	---	62	---	---	100	<0.5	<0.5	<0.5	<0.5	2.8	25
MW-21 MID	5/3/06	Secor	---	< 50	---	---	140 *	< 0.5	< 0.5	< 0.5	< 1	1.5	13
MW-21 MID	5/2/07	Secor	---	< 50	---	---	110	< 0.5	< 0.5	< 0.5	< 1	0.73	3.3
MW-21 MID	4/17/08	Secor	---	< 50	---	---	100	< 0.5	< 0.5	< 0.5	< 1	0.88	6.4
MW-21 MID	4/20/09	Blaine Tech	---	< 100	---	---	530	< 0.5	< 0.5	< 0.5	< 1	2.3	1.9
MW-22 (MID)	11/21/96	GSI	---	46	<500	<500	---	<0.5	<0.5	<0.5	<1.5	4.7	<5
MW-22 (MID)	7/10/97	Groundwater Technology Inc	---	<50	650	<400	---	<5	<5	<5	<5	15	<5
MW-22 (MID)	1/6/98	Groundwater Technology Inc	---	---	400	<100	---	<5	<5	<5	<1	<5	<5
MW-22 (MID)	5/21/98	BBC	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	0.9	<0.5
MW-22 (MID)	8/26/98	Geomatrix	---	<300	---	---	545	<0.5	<0.5	<0.5	<0.5	2.1	<0.5
MW-22 (MID)	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.6	<0.5
MW-22 (MID)	2/2/99	Alton Geoscience	---	<500	---	---	---	1.1	2.1	0.56	2.1	3.2	0.69
MW-22 (MID)	5/7/99	Alton Geoscience	---	---	<500	---	---	8	3.4	1.7	7.5	<1	6.9
MW-22 (MID)	5/26/99	Groundwater Technology Inc	---	<300	---	---	322	<0.5	<0.5	<0.5	<0.5	3.7	4.7
MW-22 (MID)	8/10/99	Alton Geoscience	---	<500	<1000	---	---	3.1	6.2	<1	4.9	8.9	<1
MW-22 (MID)	11/18/99	IT Corporation	---	<300	---	---	260	<0.5	<1	<0.5	<0.5	19	0.8
MW-22 (MID)	2/29/00	Secor	---	<300	---	---	470	<0.5	<0.5	<0.5	<0.5	29	3.3
MW-22 (MID)	5/16/00	IT Corporation	---	<300	---	---	380	<0.5	<0.5	<0.5	<0.5	16	2.4
MW-22 (MID)	8/29/00	Secor	---	<300	---	---	4400	<0.5	<0.5	<0.5	<0.5	45	14
MW-22 (MID)	11/28/00	Secor	---	<300	---	---	1100	<0.5	<0.5	<0.5	<0.5	88	13
MW-22 (MID)	11/29/00	IT Corporation	---	<300	---	---	870	<0.5	<0.5	<0.5	<0.5	88	13
MW-22 (MID)	2/6/01	Secor	---	<300	---	---	460	<1	<1	<1	<1	120	14
MW-22 (MID)	5/9/01	IT Corporation	---	<300	---	---	360	<0.5	<0.5	<0.5	<0.5	110	12
MW-22 (MID)	5/9/01	Secor	---	<300	---	---	230	<0.5	<0.5	<0.5	<0.5	83	11
MW-22 (MID)	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	30	4.5
MW-22 (MID)	11/7/01	IT Corporation	---	<300	---	---	130	<0.5	<0.5	<0.5	<0.5	36	6.5
MW-22 (MID)	1/30/02	Secor	---	<300	---	---	430	<0.5	<0.5	<0.5	<0.5	30	19
MW-22 (MID)	4/12/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	22	11
MW-22 (MID)	7/30/02	IT Corporation	---	<300	---	---	210	<0.5	<0.5	<0.5	<0.5	24	8.7
MW-22 (MID)	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	18	5.4
MW-22 (MID)	1/28/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	18	4.8
MW-22 (MID)	4/11/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	9.12	2.38
MW-22 (MID)	10/11/03	Parsons	---	---	---	---	380	<0.5	<0.5	<0.5	<0.5	12	2.8
MW-22 (MID)	4/22/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	19	4.8
MW-22 (MID)	7/21/04	Parsons	---	180	---	---	280	<0.5	<0.5	<0.5	---	---	11
MW-22 (MID)	11/4/04	Parsons	---	---	---	---	240	<0.5	<0.5	<0.5	---	31	11



TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
MW-22 (MID)	3/2/05	Parsons	---	---	---	---	180	<0.5	<1	<1	<1	---	15
MW-22 (MID)	5/7/05	Parsons	---	---	---	---	290	<0.5	<0.5	<0.5	<0.5	1.8	30
MW-22 MID	11/8/05	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	2.1	30
MW-22 MID	5/5/06	Parsons	---	---	---	---	500	< 0.5	< 0.5	< 0.5	< 1	6.1	14
MW-22 MID	12/5/06	Parsons	---	---	---	---	130	< 0.50	< 0.50	< 0.50	< 1	5.3	16
MW-22 MID	5/2/07	Parsons	---	---	---	---	200	< 0.50	< 0.50	< 0.50	< 1	4.4	14
MW-22 MID	11/14/07	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	10	15
MW-22 MID	4/17/08	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	8.3	11
MW-22 MID	10/16/08	Parsons	110	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	9.7	16
MW-22 MID	2/12/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	15	18
MW-22 MID	4/22/09	Parsons	110	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	11	23
MW-22 MID	7/20/09	Parsons	150	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	11	19
MW-22 MID	10/23/09	Parsons	130 J	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	13	16
MW-22 MID DUP	10/23/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	14	16
MW-23 (MID)	11/21/96	GSI	---	1400	<500	<500	---	62	<0.5	18	3.5	0.6	---
MW-23 (MID)	7/9/97	Groundwater Technology Inc	---	---	---	---	---	160	<1	21	26	---	---
MW-23 (MID)	7/9/97	Groundwater Technology Inc	---	140	970	<860	---	---	---	---	---	---	---
MW-23 (MID)	1/6/98	Groundwater Technology Inc	---	---	<100	<100	---	<0.3	---	<0.3	---	---	---
MW-23 (MID)	5/20/98	BBC	---	<300	---	---	---	---	---	---	---	---	---
MW-23 (MID)	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
MW-23 (MID)	5/27/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
MW-23 (MID)	11/18/99	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
MW-23 (MID)	5/16/00	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
MW-23 (MID)	11/29/00	IT Corporation	---	<300	---	---	2200	<0.3	<0.3	<0.3	<0.6	---	<5
MW-23 (MID)	5/10/01	IT Corporation	---	<300	---	---	1600	<0.3	<0.3	<0.3	<0.6	---	<5
MW-23 (MID)	11/7/01	IT Corporation	---	<300	---	---	600	<0.3	<0.3	<0.3	<0.6	---	<5
MW-23 (MID)	4/10/02	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
MW-23 (MID)	10/23/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
MW-23 (MID)	4/10/03	Groundwater Technology Inc	---	---	---	---	<100	<1	<1	<1	<2	<3	<3
MW-23 (MID)	10/8/03	Parsons	---	---	---	---	160	<0.3	<0.3	<0.3	<0.3	---	<5
MW-23 (MID)	4/22/04	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
MW-23 (MID)	11/4/04	Parsons	---	---	---	---	<100	<0.3	<0.3	<0.3	<0.3	---	<5
MW-23 (MID)	5/10/05	Parsons	---	---	---	---	650	0.4	0.79	0.41	<0.3	---	<5
MW-23 MID	11/8/05	Parsons	---	---	---	---	1900	< 0.3	0.4	< 0.3	< 0.3	---	< 5
MW-23 MID	5/3/06	Parsons	---	---	---	---	6000	< 0.3	< 0.3	< 0.3	0.32	---	< 5
MW-23 MID	12/6/06	Parsons	---	---	---	---	240	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
MW-23 MID	5/2/07	Parsons	---	---	---	---	340	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
MW-23 MID	11/14/07	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	---	< 5
MW-23 MID	4/16/08	Parsons	---	---	---	---	120	< 0.50	< 0.50	< 0.50	< 1.0	---	< 5.0
MW-23 MID	10/15/08	Parsons	150	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
MW-23 MID	4/21/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	---	< 0.50
MW-23 MID	10/23/09	Parsons	150 J	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
MW-24	11/21/96	GSI	---	92	<500	<500	---	<0.5	<0.5	<0.5	<1.5	<0.5	---
MW-24	7/9/97	Groundwater Technology Inc	---	100	1400	<1000	---	11	<5	<5	<5	<5	<5
MW-24	1/6/98	Groundwater Technology Inc	---	700	<100	<100	---	93	<0.5	4	<1	<0.5	<0.5
MW-24	5/20/98	BBC	---	<300	---	---	---	<0.3	<0.5	<0.5	<1	<0.5	<0.5
MW-24	11/4/98	Groundwater Technology Inc	---	<300	---	---	129	11	2.7	2.1	18	<0.5	<0.5
MW-24	5/26/99	Groundwater Technology Inc	---	<300	---	---	142	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-24	11/18/99	IT Corporation	---	<300	---	---	<100	<0.5	<1	<0.5	<0.5	<0.5	<0.5
MW-24	5/16/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-24	11/29/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-24	5/9/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-24	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-24	4/10/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-24	10/23/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
MW-24	4/11/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-24	10/8/03	Parsons	---	---	---	---	140	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-24	4/22/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-24	11/4/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
MW-24	5/7/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-24	11/8/05	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
MW-24	5/3/06	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
MW-24	12/6/06	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
MW-24	5/3/07	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
MW-24	11/14/07	Parsons	---	---	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
MW-24	4/17/08	Parsons	---	---	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
MW-24	10/16/08	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
MW-24	4/21/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
MW-24	10/23/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
MW-25	11/21/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1.5	17	<5
MW-25	7/9/97	Groundwater Technology Inc	---	<50	660	<400	---	<5	<5	<5	<5	17	<5
MW-25	1/6/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	15	<0.5
MW-25	5/21/98	BBC	---	<300	---	---	---	<0.3	<0.5	<0.5	<1	8.6	<0.5
MW-25	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	11	<0.5
MW-25	5/6/99	Alton Geoscience	---	<500	<500	---	---	1.9	1.2	0.68	3.3	14	1.3
MW-25 DUP	5/6/99	Alton Geoscience	---	<500	<500	---	---	2.1	1.4	0.78	3.9	15	1.3
MW-25	5/26/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	10	<0.5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
MW-25	11/18/99	IT Corporation	---	<300	---	---	<100	<0.5	<1	<0.5	<0.5	27	0.7
MW-25	5/16/00	IT Corporation	---	<300	---	---	320	<0.5	<0.5	<0.5	<0.5	50	4.7
MW-25	11/28/00	Secor	---	<300	---	---	320	<0.5	<0.5	<0.5	<0.5	62	11
MW-25	11/29/00	IT Corporation	---	<300	---	---	<100	<0.5	0.6	<0.5	0.8	73	14
MW-25	5/9/01	IT Corporation	---	<300	---	---	240	<0.5	<0.5	<0.5	<0.5	45	7.1
MW-25	5/9/01	Secor	---	<300	---	---	150	<0.5	<0.5	<0.5	<0.5	36	6.2
MW-25	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	39	9.3
MW-25	4/12/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	23	9.4
MW-25	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	15	5.1
MW-25	4/11/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	30.6	8.61
MW-25	10/11/03	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	13	3.4
MW-25	4/22/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	13	3.5
MW-25	11/4/04	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	---	17	3.4
MW-25	5/7/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	2.8	5
MW-25	11/8/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	0.95	1.9
MW-25	5/5/06	Parsons	---	---	---	---	390	<0.5	<0.5	<0.5	<1	4.3	10
MW-25	12/5/06	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	3	3.5
MW-25 DUP	12/5/06	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	3.1	3.2
MW-25	5/3/07	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	2.8	2.3
MW-25	11/14/07	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	1.6	1.3
MW-25	4/17/08	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	4.5	4.3
MW-25	10/16/08	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	8.9	6.1
MW-25	4/22/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<b>8.3</b>	<b>2.9</b>
MW-25	10/23/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<b>4.1</b>	<b>0.83</b>
MW-26	11/21/96	GSI	---	6700	<500	<500	---	460	400	200	340	0.7	---
MW-26	7/10/97	Groundwater Technology Inc	---	<50	270	<200	---	<5	<5	<5	<5	<5	340
MW-26	1/6/98	Groundwater Technology Inc	---	<500	<100	<100	---	<2.5	<2.5	<2.5	<5	<2.5	407
MW-26	5/21/98	BBC	---	<300	---	---	---	<0.3	<0.5	<0.5	<1	<0.5	<0.5
MW-26	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	1.3	<0.5	1.1	<0.5	146
MW-26	5/26/99	Groundwater Technology Inc	---	8260	---	---	8790	3000	170	400	1000	<0.5	380
MW-26	11/18/99	IT Corporation	---	<300	---	---	<100	<0.5	<1	<0.5	<0.5	<0.5	3.4
MW-26	5/16/00	IT Corporation	---	8400	---	---	7000	2300	<5	410	1480	<5	76
MW-26	11/29/00	IT Corporation	---	1800	---	---	1000	440	15	69	240	<10	69
MW-26	5/10/01	IT Corporation	---	<300	---	---	<100	2.1	<0.5	<0.5	<0.5	<0.5	1.9
MW-26	11/7/01	IT Corporation	---	1700	---	---	3700	370	79	37	171	<0.5	35
MW-26	4/11/02	IT Corporation	---	4000	---	---	5300	1200	<5	230	528	<5	65
MW-26	10/24/02	Groundwater Technology Inc	---	2100	---	---	5800	970	<5	<5	262	<2.5	74
MW-26	4/11/03	Groundwater Technology Inc	---	---	---	---	1390	858	<0.5	243	78.6	<0.5	108
MW-26	10/11/03	Parsons	---	---	---	---	900	4.6	<0.5	5.7	0.54	<0.5	29
MW-26	4/22/04	Parsons	---	---	---	---	570	<0.5	<0.5	<0.5	<0.5	<0.5	140
MW-26	11/4/04	Parsons	---	---	---	---	260	<0.5	<0.5	<0.5	---	<0.5	110
MW-26	5/7/05	Parsons	---	---	---	---	170	<0.5	<0.5	3.1	<0.5	<0.5	<0.5
MW-26	11/8/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-26	5/5/06	Parsons	---	---	---	---	120	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-26	12/6/06	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	1.9
MW-26	5/3/07	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	2
MW-26	11/14/07	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	4.4
MW-26 DUP	11/14/07	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	4.5
MW-26	4/17/08	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	0.99
MW-26 DUP	4/17/08	Parsons	---	---	---	---	<100	<0.50	<0.50	<0.50	<1	<0.50	0.65
MW-26	10/16/08	Parsons	150	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	5
MW-26	4/22/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<0.50
MW-26	10/23/09	Parsons	<100	---	---	---	---	<0.50	<0.50	<0.50	<1	<0.50	<b>2</b>
MW-27	11/22/96	GSI	---	<50	<500	<500	---	180	12	25	50	<0.5	---
MW-27	7/10/97	Groundwater Technology Inc	---	420	400	<400	---	1400	28	53	253	<5	79
MW-27	1/6/98	Groundwater Technology Inc	---	1500	<100	100	---	940	<5	70	20	20	90
MW-27	5/21/98	BBC	---	<300	---	---	---	<0.3	<0.5	<0.5	<1	<0.5	<0.5
MW-27	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-27	5/26/99	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	0.71	1.33	<0.5	1.1
MW-27	11/18/99	IT Corporation	---	7200	---	---	6400	1700	8.6	100	1110	<0.5	170
MW-27	5/16/00	IT Corporation	---	<300	---	---	<100	1.7	<0.5	<0.5	<0.5	<0.5	5
MW-27	11/29/00	IT Corporation	---	<300	---	---	<100	0.9	0.7	0.7	1	0.6	17
MW-27	5/10/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-27	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-27	4/11/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	0.9
MW-27	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	9.7
MW-27	4/11/03	Groundwater Technology Inc	---	---	---	---	<100	<0.5	<0.5	2.76	<0.5	<0.5	16.7
MW-27	10/11/03	Parsons	---	---	---	---	150	6.2	<0.5	0.79	<0.5	<0.5	8.9
MW-27	4/22/04	Parsons	---	---	---	---	1600	130	<0.5	16	<0.5	<0.5	65
MW-27	11/6/04	Parsons	---	---	---	---	540	1.6	<0.5	17	---	<0.5	65
MW-27	5/7/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-27 DUP	5/7/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
MW-27	11/8/05	Parsons	---	---	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	0.59
MW-27	5/5/06	Parsons	---	---	---	---	280	<0.5	<0.5	<0.5	<1	<0.5	2
MW-27	12/6/06	Parsons	---	---	---	---	180	<0.50	<0.50	<0.50	<1	<0.50	2.3
MW-27	5/3/07	Parsons	---	---	---	---	110	<0.50	<0.50	<0.50	<1	<0.50	1.5
MW-27	11/14/07	Parsons	---	---	---	---	<100	1.3	<0.5	<0.5	<1	<0.5	<0.5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toulene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
MW-27	4/18/08	Parsons	---	---	---	---	< 100	2.9	< 0.50	< 0.50	< 1	< 0.50	< 0.50
MW-27	10/17/08	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
MW-27	4/22/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
MW-27	10/26/09	Parsons	< 100	---	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	<b>0.54</b>
MW-28	11/27/96	GSI	---	1500	<500	<500	---	<2.5	<2.5	<2.5	<5	<2.5	---
MW-28	7/10/97	Groundwater Technology Inc	---	220	2200	<1900	---	<5	<5	<5	<5	<5	<5
MW-28	1/7/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
MW-28	5/21/98	BBC	---	<300	---	---	---	<0.3	<0.3	<0.3	<0.6	---	---
MW-28	11/5/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	---
MW-28	5/26/99	Groundwater Technology Inc	---	<300	---	---	<100	0.33	<0.3	<0.3	0.7	---	---
MW-28	11/18/99	IT Corporation	---	<300	---	---	330	<0.3	<0.3	<0.3	<0.6	---	---
MW-28	5/17/00	IT Corporation	---	<300	---	---	250	<0.3	<0.3	<0.3	<0.6	---	---
MW-28	12/1/00	IT Corporation	---	<300	---	---	470	<0.3	<0.3	<0.3	<0.6	---	<5
MW-28	5/10/01	IT Corporation	---	<300	---	---	3000	<0.3	<0.3	<0.3	<0.6	---	<5
MW-28	11/8/01	IT Corporation	---	300	---	---	160	<0.3	<0.3	<0.3	<0.6	---	<5
MW-28	4/12/02	IT Corporation	---	<300	---	---	170	<0.3	<0.3	<0.3	<0.6	---	<5
MW-29	5/21/98	BBC	---	84700	---	---	---	313	45.7	314	366	---	---
MW-29	11/5/98	Groundwater Technology Inc	---	28600	---	---	19600	87	<0.3	2.2	31	---	---
MW-29	5/27/99	Groundwater Technology Inc	---	1810	---	---	2540	150	<0.6	160	23	---	---
MW-29	11/18/99	IT Corporation	---	5100	---	---	17000	220	<0.3	190	21	---	---
MW-29	5/17/00	IT Corporation	---	1100	---	---	3400	23	<0.3	35	7.6	---	---
MW-29	11/30/00	IT Corporation	---	2400	---	---	14000	120	<0.3	160	4.4	---	<5
MW-29	5/9/01	IT Corporation	---	<300	---	---	<100	<0.3	<0.3	<0.3	<0.6	---	<5
MW-29	11/7/01	IT Corporation	---	1500	---	---	1500	14	<0.3	3.7	2.1	---	8.3
MW-29	2/1/02	Secor	---	---	---	---	---	100	7.3	160	990	<0.5	<0.5
MW-29	4/11/02	IT Corporation	---	860	---	---	5600	4.1	<0.3	4.3	12	---	<5
MW-SF-1	3/11/03	Geomatrix	---	1700	---	---	1500	1400	16	76	54	<1	620
MW-SF-1	8/1/03	Secor	---	13000	---	---	18000	4200	240	420	1020	<30	910
MW-SF-1	10/7/03	Secor	---	15000	---	---	7300	4800	170	390	1060	<40	800
MW-SF-1	4/22/04	Secor	---	27000	---	---	11000	11000	510	480	970	<100	3800
MW-SF-1	11/3/04	Secor	---	34000	---	---	12000	13000	400	690	1170	<100	2600
MW-SF-1	5/6/05	Secor	---	12000	---	---	8800	3900	220	240	340	<30	670
MW-SF-1	11/2/05	Secor	---	15000	---	---	9200	5600	340	330	1050	< 50	570
MW-SF-1	5/6/06	Secor	---	20000	---	---	9000 **	8200	730	570	1050	< 100	1300
MW-SF-1	12/8/06	Secor	---	19000	---	---	20000 **	7000	640	590	960	< 100	650
MW-SF-1	3/13/07	Secor	---	10000	---	---	2700	3400	320	390	790	< 50	160
MW-SF-1	5/4/07	Secor	---	11000	---	---	4600	3400	110	430	229	< 50	340
MW-SF-1	8/30/07	Secor	---	16000	---	---	9000	6000	210	550	290	< 100	430
MW-SF-1	11/14/07	Secor	---	16000	---	---	6300	6100	180	540	213	< 50	400
MW-SF-1	2/21/08	Secor	---	23000	---	---	5600	11000	280	530	500	< 100	1100
MW-SF-1	4/16/08	Secor	---	21000	---	---	11000	11000	350	440	550	< 200	740
MW-SF-1	8/14/08	Secor	---	18000	---	---	27000	8200	240	390	253	< 100	490
MW-SF-1	10/16/08	Secor	---	21000	---	---	12000	10000	280	490	477	< 100	770
MW-SF-1	2/24/09	Blaine Tech	---	<b>11000</b>	---	---	<b>10000</b>	<b>6300</b>	<b>85</b>	<b>160</b>	<b>90 J</b>	< 50	<b>420</b>
MW-SF-1	4/20/09	Blaine Tech	---	<b>16000</b>	---	---	<b>11000</b>	<b>7500</b>	<b>210</b>	<b>340</b>	<b>261</b>	< 100	<b>340</b>
MW-SF-1	7/22/09	Blaine Tech	---	<b>12000</b>	---	---	<b>34000</b>	<b>6300</b>	<b>110</b>	<b>180</b>	<b>89</b>	< 50	<b>510</b>
MW-SF-1	10/23/09	Blaine Tech	---	<b>21000</b>	---	---	<b>12000</b>	<b>11000</b>	<b>110</b>	<b>350</b>	<b>63</b>	< 100	<b>620</b>
MW-SF-4	3/11/03	Geomatrix	---	3600	---	---	2500	1100	<13	180	120	<13	750
MW-SF-4	10/8/03	Secor	---	40000	---	---	86000	4600	1900	990	5200	<40	530
MW-SF-4	11/2/05	Secor	---	5300	---	---	30000	1100	66	250	218	< 10	190
MW-SF-4	2/21/08	Secor	---	25000	---	---	9900	4100	89	1200	2730	< 40	330
MW-SF-4	4/16/08	Secor	---	21000	---	---	11000	4600	94	970	2920	< 100	380
MW-SF-4	8/14/08	Secor	---	20000	---	---	54000	4200	43	1100	770	< 50	260
MW-SF-4	10/16/08	Secor	---	17000	---	---	12000	3700	42	1100	1196	< 40	170
MW-SF-4	2/23/09	Blaine Tech	---	<b>20000</b>	---	---	<b>32000</b>	<b>6400</b>	<b>92</b>	<b>1000</b>	<b>1420</b>	< 50	<b>950</b>
MW-SF-9	3/11/03	Geomatrix	---	24000	---	---	13000	3200	940	340	1040	<25	1600
MW-SF-9	8/1/03	Secor	---	6600	---	---	95000	980	72	140	430	17	2500
MW-SF-9	10/7/03	Secor	---	5800	---	---	3300	340	8.8	82	92	<5	3200
MW-SF-9	5/4/05	Secor	---	5700	---	---	9700	730	73	130	190	<10	54
MW-SF-9	11/3/05	Secor	---	< 500	---	---	690	9.4	< 2.5	< 2.5	< 5	< 5	< 2.5
MW-SF-9	12/8/06	Secor	---	< 500	---	---	10000 *	35	< 2.5	< 2.5	3.6	< 5	8.7
MW-SF-9	11/14/07	Secor	---	110	---	---	1400	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
MW-SF-9	4/16/08	Secor	---	920	---	---	5800	200	1.4	6.3	3.9	< 1	16
MW-SF-9	10/21/08	Secor	---	350	---	---	770	10	< 0.5	2.3	< 1	< 1	< 0.5
MW-SF-9	4/23/09	Blaine Tech	---	<b>430</b>	---	---	<b>3800</b>	<b>44</b>	< 0.5	<b>1.2</b>	< 1	< 0.5	< 0.5
MW-SF-9	10/22/09	Blaine Tech	---	<b>2400</b>	---	---	<b>5900</b>	<b>1300</b>	< 10	<b>11</b>	< 20	< 20	<b>13</b>
PO-7	11/8/05	Secor	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
PW-1	11/27/96	Terra Services	---	---	---	---	---	<1	2.2	<1	2	270	<10
PW-1	7/15/97	Terra Services	---	190	<500	---	---	<0.5	<0.5	<0.5	<1	180	<5
PW-1	1/5/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	68	<5
PW-1	5/22/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	38	<0.5
PW-1	11/13/98	Alton Geoscience	---	<300	---	---	---	<0.5	<0.5	<0.5	<0.5	73	8.1
PW-1	5/6/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	5.7	<0.5
PW-1	11/17/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	2.5	<0.5
PW-1	5/17/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.5	<0.5
PW-1	11/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.7	<0.5
PW-1	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.6	<0.5

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toulene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>	
PW-1	11/7/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.3	<0.5	
PW-1	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-1	10/23/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-1	4/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-1	10/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-1	4/21/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-1	11/4/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-1	5/5/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	2.1	<0.5	
PW-1	5/6/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-1	12/7/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-1	5/5/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-1	11/14/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-1	4/18/08	Secor	---	< 50	---	---	460	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-1	11/21/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-1	4/20/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-1	10/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-1 DUP	10/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-2	11/25/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	76	3.3	
PW-2	7/14/97	Terra Services	---	140	<500	---	---	<0.5	<0.5	<0.5	<1	160	<5	
PW-2	1/6/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	82	<5	
PW-2	5/22/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	37	0.9	
PW-2	8/25/98	Geomatrix	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	6.8	<0.5	
PW-2	11/16/98	Alton Geoscience	---	<300	---	---	---	16	18	2	10.9	35	58	
PW-2	2/3/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<1	79	2.4	
PW-2	5/6/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	3.4	<0.5	
PW-2	8/10/99	Alton Geoscience	---	<500	<1000	---	---	<0.5	<1	<1	<1	32	<1	
PW-2	11/19/99	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	45	0.7	
PW-2	2/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	58	<0.5	
PW-2	5/16/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	50	0.8	
PW-2	8/29/00	Secor	---	<300	---	---	760	<0.5	<0.5	<0.5	<0.5	56	0.6	
PW-2	11/29/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	35	0.6	
PW-2	2/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	28	0.8	
PW-2	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	14	<0.5	
PW-2 DUP	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	12	<0.5	
PW-2	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	24	<0.5	
PW-2	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	23	<0.5	
PW-2	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-2	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.7	19	<0.5
PW-2	10/24/02	Secor	---	<300	---	---	1000	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-2	1/16/03	Geomatrix	---	<300	---	---	<100	---	---	---	---	---	---	
PW-2	4/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-2	7/7/03	Geomatrix	---	---	---	---	---	<0.5	<1	<1	<1	<0.5	<1	
PW-2	10/7/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	8.8	<0.5	
PW-2	4/21/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	18	0.56	
PW-2	7/8/04	Geomatrix	---	<50	---	---	250	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-2	11/3/04	Secor	---	83	---	---	140	<0.5	<0.5	<0.5	<0.5	52	1.5	
PW-2	5/6/05	Secor	---	110	---	---	<100	<0.5	<0.5	<0.5	<0.5	70	6.2	
PW-2	11/3/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-2	5/4/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-2	12/6/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	6.8	< 0.5	
PW-2 DUP	12/6/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	6.9	< 0.5	
PW-2	5/2/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	0.57	< 0.5	
PW-2 DUP	5/2/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	0.62	< 0.5	
PW-2	11/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-2 DUP	11/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-2	4/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-2 DUP	4/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-3	11/25/96	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1.5	110	<5	
PW-3 DUP	11/25/96	Terra Services	---	---	---	---	---	79	16	140	49	12	610	
PW-3	7/14/97	Terra Services	---	140	<500	---	---	5.9	2.4	2.9	8.4	67	<5	
PW-3	1/8/98	Terra Services	---	<100	<500	---	---	1.2	1.1	<0.5	<1.5	46	<5	
PW-3	5/22/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	48	1.6	
PW-3 DUP	5/22/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	49	<0.5	
PW-3	8/25/98	Geomatrix	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	35.3	<0.5	
PW-3	11/16/98	Alton Geoscience	---	<300	---	---	---	<0.5	4.5	0.6	3.6	21	<0.5	
PW-3	2/3/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<1	25	<0.5	
PW-3	5/6/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	21	<0.5	
PW-3	8/10/99	Alton Geoscience	---	<500	<1000	---	---	<0.5	<1	<1	<1	13	<1	
PW-3	11/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	3.5	<0.5	
PW-3	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	4.4	<0.5	
PW-3	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	2.7	<0.5	
PW-3	11/6/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	4.8	<0.5	
PW-3	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-3	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	3	<0.5	
PW-3	10/24/02	Secor	---	<300	---	---	1600	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-3	1/16/03	Geomatrix	---	<300	---	---	<100	---	---	---	---	---	---	
PW-3	4/8/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.73	<0.5	

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toulene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>	
PW-3	7/7/03	Geomatrix	---	---	---	---	---	<0.5	<1	<1	<1	<0.5	<1	
PW-3	10/7/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	2.6	<0.5	
PW-3	4/21/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-3	7/13/04	Geomatrix	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-3	11/3/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PW-3	5/6/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.53	<0.5	
PW-3	11/3/05	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-3	5/3/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-3	12/6/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	1.1	< 0.5	
PW-3	5/2/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-3	11/15/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-3	4/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-3	10/17/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PW-3	4/20/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	0.64	< 0.5	
PW-3	10/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	0.86	< 0.5	
PZ-1	11/27/96	Terra Services	---	---	---	---	---	79	16	140	49	15	610	
PZ-1	7/16/97	Terra Services	---	220	<500	---	---	<0.5	<0.5	13	<1	3	480	
PZ-1	1/6/98	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1.5	1.3	17	
PZ-1	5/26/98	Terra Services	---	400	---	---	---	<5	<5	<5	<10	<5	370	
PZ-1 DUP	5/26/98	Terra Services	---	400	---	---	---	<5	<5	<5	<10	<5	360	
PZ-1	11/16/98	Alton Geoscience	---	516	---	---	<100	110	67	8	38	7.2	320	
PZ-1	5/6/99	Alton Geoscience	---	2000	<500	---	---	500	<2	13	120	<5	230	
PZ-1	11/17/99	Secor	---	<300	---	---	<100	<2.5	<2.5	<2.5	<2.5	<2.5	210	
PZ-1	5/17/00	Secor	---	350	---	---	---	740	51	<2.5	<2.7	<2.5	<2.5	250
PZ-1	11/29/00	Secor	---	390	---	---	---	720	79	<2.5	<2.5	<2.5	<2.5	260
PZ-1	5/8/01	Secor	---	<300	---	---	---	380	15	<0.5	<0.5	<0.5	<0.5	330
PZ-1	11/6/01	Secor	---	550	---	---	---	140	8.4	<0.5	<0.5	0.7	1.4	470
PZ-1	4/9/02	Secor	---	<300	---	---	<100	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	270
PZ-3	4/22/04	Parsons	---	---	---	---	56000	6300	<1500	4100	24000	---	<25000	
PZ-3	4/22/09	Parsons	2200	---	---	---	---	< 2.5	< 2.5	< 2.5	< 5	< 2.5	< 2.5	
PZ-5	10/7/03	Secor	---	6900	---	---	<100	11	<10	<10	<10	<20	9100	
PZ-5	5/5/05	Secor	---	<50	---	---	<100	0.87	<0.5	<0.5	<0.5	<0.5	43	
PZ-5	11/2/05	Secor	---	1200	---	---	< 100	< 2.5	< 2.5	< 2.5	< 5	< 5	2100	
PZ-5	2/28/06	Secor	---	160	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	380	
PZ-5	5/4/06	Secor	---	1200	---	---	< 100	< 2	< 2	< 2	< 4	< 4	1900	
PZ-5	9/19/06	Secor	---	480	---	---	< 100	< 1	< 1	< 1	< 2	< 2	1200	
PZ-5	12/7/06	Secor	---	480	---	---	< 100	< 1.5	< 1.5	< 1.5	< 3	< 3	960	
PZ-5	3/13/07	Secor	---	320	---	---	< 100	< 1	< 1	< 1	< 2	< 2	690	
PZ-5 DUP	3/13/07	Secor	---	340	---	---	< 100	< 1	< 1	< 1	< 2	< 2	740	
PZ-5	5/4/07	Secor	---	400	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	610	
PZ-5 DUP	5/4/07	Secor	---	480	---	---	< 100	< 1	< 1	< 1	< 2	< 2	640	
PZ-5 DUP	8/28/07	Secor	---	360	---	---	< 100	< 1	< 1	< 1	< 2	< 2	460	
PZ-5	8/29/07	Secor	---	380	---	---	< 100	< 1	< 1	< 1	< 2	< 2	480	
PZ-5	11/15/07	Secor	---	370	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 1	470	
PZ-5	2/20/08	Secor	---	940	---	---	560	< 1	< 1	< 1	< 2	< 2	750	
PZ-5 DUP	2/20/08	Secor	---	1000	---	---	530	< 1	< 1	< 1	< 2	< 2	780	
PZ-5	4/15/08	Secor	---	750	---	---	330	< 1	< 1	< 1	< 2	< 2	740	
PZ-5 DUP	4/15/08	Secor	---	730	---	---	420	< 1	< 1	< 1	< 2	< 2	740	
PZ-5	8/12/08	Secor	---	1500	---	---	370	< 2	< 2	< 2	< 4	< 4	2000	
PZ-5 DUP	8/12/08	Secor	---	1600	---	---	410	< 1	< 1	< 1	< 2	< 2	2000	
PZ-5	10/16/08	Secor	---	< 3000	---	---	210	22	< 15	< 15	< 30	< 30	1900	
PZ-5 DUP	10/16/08	Secor	---	< 3000	---	---	330	21	< 15	< 15	< 30	< 30	2200	
PZ-5	2/24/09	Blaine Tech	---	1000	---	---	440	61	< 1	< 1	< 2	< 2	1200	
PZ-5 DUP	2/24/09	Blaine Tech	---	1000	---	---	450	61	< 1	< 1	< 2	< 2	1200	
PZ-5 SPLIT <sup>11</sup>	2/24/09	Blaine Tech	---	2400	---	---	1000	71	<100	< 100	< 200	< 50	1400	
PZ-5	4/23/09	Blaine Tech	---	1200	---	---	760	250	< 2	5.7	< 4	< 4	1200	
PZ-5 DUP	4/23/09	Blaine Tech	---	1200	---	---	790	270	< 2	6.8	< 4	< 4	1200	
PZ-5	7/22/09	Blaine Tech	---	3800	---	---	1800	2000	20	98	77	< 5	800	
PZ-5 DUP	7/22/09	Blaine Tech	---	3500	---	---	1900	1900	19	92	72	< 5	780	
PZ-5	10/23/09	Blaine Tech	---	2900	---	---	1300	1100	18	53	69	< 10	500	
PZ-5 DUP	10/23/09	Blaine Tech	---	3000	---	---	1300	1100	18	55	74	< 10	530	
PZ-6	11/30/00	Secor	---	<300	---	---	<100	<0.5	0.5	<0.5	<0.5	<0.5	<0.5	
PZ-6	5/8/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PZ-6	7/8/03	Geomatrix	---	---	---	---	---	<0.5	<1	<1	<1	<0.5	<1	
PZ-6	4/27/04	Geomatrix	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
PZ-6	7/8/04	Geomatrix	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.5	<0.5	
PZ-7A	6/13/03	Secor	---	340	---	---	<100	<0.5	<0.5	<0.5	<0.5	<1	660	
PZ-7A	9/24/03	Secor	---	160	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	390	
PZ-7A	10/10/03	Geomatrix	---	240	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	340	
PZ-7B	6/13/03	Secor	---	98	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.51	51	
PZ-7B	9/24/03	Secor	---	61	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	67	
PZ-7B	10/10/03	Geomatrix	---	90	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	2.3	
PZ-8A	6/13/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	12	
PZ-8A	9/24/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.7	
PZ-8A	10/10/03	Geomatrix	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	2.8	
PZ-8A	12/6/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5	
PZ-8B	6/13/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	31	

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
PZ-8B	9/24/03	Secor	---	86	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	180
PZ-8B	10/10/03	Geomatrix	---	310	---	---	<100	<0.5	<0.5	<0.5	<0.5	<1	440
PZ-8B	12/6/06	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<1	<0.5	<0.5
PZ-9A	6/13/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
PZ-9A	9/24/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
PZ-9A	10/10/03	Geomatrix	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
PZ-9B	6/13/03	Secor	---	75	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	50
PZ-9B	9/24/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	7.9
PZ-9B	10/10/03	Geomatrix	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	3.9
PZ-10	8/1/03	Secor	---	6300	---	---	1800	710	130	150	890	<10	47
PZ-10	10/7/03	Secor	---	6200	---	---	1900	1000	21	230	600	<10	55
PZ-10	1/27/04	Secor	---	3100	---	---	1800	560	5.4	63	201	<5	28
PZ-10	4/22/04	Secor	---	11000	---	---	8300	2100	29	470	1490	<20	110
PZ-10	7/19/04	Secor	---	4800	---	---	2500	890	<5	210	278	<10	45
PZ-10	11/3/04	Secor	---	4600	---	---	2800	920	9.1	280	580	<10	50
PZ-10	2/3/05	Secor	---	1000	---	---	1200	250	1.4	34	108	<2	42
PZ-10	5/4/05	Secor	---	<50	---	---	350	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
PZ-10	11/2/05	Secor	---	<100	---	---	220	<0.5	<0.5	<0.5	<1	<1	<0.5
PZ-10	2/27/06	Secor	---	<200	---	---	1600 *	<1	<1	<1	<2	<2	6.1
PZ-10	5/6/06	Secor	---	<1000	---	---	1600 *	5.1	<5	<5	<10	<10	36
PZ-10	9/20/06	Secor	---	<200	---	---	640 *	<1	<1	<1	<2	<2	3.6
PZ-10	12/6/06	Secor	---	<500	---	---	2400 *	<2.5	<2.5	<2.5	<5	<5	5.5
PZ-10	3/13/07	Secor	---	<500	---	---	1100	<2.5	<2.5	<2.5	<5	<5	<2.5
PZ-10	5/3/07	Secor	---	<1000	---	---	7100	6.1	<5	<5	<10	<10	<5
PZ-10	8/30/07	Secor	---	<200	---	---	1000	<1	<1	<1	<2	<2	<1
PZ-10	11/14/07	Secor	---	<50	---	---	360	<0.5	<0.5	<0.5	<1	<0.5	<0.5
PZ-10	2/21/08	Secor	---	<200	---	---	510	65	<1	3.1	9.4	<2	<1
PZ-10	4/16/08	Secor	---	950	---	---	670	360	5	20	85	<5	11
PZ-10	10/16/08	Secor	---	<200	---	---	1100	18	<1	<1	<2	<2	1.7
PZ-10	4/20/09	Blaine Tech	---	560	---	---	2600	26	<1	3.2	2.5	<2	12
PZ-10	7/21/09	Blaine Tech	---	<200	---	---	1700	1.4	<1	<1	<2	<2	9.6
PZ-10	10/22/09	Blaine Tech	---	<200	---	---	1200	<1	<1	<1	<2	<2	4.4
TF-8	9/18/03	Parsons	---	---	---	---	<100	1.2	<0.5	0.77	2.74	<0.5	24
TF-8	2/21/04	Parsons	---	---	---	520	---	3.2	<0.5	<0.5	---	---	46
TF-14	9/18/03	Parsons	---	---	---	---	20000	210	<2.5	62	88.8	<2.5	<2.5
TF-14	2/21/04	Parsons	---	---	---	12000	---	370	<1	130	---	---	1.2
TF-16	4/14/03	Groundwater Technology Inc	---	---	---	---	4450	23.8	5.03	15.3	16.8	---	9.51
TF-16	9/18/03	Parsons	---	---	---	---	59000	280	8.3	24	211	<0.5	9.1
TF-16	10/11/03	Parsons	---	---	---	---	7400	150	7	27	91	---	<25
TF-16	2/21/04	Parsons	---	---	---	48000	---	120	2.4	23	---	---	5.6
TF-16	4/21/04	Parsons	---	---	---	---	23000	200	30	40	320	---	4.6
TF-16	11/4/04	Parsons	---	---	---	---	16000	180	4	20	320	---	<10
TF-16	5/6/05	Parsons	---	---	---	---	27000	43	10	4.6	73	---	<25
TF-16	11/8/05	Parsons	---	---	---	---	4200	25	0.86	3.4	20	---	8.5
TF-16	5/4/06	Parsons	---	---	---	---	33000	52	0.89	10	49	---	<5
TF-16	12/8/06	Parsons	---	---	---	---	3500	28	<0.50	1.5	3	---	<5.0
TF-16	5/4/07	Parsons	---	---	---	---	13000	520	<2.5	5.4	10	---	<25
TF-16	11/15/07	Parsons	---	---	---	---	5200	450	<0.50	<0.50	<1.0	---	9.3
TF-16	4/17/08	Parsons	---	---	---	---	4300	570	1.3	3.2	4.1	---	<10
TF-16	10/16/08	Parsons	3100	---	---	---	---	330	<2.5	<2.5	<5	<2.5	6.3
TF-16	4/24/09	Parsons	2200	---	---	---	---	24	<0.50	<0.50	<1	<0.50	4.1
TF-16	10/26/09	Parsons	960	---	---	---	---	7.6	<0.50	0.34	<1	<0.50	3.9
TF-21	4/10/03	Groundwater Technology Inc	---	---	---	---	476	267	1.63	8.13	9.83	---	<3
TF-21	9/18/03	Parsons	---	---	---	---	1800	560	<5	5.6	<5	<5	<5
TF-21	10/8/03	Parsons	---	---	---	---	2500	390	<0.6	4.2	<0.6	---	<10
TF-21	2/21/04	Parsons	---	---	---	1500	---	820	<2.5	<2.5	---	---	3.6
TF-21	4/21/04	Parsons	---	---	---	---	2000	550	<1	1.6	5.8	---	2.7
TF-21	11/4/04	Parsons	---	---	---	---	860	10	<0.3	<0.3	1.2	---	<5
TF-21	5/5/05	Parsons	---	---	---	---	3600	190	13	45	310	---	<100
TF-21	11/5/05	Parsons	---	---	---	---	2200	140	0.61	3.7	39	---	6.1
TF-21 DUP	11/5/05	Parsons	---	---	---	---	2500	150	2.9	4.1	38	---	<25
TF-21	5/3/06	Parsons	---	---	---	---	3200	140	4.3	3.9	10	---	5.1
TF-21	12/6/06	Parsons	---	---	---	---	1100	44	<0.50	<0.50	5	---	<5.0
TF-21	5/4/07	Parsons	---	---	---	---	3200	80	0.93	0.86	2.2	---	7.2
TF-21	11/16/07	Parsons	---	---	---	---	790	170	<0.50	<0.50	<1.0	---	<5.0
TF-21	4/17/08	Parsons	---	---	---	---	980	190	<0.50	4.4	2.4	---	<5.0
TF-21	10/15/08	Parsons	810	---	---	---	---	37	<0.50	<0.50	<1	<0.50	1
TF-21	4/24/09	Parsons	350	---	---	---	---	40	<0.50	<0.50	<1	<0.50	<0.50
TF-21	10/26/09	Parsons	960	---	---	---	---	50	<0.50	0.46	<1	<0.50	0.74
WCW-1	11/25/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1.5	0.6	<5
WCW-1	7/15/97	Terra Services	---	<100	<500	<500	---	<0.5	<0.5	<0.5	<1	<0.5	<5
WCW-1	1/5/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-1	5/23/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-1	8/25/98	Geomatrix	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-1	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-1	2/2/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<1	<1	<0.5
WCW-1 DUP	2/2/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<1	<1	<0.5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
WCW-1	5/6/99	Alton Geoscience	---	<500	<500	---	---	2.1	9.8	0.8	4.4	<1	<0.5
WCW-1	8/10/99	Alton Geoscience	---	<500	<1000	---	---	<0.5	<1	<1	<1	<0.5	<1
WCW-1	11/18/99	IT Corporation	---	<300	---	---	<100	<0.5	<1	<0.5	<0.5	<0.5	<0.5
WCW-1	2/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-1	5/19/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-1	8/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.5	<0.5
WCW-1	11/30/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-1	2/5/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-1	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-1	9/18/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-1	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-1	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-1	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-1	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
WCW-1	10/11/03	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	1.5
WCW-1	5/6/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-1	5/3/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-1	11/13/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-1	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-1	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-2	11/25/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1.5	<1.7	<5
WCW-2	7/8/97	Terra Services	---	<100	<500	---	---	<0.5	3.5	1.4	7.4	0.57	<5
WCW-2	1/5/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	1	<0.5
WCW-2	5/19/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-2	8/25/98	Geomatrix	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	2/2/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<1	<1	<0.5
WCW-2	5/6/99	Alton Geoscience	---	<500	<500	---	---	<0.5	0.8	<0.5	<0.5	<1	<0.5
WCW-2	8/10/99	Alton Geoscience	---	<500	<1000	---	---	<0.5	<1	<1	<1	<0.5	<1
WCW-2	11/17/99	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	2/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	2	<0.5
WCW-2	5/18/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	8/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.6	<0.5
WCW-2	11/30/00	IT Corporation	---	<300	---	---	<100	0.6	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	2/5/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	9/18/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
WCW-2	4/10/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	10/11/03	Parsons	---	<100	---	---	110	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	4/21/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	11/3/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
WCW-2	5/5/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-2	11/5/05	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-2	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-2	12/5/06	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-2	5/1/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-2	11/13/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-2	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-2	10/17/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-2	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-2	10/26/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-3	11/25/96	GSI	---	120	<500	<500	---	<0.7	<0.5	<0.5	<1.5	190	<5
WCW-3	7/15/97	Terra Services	---	100	<500	---	---	<0.5	<0.5	<0.5	<1	190	<5
WCW-3	1/5/98	Groundwater Technology Inc	---	<500	200	<100	---	<0.5	<0.5	<0.5	<1	220	<0.5
WCW-3	5/23/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	201	<0.5
WCW-3	8/26/98	Geomatrix	---	<300	---	---	304	<2.5	<2.5	<2.5	<2.5	200	<2.5
WCW-3	11/3/98	Groundwater Technology Inc	---	<300	---	---	228	<0.5	<0.5	<0.5	<0.5	190	<0.5
WCW-3	2/3/99	Alton Geoscience	---	<1000	<500	---	---	<1	<1	<1	<2	200	<1
WCW-3	5/6/99	Alton Geoscience	---	<500	<500	---	---	<0.5	1.3	<0.5	<0.5	<1	1.1
WCW-3	8/10/99	Alton Geoscience	---	<500	<1000	---	---	<0.5	<1	<1	<1	130	1.8
WCW-3	11/17/99	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	100	3.3
WCW-3	2/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	100	<0.5
WCW-3	5/18/00	Secor	---	<300	---	---	110	<0.5	<0.5	<0.5	<0.5	92	1
WCW-3	8/28/00	Secor	---	<300	---	---	200	<0.5	<0.5	<0.5	<0.5	90	0.7
WCW-3	11/30/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	68	<0.5
WCW-3	2/5/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	81	<0.5
WCW-3	5/9/01	Secor	---	<300	---	---	120	<0.5	<0.5	<0.5	<0.5	63	<0.5
WCW-3	9/19/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	69	<0.5
WCW-3	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	51	<0.5
WCW-3	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	34	<0.5
WCW-3	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	29	<0.5
WCW-3	7/30/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	47	0.55
WCW-3	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	39	<1

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toulene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
WCW-3	1/28/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	44	<0.5
WCW-3	4/10/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	34	<0.5
WCW-3	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	23	<0.5
WCW-3	10/11/03	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	22	<0.5
WCW-3	1/28/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	43	<0.5
WCW-3	5/10/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	33	<0.5
WCW-3	7/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	46	<0.5
WCW-3	11/3/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	---	33	<0.5
WCW-3	2/3/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	39	<0.5
WCW-3	5/5/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	31	<0.5
WCW-3	11/5/05	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	19	< 0.5
WCW-3	2/28/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	8.8	< 0.5
WCW-3	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	10	< 0.5
WCW-3	9/20/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	16	< 0.5
WCW-3	12/5/06	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	6.6	< 0.50
WCW-3	3/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-3	5/1/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-3	8/28/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-3	11/13/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-3	2/21/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-3	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-3	8/13/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	3.6	< 0.5
WCW-3	10/17/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	1.3	< 0.50
WCW-3	2/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-3	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-3	7/20/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	1.7	< 0.5
WCW-3	10/26/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	4	< 0.50
WCW-4	11/22/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
WCW-4	7/8/97	Terra Services	---	<100	<500	---	---	0.5	0.78	<0.5	<1	<0.5	<5
WCW-4	1/5/98	Groundwater Technology Inc	---	<500	<100	300	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-4	5/19/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-4	11/3/98	Groundwater Technology Inc	---	<300	---	---	475	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-4	5/6/99	Alton Geoscience	---	<500	<500	---	---	2.1	7.7	0.62	3.4	<1	<0.5
WCW-4	11/17/99	IT Corporation	---	<300	---	---	110	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-4	5/18/00	Secor	---	<300	---	---	120	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-4	11/30/00	IT Corporation	---	<300	---	---	160	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-4	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-4	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-4	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-4	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
WCW-4	4/10/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-4	10/11/03	Parsons	---	<100	---	---	280	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-4	5/10/04	Secor	---	<50	---	---	120	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-4	11/3/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
WCW-4	5/5/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-4	11/5/05	Parsons	---	< 100	---	---	110	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-4	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-4	12/5/06	Parsons	---	< 100	---	---	120	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-4	5/1/07	Secor	---	< 50	---	---	250	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-4	11/13/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	0.72
WCW-4	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.61
WCW-4	10/17/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	0.65
WCW-4	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.51
WCW-4	10/26/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	0.64
WCW-5	11/22/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
WCW-5	7/8/97	Terra Services	---	<100	<500	---	---	<0.5	7.7	<0.5	1.4	<0.5	<5
WCW-5	1/5/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	0.7	<0.5
WCW-5	5/19/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-5	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-5	5/5/99	Alton Geoscience	---	<500	<500	---	---	10	43	3.8	21	<1	<0.5
WCW-5	11/17/99	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-5	5/16/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-5	11/30/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-5	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-5	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-5	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-5	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
WCW-5	4/10/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-5	10/11/03	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-5	5/10/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-5	11/3/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
WCW-5	5/6/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-5	11/5/05	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-5	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-5	12/5/06	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-5	5/1/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-5	11/13/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50



TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
WCW-5	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-5	10/17/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-5	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-5	10/26/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-6	11/22/96	GSI	---	230	<500	<500	---	<0.5	<0.5	<0.5	<1.5	220	24
WCW-6	7/15/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	65	10
WCW-6	1/5/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	159	3
WCW-6	5/26/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	83	2
WCW-6	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	46	1.8
WCW-6	5/6/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	53	0.68
WCW-6	11/17/99	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	11	<0.5
WCW-6	5/16/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	16	0.7
WCW-6	11/30/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	2.7	<0.5
WCW-6	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	5.7	<0.5
WCW-6	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	2.7	<0.5
WCW-6	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.7	<0.5
WCW-6	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
WCW-6	4/10/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.4	<0.5
WCW-6	10/11/03	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.93	<0.5
WCW-6	5/10/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.64	<0.5
WCW-6	11/3/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
WCW-6	5/5/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-6	11/5/05	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	1.1	< 0.5
WCW-6 DUP	11/5/05	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	0.82	< 0.5
WCW-6	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-6	12/5/06	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-6	5/2/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-6	11/13/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-6	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-6	10/17/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-6	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-6	10/26/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-7	11/22/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1.5	31	<5
WCW-7	7/15/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	<0.5	<5
WCW-7	1/5/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	30	<0.5
WCW-7	5/23/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	30	<0.5
WCW-7	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	35	<0.5
WCW-7	5/6/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	45	<0.5
WCW-7	11/18/99	IT Corporation	---	<300	---	---	190	<0.5	<1	<0.5	0.6	62	1.3
WCW-7	5/16/00	Secor	---	<300	---	---	420	<0.5	<0.5	<0.5	<0.5	120	6.4
WCW-7	11/30/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	83	6
WCW-7	2/5/01	Secor	---	<300	---	---	230	<0.5	<0.5	<0.5	<0.5	95	6.1
WCW-7	5/10/01	Secor	---	<300	---	---	180	<0.5	<0.5	<0.5	<0.5	91	9.3
WCW-7	9/18/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	140	12
WCW-7	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	91	11
WCW-7	1/30/02	Secor	---	<300	---	---	110	<0.5	<0.5	<0.5	<0.5	84	8.8
WCW-7	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	66	8.4
WCW-7	7/30/02	IT Corporation	---	<300	---	---	260	<0.5	<0.5	<0.5	<0.5	74	8.6
WCW-7	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	78	9.3
WCW-7	1/28/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	80	7.3
WCW-7	4/10/03	Secor	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	69	6.8
WCW-7	7/30/03	Secor	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	69	7.6
WCW-7	10/11/03	Parsons	---	<100	---	---	260	<0.5	<0.5	<0.5	<0.5	84	9.4
WCW-7	1/28/04	Secor	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	100	10
WCW-7	5/10/04	Secor	---	<100	---	---	170	<0.5	<0.5	<0.5	<0.5	73	6.7
WCW-7	7/20/04	Secor	---	140	---	---	<100	<0.5	<0.5	<0.5	<0.5	110	9
WCW-7	11/3/04	Parsons	---	<100	---	---	330	<0.5	<0.5	<0.5	---	84	11
WCW-7	2/3/05	Secor	---	72	---	---	110	<0.5	<0.5	<0.5	<0.5	91	8.8
WCW-7	5/5/05	Secor	---	<100	---	---	<100	<0.5	<0.5	<0.5	<0.5	83	6.9
WCW-7	11/5/05	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	14	6.7
WCW-7	2/28/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	2.5	0.84
WCW-7	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	6	2.5
WCW-7	9/20/06	Secor	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	33	7.2
WCW-7	12/5/06	Parsons	---	< 100	---	---	210	< 0.50	< 0.50	< 0.50	< 1	36	8
WCW-7	3/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	32	5.4
WCW-7	5/2/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	49	6.4
WCW-7	8/28/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	56	7.1
WCW-7	11/14/07	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	50	6.5
WCW-7	2/21/08	Secor	---	< 50	---	---	110	< 0.5	< 0.5	< 0.5	< 1	43	5.9
WCW-7	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	54	5.9
WCW-7	8/13/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	55	5.3
WCW-7	10/17/08	Parsons	100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	45	5.4
WCW-7	2/24/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	40	2.4
WCW-7	4/22/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	40	2.8
WCW-7	7/21/09	Blaine Tech	---	< 50	---	---	120	< 0.5	< 0.5	< 0.5	< 1	31	1.9
WCW-7	10/26/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	40	1.8
WCW-8	11/22/96	GSI	---	84	<500	<500	---	<0.5	<0.5	<0.5	<1.5	0.5	<5

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
WCW-8	7/15/97	Terra Services	---	<100	1700	---	---	<0.5	<0.5	<0.5	<1	<0.5	<5
WCW-8	1/5/98	Groundwater Technology Inc	---	<500	<100	1300	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-8	5/26/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-8	11/3/98	Groundwater Technology Inc	---	<300	---	---	2590	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-8	5/6/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
WCW-8	11/18/99	IT Corporation	---	<300	---	---	1100	<0.5	<1	<0.5	<0.5	<0.5	<0.5
WCW-8	5/16/00	Secor	---	<300	---	---	1500	<0.5	<0.5	<0.5	<0.5	1.8	120
WCW-8	8/28/00	Secor	---	<300	---	---	1100	<0.5	<0.5	<0.5	<0.5	0.7	<0.5
WCW-8	11/30/00	IT Corporation	---	<300	---	---	790	0.9	<0.5	<0.5	0.8	<0.5	<0.5
WCW-8	2/5/01	Secor	---	<300	---	---	940	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-8	5/9/01	Secor	---	<300	---	---	520	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-8	9/18/01	Secor	---	<300	---	---	380	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-8	11/8/01	IT Corporation	---	<300	---	---	220	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-8	1/30/02	Secor	---	<300	---	---	530	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-8	4/11/02	Secor	---	<300	---	---	470	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-8	10/24/02	Groundwater Technology Inc	---	<300	---	---	360	<0.5	<1	<1	<1	<0.5	<1
WCW-8	4/10/03	Secor	---	61	---	---	270	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-8	10/11/03	Parsons	---	<100	---	---	430	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-8	5/10/04	Secor	---	55	---	---	160	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-8	11/3/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
WCW-8	5/5/05	Secor	---	<50	---	---	100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-8	11/5/05	Parsons	---	< 100	---	---	210	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-8	5/5/06	Secor	---	< 50	---	---	110	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-8	12/5/06	Parsons	---	< 100	---	---	450	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-8	5/2/07	Secor	---	< 50	---	---	160	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-8	11/14/07	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-8	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.6
WCW-8	10/17/08	Parsons	230	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	1.1
WCW-8	4/21/09	Blaine Tech	---	< 50	---	---	210	< 0.5	< 0.5	< 0.5	< 1	< 0.5	0.59
WCW-8	10/26/09	Parsons	200	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	1.1
WCW-9	11/22/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
WCW-9	7/8/97	Terra Services	---	<100	<500	---	---	<0.5	1.1	<0.5	1.1	<0.5	<5
WCW-9	1/5/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-9	5/19/98	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-9 DUP	5/19/98	Terra Services	---	<300	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-9	11/3/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-9	5/6/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
WCW-9	11/18/99	IT Corporation	---	<300	---	---	<100	<0.5	<1	<0.5	<0.5	<0.5	<0.5
WCW-9	5/16/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-9	11/30/00	IT Corporation	---	<300	---	---	<100	0.6	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-9	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-9	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-9	4/11/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-10	11/25/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
WCW-10	7/8/97	Terra Services	---	<100	<500	---	---	<0.5	2.2	<0.5	<1	<0.5	<5
WCW-10 DUP	7/10/97	Terra Services	---	---	---	---	---	<0.5	2.2	<0.5	<1	<0.5	<5
WCW-10	1/5/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-10	5/19/98	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-10	11/4/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-10	5/5/99	Alton Geoscience	---	<500	<500	---	---	<0.5	0.8	<0.5	<0.5	<1	<0.5
WCW-10	11/17/99	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	0.8	<0.5	<0.5
WCW-10	5/19/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-10	11/30/00	IT Corporation	---	<300	---	---	<100	1	<0.5	<0.5	0.7	<0.5	<0.5
WCW-10	5/10/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-10	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-10	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-11	11/25/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
WCW-11	7/8/97	Terra Services	---	<100	<500	---	---	<0.5	2.5	<0.5	<1	<0.5	<5
WCW-11	1/5/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-11	5/18/98	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-11	11/3/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-11	5/6/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
WCW-11	11/17/99	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-11	5/18/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-11	11/30/00	IT Corporation	---	<300	---	---	<100	0.8	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-11	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-11	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-11	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-12	11/25/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
WCW-12	7/9/97	Terra Services	---	<100	<500	---	---	<0.5	2.5	<0.5	<1	<0.5	<5
WCW-12	1/5/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-12	5/18/98	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-12	11/3/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-12	5/6/99	Alton Geoscience	---	<500	<500	---	---	<0.5	<0.5	<0.5	<0.5	<1	<0.5
WCW-12	11/17/99	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-12	5/18/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-12	11/30/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5

TABLE 9

**HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009**

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toluene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
WCW-12	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-12	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-12	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-12	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
WCW-12	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-12	5/10/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-12	11/3/04	Parsons	---	<100	---	---	3600	<0.5	<0.5	<0.5	---	<0.5	<0.5
WCW-12	3/2/05	Parsons	---	<100	---	---	<100	<0.5	<1	<1	<1	---	<1
WCW-12	5/5/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-12	11/5/05	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-12	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-12	12/8/06	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-12	5/1/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-12	11/13/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-12	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-12	10/17/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-12	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-12	10/27/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-13	11/25/96	GSI	---	<50	<500	<500	---	<0.5	<0.5	<0.5	<1.5	<0.5	<5
WCW-13	7/9/97	Terra Services	---	<100	<500	---	---	<0.5	<0.5	<0.5	<1	<0.5	<5
WCW-13	1/5/98	Groundwater Technology Inc	---	<500	<100	<100	---	<0.5	<0.5	<0.5	<1	<0.5	<0.5
WCW-13	5/18/98	Terra Services	---	---	---	---	---	<0.5	<0.5	<0.5	<1	<0.5	1.4
WCW-13	11/3/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	5/6/99	Alton Geoscience	---	<500	<500	---	---	0.88	3.1	<0.5	0.87	<1	<0.5
WCW-13	11/17/99	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	5/18/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.8	<0.5
WCW-13	8/28/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	11/30/00	IT Corporation	---	<300	---	---	<100	0.6	<0.5	<0.5	<0.5	1	<0.5
WCW-13	2/5/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	0.6	<0.5
WCW-13	9/18/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1	<0.5
WCW-13	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	1/30/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	7/30/02	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
WCW-13	1/28/03	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	7/30/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	1/28/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	5/10/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	7/20/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	11/3/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
WCW-13	2/3/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	5/5/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-13	11/5/05	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	2/28/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	9/20/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	12/8/06	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-13	3/13/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	5/1/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	8/28/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	11/13/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-13	2/21/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	8/13/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	10/17/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-13	2/23/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	7/20/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-13	10/27/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-14	11/3/98	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	1.5	<0.5
WCW-14	5/6/99	Alton Geoscience	---	<500	<500	---	---	1.8	6.6	0.55	3	<1	<0.5
WCW-14	11/17/99	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-14	5/18/00	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-14	11/30/00	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-14	5/9/01	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-14	11/8/01	IT Corporation	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-14	4/9/02	Secor	---	<300	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-14	10/24/02	Groundwater Technology Inc	---	<300	---	---	<100	<0.5	<1	<1	<1	<0.5	<1
WCW-14	4/9/03	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-14	5/10/04	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-14	11/3/04	Parsons	---	<100	---	---	<100	<0.5	<0.5	<0.5	---	<0.5	<0.5
WCW-14	5/5/05	Secor	---	<50	---	---	<100	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
WCW-14	11/5/05	Parsons	---	< 100	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-14	5/5/06	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5

TABLE 9

HISTORICAL ANALYTICAL RESULTS FOR TPH, BTEX, 1,2-DCA, AND MTBE IN GROUNDWATER  
NOVEMBER 1996 THROUGH OCTOBER 2009

Well	Date Sampled	Sampled By	TPH as JP-5 <sup>1</sup>	TPH as Gasoline	TPH as Diesel	TPH as JP-4 <sup>2</sup>	TPH as FP <sup>3</sup>	Benzene	Toulene	Ethylbenzene	Total Xylenes	1,2-DCA <sup>4</sup>	MTBE <sup>5</sup>
WCW-14	12/8/06	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-14	5/1/07	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-14	11/13/07	Parsons	---	< 100	---	---	< 100	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-14	4/18/08	Secor	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-14	10/17/08	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50
WCW-14	4/21/09	Blaine Tech	---	< 50	---	---	< 100	< 0.5	< 0.5	< 0.5	< 1	< 0.5	< 0.5
WCW-14	10/27/09	Parsons	< 100	< 100	---	---	---	< 0.50	< 0.50	< 0.50	< 1	< 0.50	< 0.50

Notes:

1. JP-5 = jet propellant No. 5.
2. JP-4 = jet propellant No. 4.
3. FP = fuel product (collected from north-central plume).
4. 1,2-DCA = 1,2-dichloroethane.
5. MTBE = methyl tert-butyl ether.
6. --- = not analyzed.
7. <500 = not detected above the indicated laboratory reporting limit.
8. DUP = duplicate sample.
9. J = Estimated value
10. J 1= numeric result reported is below the reporting limit and above the method detection limit.
11. SPLIT = A split groundwater sample analyzed by Calscience Environmental Laboratories, Inc.