

November 12, 2010

Mr. Paul Cho, PG, Site Cleanup Unit IV
 California Environmental Protection Agency
 California Regional Water Quality Control Board, Los Angeles Region
 320 W. 4th Street, Suite 200
 Los Angeles, California 90013

**Re: Remedial System Monthly Summary Report for October 2010
 DFSP Norwalk Facility, Norwalk**

Dear Mr. Cho:

Parsons is transmitting the remedial system monthly summary report for October 2010 for the DFSP Norwalk Facility in Norwalk, California. This report will summarize remedial system operation for the month and include description of down time and individual well statistics.

Groundwater Treatment System					October 2010			
Well ID	Flow Meter Readings							
	GW-2/GW-13		GW-15		GW-16		Discharge Total ¹	
Date/Time	Volume (gal)	Flow (gpm)	Volume (gal)	Flow (gpm)	Volume (gal)	Flow (gpm)	Volume (gal)	Flow (gpm)
9/24/10 0:00	System shut down for 4Q2010 GWM event at 10:18. Restart 10/11/10 at 13:31							
10/11/10 7:00	5700519	9.0	2560251	5.0	930008	2.5	51211375	39
10/13/10 13:25	5726811	9.0	2575452	5.0	937030	2.5	51258040	27
10/15/10 15:17	5753725	9.0	2590800	6.0	944293	2.5	51304485	27
10/18/10 9:58	5780366	9.0	2606497	5.5	951564	2.5	51350820	7
10/20/10 14:15 ²	5799209	0*	2617481	0*	956830	0*	51384966	7
10/25/10 10:58 ³	5859439	9.0	2651639	0*	973363	0*	51490408	11
10/27/10 15:05	5884107	9.0	2666792	6.0	980712	2.5	51539000	28
10/29/2010 7:06	5907726	9.0	2679369	5.0	986639	2.5	51576700	15
Total Volume (Gal) Removed from Well	207,207.0		119,118		56,630.6		365,325	

1. Total Discharge processed under NPDES permit no. CAG994004 CI-7585

2. MX-7 filter fouled and in need of replacement. All wells shut down due to reduced GWTS flowrate.

3. Bag and MX-7 filters fouled and in need of replacement. Wells GW-15 and GW-16 shut down due to reduced GWTS flowrate.

Vapor Extraction System	October 2010
System redesign in progress. System not in operation during this reporting period.	

If you have any questions, please call me at 602-734-1083 or Mary Lucas at 626-440-6032.

Sincerely,

PARSONS



Redwan Hassan, PG
Project Manager

Distribution:

Mr. Kola Olowu, DESC-FQ
Mr. Tim Whyte, URS
Ms. Adriana Figueroa, City of Norwalk
Mr. Thomas Lynch, City of Norwalk
Mr. Norman Dupont, City of Norwalk Attorney
Mr. Charles Emig, City of Cerritos
Ms. Nancy Matsumoto, Water Replenishment District of So. CA
Mr. Mark Wuttig, CH2M Hill
Mr. Dan Jablonski, CH2M Hill
Mr. Steve Defibaugh, KMEP
Ms. Mary Lucas, Parsons
Office of Congresswoman Grace Napolitano

RAB Members:

Ms. Mary Jane McIntosh
Dr. Eugene Garcia
Mr. Bob Hoskins
Ms. Tracy Winkler

