

August 13, 2010

Mr. Paul Cho, PG, Site Cleanup Unit IV
 California Environmental Protection Agency
 California Regional Water Quality Control Board, Los Angeles Region
 320 W. 4th Street, Suite 200
 Los Angeles, California 90013

**Re: Remedial System Monthly Summary Report for July 2010
 DFSP Norwalk Facility, Norwalk**

Dear Mr. Cho:

Parsons is transmitting the remedial system monthly summary report for July 2010 for the DFSP Norwalk Facility in Norwalk, California per your request in your email dated July 20, 2010. This report will summarize remedial system operation for the month and include description of down time and individual well statistics.

Groundwater Treatment System							July 2010	
Well ID	Flow Meter Readings							
	GW-2/GW-13		GW-15 ¹		GW-16 ²		Discharge Total ³	
Date/Time	Volume (gal)	Flow (gpm)	Volume (gal)	Flow (gpm)	Volume (gal)	Flow (gpm)	Volume (gal)	Flow (gpm)
6/30/10 12:33	5379187.8	9.5	2443753	0	872443.9	0	50746270	28
7/2/10 14:20	5407477.4	9.7	2443759	0	872469.0	0	50773052	8
7/2/2010 15:30	System shut down ⁴							
7/14/2010 7:44	System restarted ⁵							
7/14/10 14:02	5410765.2	9.4	2443759	0	872469.0	0	50774350	27
7/19/10 8:42	5474728.3	9.5	2443759	0	872469.0	0	50834110	41
7/21/10 5:18	5498171.8	9.5	2443759	0	872469.0	0	50855415	40
7/21/2010 5:37	System shut down ⁶							
Total Volume (Gal) Removed from Well	118,984.0		6		25.1		109,145	

1. GW-15 pump inoperable and out for repair.
2. GW-16 pump inoperable and out for repair.
3. Total Discharge processed under NPDES permit no. CAG994004 CI-7585.
4. System modification evaluated to address selenium exceedance experienced with all wells on-line.
5. System restarted with limited well operation to reduce selenium in the influent. Pumping from GW-2/GW-13 only.
6. System shut down to evaluated further system modifications to address selenium.

Vapor Extraction System

July 2010

System redesign in progress. System not in operation during this reporting period.

If you have any questions, please call me at 602-734-1083 or Mary Lucas at 626-440-6032.

Sincerely,

PARSONS



Redwan Hassan, PG
Project Manager

Distribution:

Mr. Kola Olowu, DESC-FQ
Mr. Tim Whyte, URS
Ms. Adriana Figueroa, City of Norwalk
Mr. Thomas Lynch, City of Norwalk
Mr. Norman Dupont, City of Norwalk Attorney
Mr. Charles Emig, City of Cerritos
Ms. Nancy Matsumoto, Water Replenishment District of So. CA
Mr. Mark Wuttig, CH2M Hill
Mr. Steve Defibaugh, KMEP
Ms. Mary Lucas, Parsons
Office of Congresswoman Grace Napolitano

RAB Members:

Ms. Mary Jane McIntosh
Dr. Eugene Garcia
Mr. Bob Hoskins
Ms. Tracy Winkler

