

100 West Walnut Street • Pasadena, California 91124 • (626) 440-2000 • Fax (626) 440-6200 • www.parsons.com

February 13, 2012

Mr. Paul Cho, PG, Site Cleanup Unit IV California Environmental Protection Agency California Regional Water Quality Control Board, Los Angeles Region 320 W. 4th Street, Suite 200 Los Angeles, California 90013

Re: Remedial System Monthly Operational Summary Report for January 2012
Defense Fuel Support Point Norwalk Facility, Norwalk, California

Dear Mr. Cho:

Parsons is transmitting the remedial system monthly summary report for January 2012 for the Defense Fuel Support Point (DFSP) Norwalk Facility in Norwalk, California. This report will summarize remedial system operation for the month and include description of down time and individual well statistics.

Groundwater Extraction System

In taking into account the planned downtime for routine operation and maintenance (O&M) tasks and permit compliance sampling and not including it, the groundwater extraction system operated for an estimated 98.3 percent for the month of January 2012. System operation was ceased for routine system maintenance as noted in Table 1.

Table 1									
Groundwater Treatment System January 2012									
Well ID	Flow Meter Readings								
	GW-2/GW-13		GW-15		GW-16		Discharge Total ¹		
Date/Time	Volume (gal)	Flow (gpm)	Volume (gal)	Flow (gpm)	Volume (gal)	Flow (gpm)	Volume (gal)	Flow (gpm)	
1/16/2012 12:35 ^{2′3}	8969379.5	9.5	5311462	7.0	2921750	6.8	58794682	30	
1/18/2012 14:16	8994848.6	9.3	5328800	10.0	2939247.0	6.5	58851400	8	
1/19/2012 14:53 ⁴	8998156.0	9.2	5331215	7.0	2941310.0	6.6	58860565	35	
1/20/2012 8:20 ⁵	9007740.5	9.2	5338120	6.5	2948357.0	6.8	58881865	35	
1/23/2012 10:30 ⁴	9028409.5	8.5	5353010	7.0	2963358.0	6.5	58929920	34	
1/24/2012 10:45	9041552.0	9.0	5362295	6.0	2972586.5	6.5	58960120	29	
1/26/2012 11:30 ⁶	9062031.3	0.0	5376849	0.0	2987468.5	0	59006810	8	
1/27/2012 10:30 ⁴	9065312.0	9.2	5379375	7.0	2989822.5	6.8	59016285	34	
1/30/2012 9:15 ⁷	9094878.5	8.7	5399961	7.0	3011460.0	6.6	59083640	25	

Table 1								
Groundwater Treatment System January 2012								y 2012
Well ID	Flow Meter Readings							
Well ID	GW-2/GW-13		GW-15		GW-16		Discharge Total ¹	
Date/Time	Volume (gal)	Flow (gpm)	Volume (gal)	Flow (gpm)	Volume (gal)	Flow (gpm)	Volume (gal)	Flow (gpm)
1/31/2012 11:05	9106762.0	8.9	5408265	6.0	3020150.0	6.6	59110660	22
Total Volume (Gal) Removed from Well	138,569.7		97,892		99,460		320,730	

^{1.} Total Discharge processed under NPDES permit no. CAG994004 CI-7585. Totalizer flow is independent of inlet flows. Inlet well flow is routed to surge tank for storage until water level triggers operation of GWTS.

- 2. GWT system restarted at 11:00
- 3. MX-7 filters replaced.
- 4. Bag and MX-7 filters replaced.
- 5. Weekly TBA compliance sample collected.
- 6. Monthly NPDES compliance samples collected. Remote wells shut down by high surge tank level.
- 7. Bag filters replaced.

Vapor Extraction System

The vapor extraction system operated continuously for the month of January 2012 except for planned O&M tasks and routine sampling (as indicated on Table 2). Therefore, not including the planned downtimes, the vapor extraction system operated 100 percent during January 2012. System operation is summarized in Table 2. Vapor extraction wells VEW-32, VEW-33, VEW-34, VEW-35, VEW-36 and VEW-37 (Eastern Boundary Wells) and horizontal wells HW-1, HW-3, HW-5 and HW-7 (covering the expanse of the above ground storage tank area) where on-line during operation for this reporting period.

Table 2									
Vapor Extraction System January 201									
	Run	VES		GAC-1		GAC-2		GAC-3	
	Time	Flow	Temp	Pres.	Temp	Pres.	Temp	Pres.	Temp
Date/Time	(Hours)	(cfm)	(deg,F)	(In w.c.)	(deg, F)	(In w.c.)	(deg, F)	(In w.c.)	(deg, F)
1/13/2012 15:00 ¹	7571.5	153	100.2	17	84	11	70	7	70
1/16/2012 12:45	7674.3	158	114.1	18	90	12	92	8	85
1/18/2012 14:47	7691.3	157	125.8	18	100	12	99	6.5	88
1/19/2012 14:06	7714.5	154	122.7	18	98	12	98	7	86
1/20/2012 8:35 ²	7733.0	158	110.8	18	92	12	84	7	80
1/23/2012 8:45	7805.2	108	99.1	18	72	12	80	7	72
1/25/2012 11:00	7855.6	149	132.6	18	106	12	96	7	86
1/26/2012 11:552′3	7880.4	136	140.2	18	114	12	104	7	92
1/27/2012 10:40	7903.1	171	110.1	18	114	12	104	7	92
1/30/2012 7:55	7972.4	170	89.6	21	76	15	74	9	70



Mr. Cho

Remedial System Monthly Summary Report for January 2012

Footnotes:

- 1. VES system restarted at 14:50
- 2. VES weekly PID readings taken.
- 3. Monthly compliance samples collected. VES operating temperature exceeded permit limit (140 deg,F), dilution valve was opened to lower temperature.

cfm-cubic feet per minute

In w.c.-Pressuremeasured in inches of water column

"Hg-Pressure measured in inches of mercury

psi-Pressure measured in pounds per square inch

If you have any questions, please call me at 602-734-1083 or Mary Lucas at 626-440-6032.

Sincerely,

PARSONS

Project Manager

Redwan N. Hassan, PG

Distribution:

Mr. Matthew Young, DLA-E

Mr. Tim Whyte, URS

LTC Tam Gaffney, March AFB

Ms. Adriana Figueroa, City of Norwalk

Mr. Norman Dupont, City of Norwalk Attorney

Mr. Charles Emig, City of Cerritos

Mr. Mark Wuttig, CH2M Hill

Mr. Dan Jablonski, CH2M Hill

Mr. Steve Defibaugh, KMEP

Ms. Mary Lucas, Parsons

Office of Congresswoman Grace Napolitano

RAB Members:

Ms. Mary Jane McIntosh

Dr. Eugene Garcia

Mr. Bob Hoskins

Ms. Tracy Winkler

